

# **FIELD QUALITY PLAN**

**FOR**

**Name of work:- Improvement of storage facility of IMM store  
inside factory area**



**FACTORY CIVIL DEPARTMENT**

**BHARAT HEAVY ELECTRICALS LIMITED**

**BHOPAL**



BHOPAL  
FACTORY CIVIL DEPARTMENT

## AUTHORISATION FOR DIFFERENT CATEGORIES OF CHECKS

Classification of Check		Inspection Authority BHEL	Clearing Authority BHEL
Symbol	Description		
A	Critical	Engineer-in -charge	Sr. Engineer-in -charge
B	Major	Engineer-in -charge	Sr. Engineer-in -charge
C	Minor	Engineer-in -charge	Sr. Engineer-in -charge

NOTE :

- 1 Quantum of check shall be 100% for all characteristics unless otherwise mentioned in reference documents. Contractors will be responsible for getting the work inspected by inspecting authority after carrying out inspection by themself as per Field Quality Plan.
- 2 In case of non-conformity, before accepting, clearing agency shall ensure disposition and the same shall be reflected in the log-sheet /protocol.
- 3 For checks where log sheets are not called for, suitable records shall be maintained in the form of log book / protocols.
- 4 Abbreviations used in the column "Type of Check" are  
R : Record Verification  
M : Measurement  
W : Witness  
T : Test
- 5 Abbreviations used in the column "Format of Record" are  
SR: Site Register  
TR : Test Report
- 6 In case of non-availability of inspecting/clearing authority of prescribed level the job shall be performed by higher authorities or the persons authorized by sectional head

 <b>BHOPAL</b>	<b>Name of work:- Improvement of storage facility of IMM store inside factory area.</b>					<b>DOC NO: FQP</b>		
					<b>REV NO: NIL</b>			
<b>Field Quality Plan</b>								
S No.	CHARACTERISTICS / ITEM	TYPE OF CHECK	INSTRUMENT	CLASS	QUANTUM/ FREQUENCY OF CHECK	REFERENCE DOCUMENT/ ACCEPTANCE STANDARD	FORMAT OF RECORD	REMARKS
1	<b>GALVALUME SHEET</b>							
1.1	Relevant tests as per manufacturer specifications	T	IS 15965 or AS-1397 or relevant standard of ASTM	A	For each lot of supply	IS 15965 or AS-1397 or relevant standard of ASTM	Test record	Manufacturer test report to be submitted