

INVENTORY No.	SIGN. & DATE	REF. DRG. No.	E	D	C	B	A	DRG. No.	2	3	4	5	6	7	8									
									BILL OF QUANTITY (FOR INVERTER ROOM)															
									FACP Fire Alarm Panel Manual Call Point Hooter with strobe Smoke detector 2CX1.5sqmm Armoured cable								1 Nos 1 Nos 1 Nos 3 Nos As required							
																	1. All dimensions are in mm. 2. Fire alarm system cable shall be minimum size 2CX1.5 sqmm armoured PVC cable. 3. Cable shall be laid concealed in PVC conduits.							
									REV. DATE ALTERED CHECKED APPROVED								REV. DATE ALTERED CHECKED APPROVED							
DRAWN AK 210619								CHECKED SP 210619																
APPROVED PR 210619								DISTRIBUTION OF PRINTS								DEPT. CODE								
1								2		3		4		BHEL DRG. No.		TENDER PURPOSE ONLY								

PROJECT TITLE : SCCL SOLAR POWER PROJECTS TELANGAMA
OWNER : SCCL

BHARAT HEAVY ELECTRICALS LIMITED.
ELECTRONICS DIVISION, BANGALORE

TITLE:
ICR-FIRE AND SMOKE DETECTION LAYOUT

No. OF SHEETS	01
SHEET No.	01
REV	01