



	BHEL: BAP: RANIPET Water Business Pre-Qualification requirement for LT XLPE POWER CABLE	Ref:	RWT80719 PCAB:PQ
		Dt:	18.12.18
		Rev :	00

The Qualification requirements for LT power cables are detailed below and Bidders should meet the same. Offers of bidders who do not meet qualification requirement will not be considered.

Item : LT XLPE POWER CABLE Supply : YES Erection & Commissioning : NO	
1	Vendor should be a manufacturer of LT power cables
2	Established in-house facility to carry out all routine, type & acceptance tests as per relevant ISI International Standards on LT XLPE FRLS power cables (except UV radiation & hydrolytic stability test which can be conducted at Govt. Lab / Govt approved Independent lab).
3	Capacity of manufacturing 30 km of LT Power cables per month
4	Minimum two (2) nos. purchase orders of quantity more than 5 kms for LT XLPE Power Copper cables shall be submitted which should not be more than two (2) years old from the date of enquiry or the date (22.09.2015) for establishing continuity in business.

General Conditions:

1. Bidder shall furnish necessary documentary evidence in original / notarized (legible) copy as a proof of meeting the qualifying criteria for the review by BHEL. Acceptance of documentary evidence rests with BHEL.
2. Bidders who defaulted, in any of the previous tenders floated by BHEL are not permitted to respond. Such offers, if found later, will not be considered for evaluation.
3. After receipt of offers, during scrutiny, if any vendor found to have been banned by BHEL, then their offer will be summarily rejected at any stage.

Prepared by  (18/12/18)	Checked by  18-12-18	Approved by 
--	---	--