

CORRIGENDUM-2 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 1699

Sub: Levelling and Grading Works Containing Package-1 and Package-2 for 5 x 800MW Yadadri Thermal Power Station at Veerlapalem village, Dameracherla Mandal, Nalgonda district, Telangana state

A. The following clauses in of Clause No. 1.0 Salient Features of NIT in NOTICE INVITING TENDER are revised as below: -

Description	As Per Tender	Revised as
Sl. No v) Due Date & Time of Offer Submission	07.12.2017, 15.00 HRS	14.12.2017, 15.00 HRS
Sl. No vi) Opening of Tender	07.12.2017, 15.30 HRS	14.12.2017, 15.30 HRS

B. The following clarification was sought in regard to subject Tender and BHEL's clarification is furnished below for information.

Sl no	Query	BHEL Reply
1	<p>The entire earthwork in excavation shall either be in soft rock or in hard rock. The hard rock shall be excavated by open blasting or controlled blasting. The quantity/level to be finally excavated may not be controlled to the stipulated level as per level mentioned in drawing and over excavation may take place as the blast may upload with lower intensity or higher intensity.</p> <p>Kindly clarify regarding tolerance/ variance limit and the process to deal with such conditions.</p>	<p>The trailing Clause is added as point No. (g) Under Clause No. 6.02 Measurements, of Volume IA Part II Chapter 2 Sub-Section D-22: Technical Specification for Site Levelling & Grading Works.</p> <p>(g)</p> <p>i. The final cutting level shall be maintained as per the level specified in drawing/specification.</p> <p>ii. The allowable tolerance for the final cutting level shall be limited to maximum of 100mm on both down and upper side of the specified level as per drawing/specification.</p> <p>iii. The excess excavated area shall be filled by the bidder with good quality of earth at their own cost, in case the excavation in the downside exceeds more than the allowable limit specified above.</p> <p>iv. No further blasting shall be carried out in the excavated areas, in case excavation in the upper side is less than the allowable specified above.</p> <p>v. The payment shall be as per the actual measurement for the works executed with in the allowable limits specified above.</p>

NOTE:

1. ALL OTHER CONDITIONS REMAIN UNCHANGED.
2. BIDDERS ARE REQUESTED TO CONSIDER THIS CORRIGENDUM AS PART OF TENDER SPECIFICATION AND QUOTE ACCORDINGLY.

AGM / SCT & Purchase