

**Corrigendum 2 dated Jan 12, 2018 to Tender Specification BHEL PSSR SCT 1702**

A) Some of the bidders had raised queries in the published tender specification. The Clarifications issued by BHEL are furnished below:

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
1	Scope of Works	Volume - IA - Part I - Chapter -II, Clause 1.2.7	The area of work shall be cleared of all vegetation, rubbish and other objectionable matter and materials removed shall be burnt or otherwise disposed of as directed by the Engineer-In-Charge.....	Vegetation clearance shall be done by Keller. Necessary permission for clearance from relevant authorities to be obtained by BHEL.	Clearance for vegetation removal shall be obtained by BHEL.
2		Volume - IA - Part I - Chapter -II, Clause 1.3.9	All the works areas shall be adequately flood lighted to the satisfaction of Engineer-in-charge when the work is in progress during the night shifts.	Agreed.  Permit for Round the clock working to be provided by BHEL from day one.	Round the clock working shall be permitted by BHEL. Vendor shall submit plan for round the clock working.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
3	Terms of Payment	Volume - IA - Part I - Chapter - VII, Clause 1.7.3	Interim Payment. 1.7.3.2 95% item rate shall be released after completion of works and certification by Engineer in charge 1.7.3.3 5% of item rate shall be released after submission of the quality check formats /documents as per the quality plan for a quantum of work billed and duly certified by Engineer in charge.	Due date for certification shall be specified?	Tender Condition prevails.
4		Volume - IA - Part -II, Chapter 1, S.No. 12	The payment for running bills will normally be released within 30 days of submission of running bill complete in all respects with all documents.	Agreed. Due date for certification shall be specified?	Tender Conditions prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
5	Price Variation Claim	Volume - IA - Part -II, Chapter 1, S. No. 7, Clause 2.17.2, 2.17.5, 2.17.9	85% component of executed contract value is considered for PVC calculations and remaining 15% considered as fixed component..Base date: Actual date + schedule completion date.PVC shall be applicable only, during extended period of contract (if any) after the scheduled completion period and for the portion of work delayed/backlog for the reasons not attributable to the contractor.PVC claim not applicable for force majeure.Total PVC claim shall not exceed 15% of the cumulatively executed contract value.	PVC calculation apply for 100% of the Contract value.	Tender Conditions prevails.
6	Security Deposit	Volume - IA - Part -II, Chapter 1, S. No.2, Clause 1.10.9	The validity of Bank Guarantees towards Security Deposit shall be initially upto the completion period as stipulated in the Letter of Intent/Award + 3 months, and the same shall be kept valid by proper renewal till the acceptance	Cap on Security Deposit BG validity. Due date for certification of final bill ?	Tender Condition prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
			of Final Bills of the Contractor, by BHEL		
7	Quantity variation	Volume - IA - Part -II, Chapter 1, S. No. 6,	<b>Clause 2.14.1 in GCC regarding Quantity Variation:</b> Clause 2.14.1 in GCC is revised as "The quantities given in the contract are tentative and may change to any extent (both in plus side and minus side). The quoted rates for individual items shall remain firm irrespective of any variations in the individual quantities. No compensation becomes payable in case the variation of the final executed contract value is within the limit of Minus (-) 30% of awarded contract value.	Variation shall be $\pm$ 10% and beyond that rates shall be raised at mutually agreed terms.	Vendor to bid as per tender conditions.
8	Work Permit beyond normal working hours	Volume - IB - Special conditions of Contract, Rev 01 dated 1st June 2012, Amendment 01 dated October 01, 2015 Clause 5.13	It is the responsibility.....the Contractor shall arrange necessary work permit for working beyond normal working hours.	Permit to Round the clock working to be provided by BHEL from day one.	Round the clock working shall be permitted by BHEL. Vendor shall submit plan for round the clock working.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
9	Price Variation Claim	Volume - IB - Special conditions of Contract, Rev 01 dated 1st June 2012, Amendment 01 dated October 01, 2015 Clause 10.3	Release of payment in each running bill including PVC Bills where ever applicable will be restricted to 95% of the value of work admitted as per stages of progressive pro rata payments.	PVC on 100% work done value?	Tender Condition prevails.
10	RA Bill Payment	Volume - IB - Special conditions of Contract, Rev 01 dated 1st June 2012, Amendment 01 dated October 01, 2015 Clause 10.5	The payment for running bills will normally be released within 30 days of submission of running bill complete in all respects with all documents. It is the responsibility of the contractor to make his own arrangements for making timely payments towards labour wages, statutory payments, outstanding dues etc and other dues in the meanwhile. In case of Civil works, 60% of RA Bills complete and correct in all respects and certified by BHEL Engineer, shall be paid within 15 days of receipt. Balance payment shall be within 30 days.	Due date for certification?	Tender condition as per sl no. 12 of Volume-IA Part-II Chapter-1 prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
11	Return of Security Deposit	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 1.11	Security Deposit shall be refunded / Bank Guarantee(s) released to the Contractor along with 'Final Bill' after deducting all expenses.....with them by BHEL.	Due date for final bill certification?	Tender Condition prevails.
12	Bank Guarantees	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 1.12 iii)	It is the responsibility of the bidder to get the Bank Guarantees revalidated/extended for the required period (subject to a minimum period of six months), as per the advice of BHEL Site Engineer / Construction Manager. BHEL shall not be liable for issue of any reminders regarding expiry of the Bank Guarantees.	BG shall be extended based on the project requirement.	Tender Condition prevails.
13	Measurement of work and mode of payment - Final bill	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.6.11	.....The final bill shall be prepared and paid within a reasonable time after completion of work.	Clarity on final bill certification & payment?	Tender Condition prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
14	Interest bearing recoverable advances	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.13	Interest bearing advance ..... CHECK	Interest free advance payment upon signing of LOI/LOA.	i) This clause is to be read in conjunction with sl no. 5 of Volume-IA Part-II Chapter-1. ii) Tender Condition prevails.
15	Quantity variation	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.14	The quantities given.....	Rate revision allowed for reduced quantity. Whereas rate revision for increase in quantity?	i) Clause 2.14 to be read in conjunction with sl no. 6 of Volume-IA Part-II Chapter-1. ii) Tender Conditions prevails.
16	Force Majeure	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.20.2	If the contractor suffers delay due to force majeure events,..... time allowed and shall not be eligible for compensation.	Demob proposal for prolonged duration (or) pay standby charges.....	Tender condition prevails.
17	Retention Amount	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.22		Clarity on final bill certification & payment? No cash retention, BG shall be submitted from day 1 valid until	Tender condition prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
				completion of DLPC	
18	Final Bill	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.23.2	.....BHEL shall settle the final bills after deducting all liabilities of Contractor to BHEL	Clarity on final bill certification & payment?	Tender condition prevails.
19	Closing of Contract	Volume - IC - General conditions of Contract Rev 01 dated 1st June 2012, Amendment 03 dated October 2015 Clause 2.25	<b>2.25 Closing of Contracts</b> The Contract shall be considered completed and closed upon completion of all contractual obligations and settlement of Final Bill or completion of Guarantee period whichever is later. Upon closing of Contract, BHEL shall issue a completion certificate as per standard format, based on specific request of Contractor.	JCC upon completion of practical activity?	Tender condition prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
20	Cut off level of Piles	SCT_1662_VOLUME_II_PRICE BID_Package 1, Ref.No. 2504.0	...(length to be measured from pile cut-off level to the bottom of pile... )	Bidder needs to understand the depth of Cut off level (COL) from Estimated ground level (COL). Kindly provide.	Pile cut off levels for different structures shall vary and the same shall be furnished in respective pile layout drawings during detailed engineering. However, minimum depth of pile cut off level is 3 m below existing ground level.
21	Empty boring	SCT_1662_VOLUME_II_PRICE BID_Package 1, Ref.No. 2504.0	...(length to be measured from pile cut-off level to the bottom of pile)...	Will the boring depth from estimated ground level to pile cut off level be considered for payment separately?	No. The cost of empty boring from ground level to pile cut off level is already included in the item no. A 2504.
22	Empty boring	SCT_1662_VOLUME_II_PRICE BID_Package 1, Ref.No. 2504.1	...(length to be measured from pile cut-off level to the bottom of pile)...	Bidder is requesting the over all pile layout.	Pile layout drawings will be furnished during detailed engineering.
23	Ground water level and Pile cut of level	VOLUME: II B SECTION – C SPECIFIC TECHNICAL REQUIREMENTS SPECIFICATION NO: PE-TS-412-600-C026, f) Concrete Level – finishing of pile head	....Concrete shall be cast to minimum of 500 mm above the cut-off level, or local ground water level, whichever is higher....	Requesting you to provide the difference of ground water level and pile cut off level to understand the quantity of overcast	Generally the depth of ground water table varies from 1 to 1.5 m below existing ground level.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
				required to be done.	
24	Permission for sub contracting	VOLUME-IC GENERAL CONDITIONS OF CONTRACT (GCC) Rev 01, 1st June 2012 Amendment 03, 01st October 2015, Clause 1.15.9	The successful tenderer should not sub-contract part or complete work detailed in the tender specification undertaken by him without written permission of BHEL's Construction Manager/Site Incharge.	Bidder understand that permission from BHEL is required for sub-contracting. But Is subcontracting applicable for the successful bidder? If yes, a) Is multiple subcontracting applicable? b) Is subcontracting applicable for part or full job?	Tender condition prevails
25	Confirmation for tractor mounted rigs	VOLUME – I Part I & II TECHNICAL CONDITIONS OF CONTRACT (TCC), PART-I CHAPTER-IV, Clause 1.4.2.	7 NOS HYDRAULIC ROTARY PILING RIGS.	Bidder want to confirm if tractor mounted rigs/DMC are allowed in any condition or not.	Not allowed.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
26	Muck removal	SCT_1702_VOLUME_II_PRICE BID, Ref.No : 2504.0	Installation of Bored cast-in-situ RCC vertical pile...	<p>BCIS piling generates considerable amount of soil muck which need to be disposed to maintain proper platform to continue piling and ensure safety. Bidder wants to know who shall be responsible for muck disposal?</p> <p>If the bidder is responsible for muck disposal, what shall be the maximum lead for this muck disposal and will it be paid separately to the successful bidder?</p>	<p>Bidder shall dispose the muck with a lead of 3Km. Items rate is inclusive of cost of disposal.</p>

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
27	Working hours	SPECIAL CONDITIONS OF CONTRACT (SCC) Chapter – V : Responsibilities of Contractor in respect of Labour, Supervisory Staff, etc., Clause : 5.13	...Where permitted, by customer / BHEL, to work beyond normal working hours, the contractor shall arrange necessary work permits for working beyond normal working hours	What will be the normal working hours and working days?  Is 'round the clock'(24 hours) work permitted for the successful bidder's scope of works mentioned in the tender?	Round the clock working shall be permitted by BHEL. Vendor shall submit plan for round the clock working.
28	Bill certification	SPECIAL CONDITIONS OF CONTRACT (SCC): Chapter-X: RA Bill Payments, Clause:10.5	In case of Civil works, 60% of RA Bills complete and correct in all respects and certified by BHEL Engineer, shall be paid within 15 days of receipt. Balance payment shall be within 30 days.	How much time will be taken for the certification of Monthly RA bill after submission by the successful bidder to BHEL?	Tender condition as per sl no. 12 of Volume-IA Part-II Chapter-1 prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
29	Reinforcement couplers	SCT_1702_VOLUME_II_PRICE BID : Bill of Quantities Ref 406.0	Supply and fixing reinforcement bar couplers (of approved manufacturer's as per the relevant IS code) in position for steel reinforcements of TMT steel of grade Fe-500D or 500EQR confirming to IS:1786 including , labour, scaffolding, transportation to & from stores etc complete all as per specifications, drawings and as directed by Engineer.(Agency has to supply reinforcement bar couplers).	a) Kindly clarify the make of couplers. whether Cold forged couplers or hot forged couplers to be used. b) Some of the reinforcement bars are odd in size like 28mm and 36mm as per market availability. Same way couplers are also odd sized. Kindly clarify.	a)Only cold forged couplers are to be used. Make of the coupler to be approved by BHEL before usage. B) 28mm and 36mm are both available in the market.
30	Carriage for disposal of unservicable material	SCT_1702_VOLUME_II_PRICE BID : Bill of Quantities Ref 2601	Carriage for disposal of unservicable material	Identifying the dumping yard is in BHEL scope? If yes requesting you to provide the maximum lead for dumping yard?	Maximum lead for Dumping yard location is approximately 2 Km

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
31	Routine Load Test	SCT_1702_VOLUME_II_PRICE BID : Bill of Quantities	Routine Load Test	Bidder is requesting to conduct the routine load test at ground level. And test load for various pile diameter is required for kentledge setup arrangements.	Routine load test shall be conducted at pile cut off level only as per respective piling layout drg. The test load is 1.5 times the design pile capacity in Vertical compression and in lateral case. The tentative design pile capacities are as below 1. 600 mm dia 75 MT (Vertical), 8.40 MT (Lateral), 20 MT (Uplift) 2. 600 mm dia 150 MT (Vertical), 8.40 MT (Lateral), 35 MT (Uplift) 3. 760 mm dia 250 MT (Vertical), 12.30 MT (Lateral), 40 MT (Uplift) However, the final design pile capacities shall be furnished in job pile drawing during detailed engg.
32		Advance for Mobilization - VOLUME-IA PART-I CHAPTER-VII TERMS OF PAYMENT 1.7.1 Advance for Mobilization	Interest bearing advance for Mobilization, limited to 5% of the contract value will be paid against submission of bank guarantee of at least 110% of the advance valid for	Bidder requests client to consider interest free mobilization advance.	Tender condition prevails.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
			the contract period, which will be recovered from the first running bill .		
33		Drawings	General	Kindly provide the drawing for the following 1. Pile Layout 2. Pile cross section 3. Reinforcement Detailing 4. Pile cap and pedestal	Drawings will be provided progressively during execution
34		SCT_1702_VOL UME_II_PRICE BID, Ref.No : 2504.0,	Muck Removal Scope	1.Bidder wants to know who shall be responsible for muck disposal? 2.If the bidder is responsible for muck disposal, what shall be the maximum lead for this muck disposal and identify the dumping area.	Bidder shall dispose the muck with a lead of 3Km. Items rate is inclusive of cost of disposal.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
35		NIT Clause 9.0	Assessment of Capacity of Bidders	Bidder understands that Assessment Capacity will be done for ONLY ONGOING PACKAGES with BHEL ONLY. In case the bidder is currently not working with BHEL, this clause will NOT BE APPLICABLE, please clarify	Tender Condition prevails.
36		NIT- Clause 1.0 sl. no. vii	EMD Amount	In case of bidders quoting for both packages EMD shall be Rs.51,50,000/- .Kindly Confirm?	EMD Amount Rs. 51,50,000/- is irrespective of number of packages.
37		TECHNICAL CONDITIONS OF CONTRACT (TCC)	Material Supply -1.13.2 STEEL MATERIAL 1.13.2.1 ISSUE OF STEEL	Bidder wants to know who shall be responsible for supply of Mild Steel , Earthing rod MS round. Structural	As per Vol-1A, Part-1, Chapter-III, clause 1.3.7, the reinforcement steel shall be supplied at free of cost

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
				Steel, Stainless steel.	
38	General		Tender Drawings	Kindly issue Tender Drawings showing pile layout and foundation details or pile cross section drawing.	Drawings will be provided progressively during execution
39	BOQ Item no.A403		In BOQ Reinforcement steel is not mentioned as free supply whereas as per clause no.1.3.7.1 of TCC, cement and steel shall be supplied free of cost by BHEL.	Please include in BOQ that Reinforcement Steel shall be supplied free of cost by BHEL.	As per Vol-1A, Part-1, Chapter-III, clause 1.3.7, the reinforcement steel shall be supplied at free of cost
40	BOQ Item no.A2504		BOQ indicates empty boring to be included in this item.	Please indicate length of empty boring measured from working ground level upto pile cut off level	The cost of empty boring from ground level to pile cut off level is already included in the item no. A 2504.
41	BOQ Item no.A2504		BOQ indicates muck disposal is in Contractor's scope.	Please confirm the lead for muck disposal and debris disposal within the	Bidder shall dispose the muck with a lead of 3Km. Items rate is inclusive of cost of disposal.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
				site premises or outside.	
42	BOQ Item no.2512.0		As per clause no.5.02.00 of Specification BTG EPC contract the capacities are indicated for 600mm, 650mm, 700mm, 750mm & 800mm for length of piles of depth 13m below existing ground level whereas in BOQ the depth of piles below cut off level for 600mm and 760mm is mentioned as 14m and 23m and as per clause no.2.04.00 capacities are as per Annexure A but capacities are not mentioned in Annexure A.	Please mention the vertical, lateral and pull out capacities for the respective diameters based on the length indicated in BOQ.	The tentative design pile capacities are as below 1. 600 mm dia 75 MT (Vertical), 8.40 MT (Lateral), 20 MT (Uplift) 2. 600 mm dia 150 MT (Vertical), 8.40 MT (Lateral), 35 MT (Uplift) 3. 760 mm dia 250 MT (Vertical), 12.30 MT (Lateral), 40 MT (Uplift) However, the final design pile capacities shall be furnished in job pile drawing during detailed engg.
43	BOQ Item no.2512.0		In BOQ only routine pile load tests has been indicated. As per clause no.18.08.00 of Specification for BTG EPC contract initial load tests to be conducted prior to working piles.	Please confirm whether initial load test has to be conducted or not.	Conducting Initial pile load test is not in the scope of this tender.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
44			As per BOQ the IS Code mentioned was IS 4968, Part I, whereas as per clause no.5.07.00 of Specification for BTG EPC contract it indicates IS 4968, Part II.	Please indicate which specification / IS to be followed.	IS 4968 Part-I is to be followed.
45	BOQ Item no.A2504		As per IS 4968 Part I Dynamic Cone Penetration test has to be conducted in cohesionless soils the depth may be limited to 5m and in mixed soil with binding material the depth may be 10m. But as per BOQ, the maximum depth upto 27m below cut off level has to be conducted.	Please clarify.	Technical specification & BOQ to be followed.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
46	BOQ Item No. A2518		<p><b>Item Description :</b>            Conducting Ultrasonic Pulse Velocity (UPV) Test as per IS 13311, Part-1 on job piles as per specification and as per direction of Engineer-in-charge.</p>	<p>Since the unit of Item is in Cubic Meter, Kindly clarify that, upto what depth, the pile has to be tested and clarify the mode of measurement.</p> <p>Also clarify whether the excavation involved in testing shall be paid under relevant item or to be included in the item rate. Please provide specification for ultrasonic pulse velocity (UPV) test.</p>	<p>UPV test shall be conducted on piles for 1 m length above pile cut off level. Mode of measurement is cubic meter of concrete considering 1 m of pile length to be tested. Since UPV testing is to be done above pile cut off level, hence no additional excavation is required for this test. UPV test shall be conducted as per IS 13311 Part-1.</p>
47	TCC, Clause no.1.3.3		Contractor has to make his own arrangements for labour colony.	Please provide land for labour colony free of cost inside or outside the premises of site.	Tender condition prevails

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
48	TCC, Clause no.1.3.5		Construction water required for construction purposes shall be arranged by the bidder.	Since the water resources are not available in the nearest areas please confirm the water is provided by TANGEDCO / BHEL on chargeable basis.	Construction water is under the scope of the bidder. However if water is made available by BHEL the same shall be provided to the bidder on chargeable basis.
49	TCC, Clause no.1.3.7.4		Riversand to be used for construction purpose.	As per our site visit, river sand is not available and T.N. Government not permitted for the sand quarries. Therefore, we request you to change the specification to use M.Sand and accordingly issue necessary corrigendum or specify the basic price of river sand. Please confirm.	M-Sand shall be used with the approval of BHEL/TANGEDCO. Please refer Vol-1A, Part-1, Chapter-III for more details on Msand usage.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
50	TCC, Clause 1.4.2 (T&Ps and MMEs TO BE DEPLOYED BY CONTRACTOR)		<b>Requirement</b> :2 nos. <b>Portable automatic concrete batching plant (Output 30 cum / hr)</b> with printing facility and independent DG Backup.With minimum 2 nos. of cement silo (100MT each) for each batching plant.	Is there any specific requirement of Portable batching plant to be engaged for the work or we shall use normal static type Batching Plant of the required capacity ?. Kindly clarify.	Static automatic Batching plant with other requirement as specified in Sl.No.6 of clause 1.4.2 shall also be used
51	TCC, Clause no.1.7.3		As per TCC Interim payment "95% item rate shall be released after completion of work. Balance 5% shall be released after submission of quality check". But as per cl.no.10.4 of R.A.Bill payments in SCC 5% shall be considered as Retention Amount.	Please clarify whether Retention is applicable.	Tender conditions prevail.
52	Clause no.5.03.00 of specification of BTG EPC contract.		Detailed geotechnical investigation to be conducted by contractor / EPC contractor on award of work.	Please confirm whether soil investigation has to be conducted or not. If to be conducted please	Soil investigation will be conducted by BHEL.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
				indicate the items in BOQ.	
53	Clause no.11.01.03 of specification of BTG EPC contract.		Contractor has to provide 700 sq.m. of office area with AC and false ceiling, conference room to accommodate 70 people, covered parking area of 10 cars.	Please indicate whether these facilities has to be provided by Bidder.	Facilities need not be provided by contractor
54	Clause no.18.03.00 of specification of BTG EPC contract.		Design criteria " Piles shall be designed in line with approved soil investigation report".	From the BOQ, we understand that pile design is not in our scope; Please confirm.	Pile Design is in the scope BHEL
55	Specification.		Metal doors, windows, ventilators, louvers, glass and glazing, miscellaneous metal siding, painting, white washing, sheet work and finishing etc. technical specification has been given in tender document.	These miscellaneous items are not available in BOQ. We presume that these specifications are not applicable for our scope of work.	Metal doors, windows, ventilators, louvers, glass and glazing, miscellaneous metal siding, painting, white washing, sheet work and finishing are not in the scope of the contractor
56	E-tender			Please indicate the maximum size of of files to be uploaded.	Each file can be of maximum 15MB size.

Sl. No.	Description	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
57	NIT			Please clarify whether DD for tender document has to be obtained in the name of "BHARAT HEAVY ELECTRICALS LIMITED" payable at Chennai.	DD for tender document has to be obtained in the name of "BHARAT HEAVY ELECTRICALS LIMITED" payable at Chennai
58	TCC, Cl.no.1.3.7.1		Cement and steel reinforcement free supply by BHEL.	Please clarify whether the testing of free issue materials shall be in the scope of Owner of Bidder.	Cement as per field quality plan shall be tested by the vendor. Steel testing is not required.
59	General			Please confirm whether temporary approach road for different units shall be provided by BHEL.	Temporary approach road will not be provided by BHEL.

All other conditions of the tender specification remain unchanged.

Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-  
AGM / Subcontracts & Purchase