

CORRIGENDUM - 1 TO TENDER SPECIFICATION BHEL PSSR SCT 1738 - DT: 18.05.2018

TENDER SPECIFICATION BHEL PSSR SCT 1738 - Hiring of One number suitable capacity Heavy Duty Hydraulic Crawler Crane At BHEL
2X660MW Ennore SEZ STPP, Vayalur BR PO, Minjur Tamilnadu State

<u>Sl. No.</u>	<u>Bidder's Query</u>	<u>BHEL reply</u>
1	Please let us know what are the radius requirements for the lifts. i.e. for Ceiling Girder, Welded beams and Silencer erections.	Minimum radius of 16 to 20 m is required.

Note:-

All other Terms & Conditions remain unchanged. Bidders are requested to consider this Corrigendum as part of the Tender Specification and quote accordingly.

-sd-
R.Siva
Sr.Engineer/SCT