

Corrigendum 3 dated Sep' 25, 2019 to Tender Specification BHEL PSSR SCT 1852

Corrigendum 3 dated Sep' 25, 2019 to Tender Specification BHEL PSSR SCT 1852 for the work of Erection, Testing & Assistance for Commissioning and Trial Operation of Boiler & Auxiliaries, Air Pre Heaters, Ducts & Dampers, Boiler Integral Piping, Fans, Bowl Mills, Rotating Equipment etc. of Unit 1, Auxiliary Boiler & Auxiliaries, Application of Refractory and Insulation, Supply and Application of Final Painting including Handling of Materials at BHEL / Client's Stores / Storage Yard and transportation to site of Erection at 2x800 MW Uppur Super Critical Thermal Power Project, Ramanathapuram Dist., Tamil Nadu

1) Some of the Bidders had asked queries in the published Tender Specification. The clarifications issued by BHEL are furnished herewith: -

SI No.	Ref. Clause	Existing Provision	Bidder's Query	BHEL Reply
1	Technical Conditions of Contract (TCC) Volume-1A - Part-1 - Chapter - IV - T&Ps and MMEs to be deployed by Contractor – Clause 1.4.1, SI No. 3	40 T Crawler Crane - 01 No.	Can we deploy 40 Ton Tyre mounted crane instead of 40 Ton crawler crane for ease of Erection/ Loading/ Unloading activities- Please clarify	Tender condition prevails
2	Technical Conditions of Contract (TCC) Volume-1A - Part-1 - Chapter - III - Facilities in the scope of contractor / BHEL (Scope of Matrix) - SI.No. 1.3.1.3	Water Supply	Please clarify the Scope of supply of DM water for Construction/ Testing/ Commissioning purpose i.e. Hydro test/ Flushing etc.	1. Water for construction and drinking purpose to be arranged by the bidder. 2. DM Water required for Hydro-testing/ Steam blowing/ other commissioning activities will be provided by BHEL/ Customer

All other conditions of the tender specification remain unchanged.

Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-
Sreenath N G
Deputy Manager/ SCT