

**Corrigendum 6 dated Dec' 07, 2019 to Tender Specification BHEL PSSR SCT 1866** for Structural Works of Coal Handling Plant and Ash Handling Plant area and Non-plant structure of Unit 1 & 2 (Package 2) for 2 x 660 MW Udangudi Supercritical Thermal Power Project, Tuticorin, Tamil Nadu

**A. The following clauses are changed as below:**

Sl No.	Clause No.	Existing Clause	Revised Clause
1	Techno commercial bid Volume-I Book-I, Notice Inviting Tender, Clause No. 1.0- Salient Features of NIT, Sl No. v and vi	v) Due Date & Time of Offer Submission: Date 09.12.2019, Time 15.00 Hrs vi) Opening of Tender: Date 09.12.2019, Time 15.30 Hrs	v) Due Date & Time of Offer Submission: Date 16.12.2019, Time 15.00 Hrs vi) Opening of Tender: Date 16.12.2019, Time 15.30 Hrs

**B. Refer Corrigendum 5 dated 06.12.2019 and note that Sl. No. 6 and Sl. No. 7 of Corrigendum 5 are modified & furnished as below:**

Sl. No	Clause No.	Existing as per tender document	Query / Request	BHEL Clarification / Reply
6	Price Bid - A2329	Design, supply, fabrication, erection of <b>stoplog gates</b> , sluice gates etc in CW Pumps/Sea water Intake/Outfall pumps made out of SS 316L with embedments required, lifting beams, special tools & plants, spare parts for three years, machining, casting, all materials such as structural steel, cast steel, stainless steel, brass used for seals, rubber seals, gears, ball and roller bearing, branch bushings, greasing, bolts, nuts, lugs, threaded fastners etc., cleaning, blasting(SA 2 1/2) to near white metal surface, along with a second stage concreting to true plumb and levels, submission of drawings / fabrication drawings for engineers approval etc all complete as per approved drawings. The leakage through rubber seal shall not be more than 5 lit/min/metre length of seal under maximum head. (only weight of stainless steel including embedments shall be considered for payment purpose). (supply of stainless steel is in the scope of contractor only)	It is mentioned as only weight of stainless steel including embedments shall be considered for payment purpose, but the work also involves structural steel works. Kindly clarify us whether we should include the payments for structural steel works or not.	Item rate to be inclusive of structural steel works also"
7	Price Bid - A2331	SS component mentioned under ST No. A2329.		<b>Item description is modified as mentioned below:</b> "SS component mentioned under ST No. B2329.

All other conditions of the tender specification remain unchanged.

Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-  
Vinod Jaseja  
Sr. Dy. Gen. Manager / SCT