

Corrigendum 1 dated February 24, 2020 to Tender Specification BHEL PSSR SCT 1887

Corrigendum 1 dated February 24, 2020 to Tender Specification BHEL PSSR SCT 1887 for the work of Civil and Architectural works of AHP, LHP & GHP at 5X800MW Yadadri Thermal Power Project, Veerlapalem village, Dameracherla Mandal, Nalgonda District, Telangana

A) Extension of due date of Offer Submission: -

Sl. No	Published In	Existing	Revised As
1)	Techno-Commercial Bid Volume I Book I Notice Inviting tender (NIT) Clause 1.0 Salient Features of NIT, SI No. v) Due Date & Time of Offer Submission	Date: February 24, 2020, Time: 15.00 Hrs	Date: March 02, 2020, Time: 15.00 Hrs
2)	Techno-Commercial Bid Volume I Book I Notice Inviting tender (NIT) Clause 1.0 Salient Features of NIT, SI No.vi) Opening of Tender	Date: February 24, 2020, Time: 15.30 Hrs	Date: March 02, 2020, Time: 15.30 Hrs

B) The following is added as clause 34.0 to the Notice Inviting Tender:

34.0 In the course of evaluation, if more than one bidder happens to occupy L-1 status, effective L-1 will be decided by soliciting discounts from the respective L-1 bidders.
In case more than one bidder happens to occupy the L-1 status even after soliciting discounts, the L-1 bidder shall be decided by a toss/ draw of lots, in the presence of the respective L-1 bidder(s) or their representative(s).
Ranking will be done accordingly. BHEL's decision in such situations shall be final and binding.

Corrigendum 1 dated February 24, 2020 to Tender Specification BHEL PSSR SCT 1887

C) The following clauses are revised as below:

Clause No.	Existing Clause					Revised Clause				
VOLUME-IA PART-I CHAPTER-III FACILITIES & CONSUMABLES IN THE SCOPE OF CONTRACTOR / BHEL (SCOPE MATRIX) SI No. 1.3.1.3.0 WATER SUPPLY	SI.No.	Description PART I	Scope to be taken care by		Remarks	SI.No.	Description PART I	Scope to be taken care by		Remarks
			BHEL	Bidder				BHEL	Bidder	
	1.3.1.3.0	WATER SUPPLY					1.3.1.3.0	WATER SUPPLY		
	1.3.1.3.1	For construction purposes:		Yes	Free of charges as provided by TSGENCO		1.3.1.3.1	For construction purposes:	Yes	Free of charges as provided by TSGENCO
	1.3.1.3.1.1	Making the water available at single point		Yes	As provided by TSGENCO		1.3.1.3.1.1	Making the water available at single point	Yes	As provided by TSGENCO

D) Some of the Bidders had asked queries in the published Tender Specification. The clarifications issued by BHEL are furnished herewith: -

Sl. No	Reference Clause	Existing Provision	Bidder's Query	BHEL Reply
1.	Supply of Water Vol.IA Part-I Chapter - III	1.3.1.3.0 Water supply for construction purposes Scope to be taken care by Bidder - "Yes" Remarks - Free of charges as provided by TSGENCO	Bidder requests client to kindly confirm if the water supply is in BHEL's scope or Bidder's scope as the clause mentioned is contradictory.	Water supply for construction purpose shall be provided by BHEL free of cost as provided by TSGENCO. For further details refer clause no. 1.3.5 (page no. 51 of 1224 of Part 1 Of

Corrigendum 1 dated February 24, 2020 to Tender Specification BHEL PSSR SCT 1887

Sl. No	Reference Clause	Existing Provision	Bidder's Query	BHEL Reply
				2 of Technical Conditions of Contract Volume I Book I) Also, refer clarification given at Clause C above.
2.	Advance for mobilization: Vol. IA Part-I Chapter - VII	1.7.2.1 Interest bearing advance for Mobilization, limited to 5% of the contract value will be..... The advance for mobilization shall be paid as under.	Bidder requests client to consider interest-free mobilization advance.	Tender condition prevails.
3.	Supply materials: Vol.IA Part-I Chapter - XII	1.12.5 The contractor shall in no case be entitled for any compensation or damages on account of any delay in supply or non-supply thereof for all or any such material.	Bidder requests client for compensations for any reasons not attributable to the contractor.	Tender condition prevails.
4.	Supply of Materials: Vol. IA Part-I Chapter - XIII	1.13.2.1.3 The steel issued to the contractor shall be mainly in standard length and sections as received from the supplier. However, the contractor shall be bound to accept the steel in length as available in the project stores no claims for extra payment because of issue of non-standard length will be entertained.	Bidder requests client to remove the wastage penal rates towards recovery mentioned and consider the return of materials as surplus by weight, irrespective of their sizes.	Tender condition prevails.
5.	Earnest Money Deposit Vol.IA Part-II Chapter - 1	1.9.1 (v) In case EMD amount is more than Rs. Two Lakhs, Tenderer has the option to submit Rs. Two lakhs in the forms described above in clause no.1.9.1. (i) to (iv) and the remaining amount over and above Rs. Two Lakhs in the form of Bank Guarantee from Scheduled Bank (along with the Offer).	Bidder requests client to consider the entire value of EMD in the form of BG.	Tender conditions prevails.
6.	Liquidated damage: GCC Cl. 2.7.9 at the rate of 0.5% of the contract value, per week of delay or part thereof subject to a maximum of 10% of the contract value.....	Bidder requests client to consider a maximum LD of 5% of CV.	Tender condition prevails.

Corrigendum 1 dated February 24, 2020 to Tender Specification BHEL PSSR SCT 1887

Sl. No	Reference Clause	Existing Provision	Bidder's Query	BHEL Reply
7.	General-Drawings		Bidder requests client to kindly provide drawings of cross-section of excavation for Wagon Tippler, Track Hopper, etc.	Drawing relevant to the scope of works of this tender shall be provided progressively after award of work to successful bidder. This for bidder's information that Wagon tippler and track hopper is not covered under the scope of work of this tender.
8.	General-Sand		Bidder requests client to kindly allow the usage of M-Sand for construction as there is scarcity of sand and approval procedures in Telangana.	Tender condition prevails.

ALL OTHER CONDITIONS REMAIN UNCHANGED.

BIDDERS ARE REQUESTED TO CONSIDER THIS CORRIGENDUM AS PART OF TENDER SPECIFICATION AND QUOTE ACCORDINGLY.

-Sd-
Vinod Jaseja
Sr. Dy. Gen.Manager / SCT