

**1 X 600 MW - ENNORE TPS – EXTERNAL CHP**  
**PRE QUALIFICATION CRITERIA FOR VENDORS:**

Vendor should have successfully designed, manufactured/got manufactured, erected and commissioned pipe conveyor system of minimum 1000 TPH capacity on turnkey basis including civil and structural works at 2 different projects and working satisfactory for 1 year as on the date of bid opening. The length of pipe conveyor executed shall not be less than 1 Km. Vendor shall produce end user certificate for the same along with the offer.

The vendor who has executed only mechanical works (excluding civil and structural works) as above mentioned can also quote provided he associates with a civil and structural contractor who has carried out 20,000M<sup>3</sup> of concrete works and 5,000 tons of structural steel work in a power plant industry in a year. The name of the civil and structural contractor with whom the vendor associates shall be specified in the offer along with a certificate of concurrence from the Civil and Structural Contractor.