VOLUME-IA

TECHNICAL CONDITIONS OF CONTRACT (TCC)

BHARAT HEAVY ELECTRICALS LIMITED



Sl. No	DESCRIPTION	Chapter
1	Project Information	Chapter-I
2	Scope of Works	Chapter-II
3	Facilities in the scope of Contractor/BHEL (Scope Matrix)	Chapter-III
4	T&Ps and MMEs to be deployed by Contractor	Chapter-IV
5	T&Ps and MMEs to be deployed by BHEL on sharing basis	Chapter-V
6	Time Schedule	Chapter-VI
7	Terms of Payment	Chapter-VII
8	Taxes and Duties	Chapter-VIII
9	Estimated Weight for various systems in scope of work (BOQ)	Chapter-IX
10	General	Chapter-X
11	Progress of work	Chapter-XI
12	Foundation & Grouting	Chapter-XII
13	Material Handling, Transportation and Site Storage	Chapter-XIII
14	Erection	Chapter-XIV
15	Welding, Heat treatment & Radiography and Non- destructive testing	Chapter-XV
16	Hydraulic test	Chapter-XVI
17	Testing, Pre – Commissioning & Commissioning and Post Commissioning	Chapter-XVII
18	Painting	Chapter-XVIII
19	Lining & Insulation	Chapter-XIX
20	Preservation & Protection of Components	Chapter-XX
21	Welding Schedule	Chapter-XXI
22	Weightages / Factor	Chapter-XXII
23	Technical Annexure	Chapter -XXIII

1. Project Information

Project Name: 3x800 MW Patratu Vidut Utpadan Nigam Ltd. (PVUNL) Patratu STPP. The proposed site is located near Patratu town in Ramgarh district of Jharkhand.

The latitudes and longitudes of the site are as follows:

1	Project Name		3x800 MW Patratu Vidut Utpadan Nigam Ltd. (PVUNL) Patratu STPP
2	Plant Site Location		Near Patratu town in Ramgarh district of Jharkhand
3	Location	Co-ordinate	Main Plant & Township:
3.1	Corner name	Latitude	Longitude
3.2	Top Corner	23° 39 ' 00" N	85° 17′ 51.5″ E
3.3	Bottom Corner	23° 38 '12.5" N	85° 17′ 27" E
3.4	Left Corner	23° 38 ' 22.5" N	85° 17′ 10.6′′ E
3.5	Right Corner	23° 38 ′ 40" N	85° 17′ 57'' E
4	Nearest Town/City		Patratu -03 Kms, Ramgarh– 30 Kms, Ranchi – 37 Kms
5	Nearest Railway Station		Patratu-4 Kms
6	Nearest Airport		Ranchi-45 Kms
7	Nearest S	eaport	Kolkata-424 Kms
8	Nearest F	Road Access	Ranchi Patratu Ramgarh Rd
9	Site Elev	ation	377 M above MSL
10	Ambient Temperature		
10.1	Mean of Daily Maximum Temperature		40°C (During May)
10.2	Mean of Daily Minimum Temperature		10.7°C (During December)
10.3	•	Temperature	27°C (Maximum)
11	Annual R	ainfall	311 mm average annually

12	Wind Speed	0 to 39 Km/Hr
13	Wind Direction	East North East to West South West
14	Seismic Zone	Zone III as per IS:1893
15	Owner/Customer	Patratu Vidyut Utpadan Nigam Limited (PVUN Limited) - JV of a subsidiary of NTPC Ltd and Jharkhand Bijli Vitran Nigam Limited (JBVNL).

The vicinity map of the project is shown below



1.0	INSTRUCTIONS TO BIDDERS
1.1	The Bidder shall visit project site and acquire full knowledge and information about conditions prevailing at site and in & around the plant premises, together with site conditions, transportation routes, various distances, all the statutory, obligatory, mandatory requirements of various authorities and all information that may be necessary for preparing the bid and entering into the Contract. All costs for and associated with site visits shall be borne by the bidder.

1.2	Other contractors would be working in this area and their structures are to be protected. The material brought and stacked for construction should not make hindrance to other contractors.					
1.3	The information given herein is for general guidance and shall not be contractually binding on BHEL/Owner. All relevant site data /information as may be necessary shall have to be obtained /collected by the Bidder.					
1.4	The contractor, in the event of this work awarded to him, shall establish an office at site and keep posted an authorized, responsible officer with valid Power of Attorney for the purpose of the contract. Any order or instructions of the 'Engineer' or his duly authorized representative, communicated to the contractor's representative at site office will be deemed to have been communicated to the contractor at his legal address.					
1.5	No claim will be entertained by BHEL on ground of lack of knowledge and the contractor's rates shall be deemed to have taken this into account.					
1.6	Bidders may fix person:	up their site visit in consultation	n with below mentioned contact			
	Name:	Mr. Suman Mishra	Mr. Praveen Pandey			
	Designation:	Designation: GM Sr. Manager				
	Location: 3X800 Patratu Project PSWR Nagpur					
	Email:	suman.mishra@bhel.in praveen.pandey@bhel.in				
	Ph. No.	(+91) 94793 72033	(+91) 95740 15556			

2.0 SCOPE OF WORK

2.1 The scope of work for package as follows:

The intent of this erection specification is to provide services for execution of the project according to most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for the proper and efficient services towards installation of the plant shall not relieve the contractor of the responsibility of providing such services/ facilities to complete the work or portion of work awarded to him. The quoted/ accepted rates/ price shall deem to be inclusive of all such contingencies.

- 2.2 The work to be carried out under scope of this specification covers **complete work of** ACC (Air Cooled Condenser) & its Auxiliaries of Unit#2 covering receipt from stores/ yard located within project premises, arranging their issue, transportation to site, temporary storage prior to erection, if required, cleaning, preservative painting, Fabrication, erection, alignment, welding, levelling, adjustment etc. including insulation & finish painting, all pre-commissioning tests, start-up and trial run of individual equipment, final commissioning, trial run and handing over of units to BHEL/ their customer including performance & guarantee (PG) test of units, reconciliation of materials issued to contractor & returning unused materials to BHEL stores/yard/places designated by BHEL OR CUSTOMER. The work shall conform to dimensions and tolerances given in various drawings and documents that will be provided during erection. If any portion of works is found to be defective in workmanship & not conforming to drawings/documents or other stipulations, the contractor shall dismantle and re-do the work duly replacing the defective materials at their own cost, failing which recoveries, as determined by BHEL, shall be affected from contractor's bills.
- 2.2.1 BHEL at its discretion may include other area works limited to 15% of awarded contract value, which are not mentioned in above scope of works. Contractor shall execute such works as desired and as directed by BHEL Engineer. The item rates & contract conditions shall remain unchanged for such works.

2.3 DETAILED SCOPE OF WORK:

The scope of work under this contract covers Erection, Testing & Commissioning of Air Cooled Condenser (ACC) and associated auxiliaries, which includes material receipt from store, transportation to site, erection, testing, commissioning, trial run, handing over etc, as required, for total scope defined in this specifications along with other document of complete work of erection & commissioning of Air Cooled Condenser covering Structures, finned tube bundles, Steam Distribution manifold, Axial Fan system, Wind wall structures, Elevators, Air Removal system, Condensate System, Steam Ducting, Draining System, Cleaning System, Lifting devices, Insulation, Finish Painting etc. with required Structures, platforms, stairs, Hoist and Chain Pulley Blocks, EOT cranes, temporary passenger elevators etc of Unit#2 at 3x800 MW PVUNL STPP Patratu. ACC shall include the following systems/ equipment:

- 2.3.1 Condenser modules, finned heat exchanger tube bundles, steam and condensate collection header.
- 2.3.2 Complete air moving system incl. fans, speed reducer, couplings, electric motors, fan support bridges and equipment required for safe operation.
- 2.3.3 Steam distributing system from steam turbine outlet to the ACC unit including main steam duct, steam distribution manifold, steam header.
- 2.3.4 Condensate tank including connections for makeup water with condensate strainer, standpipe, manholes, nozzles connection, insulation, hand railing etc.
- 2.3.5 Steam duct shall be welded to turbine exhaust.
- 2.3.6 Connections for Steam turbine HP-LP bypass valves.
- 2.3.7 Fin tube cleaning system of semi-automatic type. The fin tube bundles shall be cleaned using high pressure water.
- 2.3.8 Necessary vacuum breaker valves and provision of rupture devices.
- 2.3.9 Provisions for accommodating expansion and contraction with changes in thermal load.
- 2.3.10 Steam duct connecting turbine exhaust flange to steam distribution manifold shall include expansion joints, rupture discs, inspection ports, drain pots and necessary vent and drain connections.
- 2.3.11 All necessary structures for bundles, fans, motor, gearboxes, piping, cable rack, lighting, etc., with inspection platforms, stairways, ladders for access to all instruments, drives, valves, and to operation, maintenance and inspection locations (e.g. duct manholes). At least one staircase and one caged ladder to be provided to get access to the ACC main platform.
- 2.3.12 Staircases shall be provided for Air Cooled Condenser (ACC) of all units. Further, the Air-Cooled Condensers shall be interconnected with each other by platform and structure.
 - i. Interconnecting platform between U#1 & U#2 shall be in the scope of U#2 agency.
 - 2.4 Brief Description of the system are as follows:
- 2.4.1 Steam Exhaust System

The scope of work of the contractor for Air Cooled Condenser will be inclusive but not limited to following:

2.4.1.1 Main Steam Duct

- i. The scope of work includes receipt from open storage yard, stores, handling, preassembly, preservation, erection and commissioning etc. of following major systems
- ii. Preassembly and erection of expansion joints and main steam ducting including blank plate.
- iii. Preassembly and erection of elevated horizontal ducting
- iv. Welding of the steam exhaust duct & distribution manifold in accordance with WPS and procedure.
- 2.4.2 **Steam duct Riser -** preassembly & erection & welding of riser.
- 2.4.3 **Steam Distribution Manifold-** Erection of steam Distribution Manifold and condensate Header and vacuum system and checking of Alignment.

2.4.2 Tube Bundle System:

- **2.4.2.1** Preparation of Bundles.
- **2.4.2.2** Installation of Bundles, alignment and welding in accordance with procedure.
- 2.4.3 **Condensate Header-** Erection and alignment of Condensate manifold and doing associated piping job.

2.4.4 AIR MOVING SYSTEM

2.4.4.1 Fans:

- i. Sorting out of fan deck beam and fan deck plates and placing up at fan deck level. Securely fixing of fan deck plates against falling down due to wind or other external force.
- ii. To prepare temporary supporting arrangement for assembling the motor bridge
- iii. Erection of gearboxes, motor, fan hub and blades etc.
- iv. Erection of structural parts like: handrails, gratings etc.
- v. Assembly of fan screen, fan ring.
- vi. Whole assembly of fan ring and safety screen shall be erected on its support at fan deck level.
- vii. Fan bell shall be fixed onto the supporting plates of fan deck structures through bolting connection.
- viii. Assembly and erection of air inlet bells.
- **2.4.4.2 Gear Box:** Erection of fan gear box and filling of lubrication oil as per procedure and specification.

2.4.4.3 Fan Bridge

- i. Erection of assembled motor bridge or individual assemblies at fan deck level.
- ii. Completion of all structural works for fan erection purpose

2.4.5 STRUCTURE (UPPER)

"A" Frame Structure:

- i. Pre-assembled A-Frames to be erected followed with erection of Top Girders, Distance Bracings, Diagonal Bracings and Monorails.
- ii. Installation of internal and external doors.
- iii. Fixing of intermediate cladding sheet on the internal and external "A Frames".

2.4.6 Wind wall Structure

- i. To fabricate wind wall structures and necessary sheeting works and erection of same as per drawing
- ii. Complete ACC and auxiliaries supporting structural steel, walkways, platforms, ladders and gratings, hand rail, stair cases as per drawing including inter connecting walkways and connecting platform, elevator, chequered plates, kicker / toe-guard plates wherever required, foundation bolts, nuts, fasteners, inserts, anchor channels, base plates, packers, shims, pipe sleeve for equipment and columns under scope.
- iii. Erection of Elevator and stair case structure including its bracings, connecting members and cladding structures.

2.4.7 AIR EVACUATION SYSTEM / VACUUM SYSTEM

2.4.7.1 Piping and Tube-Walls: Piping and erection of Tube walls/bundles shall be done as per PID drawings.

2.4.7.2 Vacuum Pump and it's Piping:

- i. Erection, Testing and Commissioning of Vacuum Pumps
- ii. Piping for Air Take-off lines between secondary bundles and its holding pumps

2.4.8 TANK AND DRAIN SYSTEM:

- i. Erection of Drain Tank and its Piping
- ii. Erection of Drain Pump and its piping
- iii. Erection of Condensate Tank and its Piping
- iv. Erection of condensate lines between condensate manifolds and turbine exhaust box.
- v. Prefabrication and erection of condensate and air take-off piping.
- vi. Main Piping job as per approved drawing.
- vii. Erection of condensate pump and its Piping.

2.4.9 OTHER MISC. ITEMS:

2.4.9.1 Cleaning System along with Ladder:

- i. Erection of valley walkway structures, laying of gratings including erection of cleaning ladders
- ii. Erection of cleaning system, pump and associated pipe works.
- iii. Erection of Stairs, Electric Hoist, Chain Pulley Blocks, EOT cranes.

2.4.9.2 Erection of Lifting Devices and obtaining Statutory Clearances

EOT Cranes (Upto 20 MT handling capacity), Misc. Hoist (Mech/Electrical), Chain Pulley etc.

- 2.5 The quantities indicated in the tender specification are approximate and are liable for variation and alteration at the discretion of BHEL. The quoted unit rate shall be applicable for any additional product group also, if included at a later date integral to the main scope of work / package envisaged. The work executed shall be measured and priced as per the unit rate arrived at for each work area as mentioned in the relevant clauses.
- 2.6 The system wise breakup of equipments are indicated in the relevant chapters of this tender specification, but the contractor is required to erect actual tonnage which may be necessary to complete the work in all respects as detailed in the tender specifications, for which payments shall be released on finally settled rates. The weights and dimensions of material shown are approximate and are liable to vary. No increase in quoted / accepted rates / prices shall be allowed due to change in weights and dimensions of the equipment / materials.
- **2.7** The weights given in the **Chapter-IX** "**ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE OF WORK (BOQ)**" are approximate and these are subject to change as per site conditions.
- **2.8** Supervisors / Engineers, consumables etc., required for the scope of work shall be provided by the contractor. All the expenditure including taxes and incidentals in this connection will have to be borne by him unless otherwise specified in the relevant clause. The contractor's quoted rates should be inclusive of all such contingencies.
- 2.9 It shall be specially noted that, the contractor may have to work round the clock (24x7) to achieve the completion schedules / plans / targets during the entire course of erection, testing and commissioning works, which may involve payment of considerable overtime. Hence contractor's quoted rate shall take into consideration of all expenses that will be incurred for such arrangement of personnel including labours, engineers / supervisors, T&Ps etc.
- 2.10 The terminal points can be inferred from the relevant drawings and any further clarifications can be obtained / decided by BHEL and that is final and binding on the contractor for deciding the scope of work and effecting the payment for the work done up to the terminals. Carrying out work as per the specification between equipments constituting terminal points, whether the terminal equipments fall within the scope of work/specification, contractor shall carry out the terminal joints at either end. Also where the piping connection to the terminal points involve flanged joints, matching of flanges, fixing gaskets, bolting and tightening as per BHEL Engineers instructions is in the scope of work. In case piping connected to equipment, matching of flanges for achieving the parallelism and alignment at the equipment end, by suitably resorting to heat correction or other method as instructed by BHEL Engineer, with in the quoted rate.

- 2.11 The work shall conform to dimensions and tolerances given in various drawings and quality manuals provided by BHEL. If any portion of work is found to be defective in workmanship not conforming to drawings or other stipulations, the contractor shall dismantle and redo the work duly replacing the defective materials at his cost, failing which the job will be carried out by BHEL by engaging other agencies / departmentally and recoveries will be affected from contractor's bill towards expenditure incurred including 5% BHEL's overhead charges.
- 2.12 Contractor has to work in close co-ordination with other erection agency at site. BHEL engineer will co-ordinate area clearance. In a project of such magnitude, it is possible that the area clearance may be less/more at a particular given time. Activities and erection program have to be planned in such a way that the milestone events are achieved as per schedule/ plans. Contractor shall arrange & augment the resources accordingly.
- **2.13** No member of the already erected structure/ platform, pipes, grills, platform, other component and auxiliaries should be cut without specific approval of BHEL engineer.
- **2.14** The storage yard is located within the plant boundary and nearby (Approx. 3-4 KM) of the plant premises in 2-3 locations. All other materials have to be transported from storage yard to construction area by the contractor at his own cost.
- 2.15 During the course of erection, testing and commissioning, certain rework / modification / rectification / repairs / fabrication etc will be necessary on account of feedback/revision from various relevant sources, and also on account of design discrepancies/ alterations, manufacturing defects, site operations/ maintenance requirements. This will also include modifications / re-works suggested by BHEL / Customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repairs etc promptly and expeditiously. Daily log sheets indicating the details of work carried out, man-hours etc shall be maintained by the contractor and got signed by BHEL engineer every day. Claim of Contractor if any, for such works will be governed by relevant clauses of 'General Conditions of Contract.
- 2.16 The scope of work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, engineering and construction management and green belt management. The contractor should ensure successful and timely completion of the work. The contractor must have adequate quantity of tools, construction aids, equipments etc., in his possession. He must also have on his rolls adequately trained, qualified and experienced supervisory staff and skilled personnel. The manpower deployment identified by contractor shall match with above scope of works.

- 2.17 Contractor shall execute the work as per sequence and procedure prescribed by BHEL at site. The erection manuals for ACC Erection etc., which are available with BHEL site office, are to be referred for compliance and guidance before taking up the work. Any failure to comply with the above might lead to rework and the cost for the same shall be borne by the contractor only. BHEL engineer, depending upon the availability of materials, fronts etc., will decide the sequence of erection and methodology. No claims for extra payment from the contractor will be entertained on the grounds of deviation from the method of erection adopted in erection of similar jobs or for any reason whatsoever.
- 2.18 Touch-up Painting (Applicable in entire scope of work): All ACC structures/components shall be supplied from BHEL units/workshops with finish coats of paint. Therefore, final painting is not applicable in the scope of contractor. However, touch up painting (wherever required), incidental to the work, shall be in the scope of the contactor, including supply of the required paints and primers and associated consumables.

Though the final painting is not there in the scope of the contractor, in case any shop painted structure/component is required to be repainted due to the reasons attributable to the contractor such as Mis-handling, damage during erection process, other reasons incidental to the work etc., such re-painting/finish painting of the components/structures shall be in the scope of the contractor including the supply of paints and primers along with all required consumables.

	Description	Scope		Remarks
Sl. No		taken o	care by	
	PART I	BHEL	Bidder	Tterrior K5
3.1	ESTABLISHMENT			
3.1.1	FOR CONSTRUCTION PURPOSE:			
a	Open space for office (as per availability)	Yes		Location will be finalized after joint survey with owner
b	Open space for storage (as per availability)	Yes		Location will be finalized after joint survey with owner
С	Construction of bidder's office, canteen and storage building including supply of materials and other services			
d	Bidder's all office equipments, office / store / canteen consumables		Yes	
e	Canteen facilities for the bidder's staff, supervisors and engineers etc	YAC		
f	Firefighting equipments like buckets, extinguishers etc		Yes	
g	Fencing of storage area, office, canteen etc of the bidder		Yes	
3.1.2	FOR LIVING PURPOSES OF THE BIDDER			
a	Open space for labour colony (as per availability)		Yes	Agency has to make his own arrangement at his own cost.
b	Labour Colony with internal roads, sanitation, complying with statutory requirements	ion, complying with statutory Yes		
3.2	ELECTRICITY			
3.2.1	Electricity For construction purposes only of Voltage 415/440 V, 3 phase, 50Hz	Yes		Chargeable basis

	Description	Scope	/ to be	
Sl. No	•	taken care by		Remarks
	PART I	BHEL	Bidder	Remarks
a	Single point source	Yes		At a distance of 1000 M from site (Distance is only tentative, it may vary up-to an extent depending on site condition)
		(any duti as cl cust be p	Chargeable basis (any taxes, duties, levy etc. as charged by customer, shall be paid by contractor.)	
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
С	Duties and deposits including statutory clearances if applicable		Yes	
3.2.2	Electricity for the office, stores, canteen etc. of the bidder			Chargeable basis (any taxes, duties, levy etc. as charged by customer, shall be paid by contractor.)
a	Single point source	Yes		At a distance of 1000 M from site (Distance is only estimated, it may vary up-to an extent depending on site condition).
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
С	Duties and deposits including statutory clearances if applicable		Yes	

	Description	Scope	/ to be	Remarks
Sl. No		taken d	care by	
	PART I	BHEL	Bidder	Remarks
3.2.3	Electricity for living accommodation of the bidder's staff, engineers, supervisors etc		Yes	Agency has to make his own arrangement at his own cost.
a	Single point source		Yes	
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
С	Duties and deposits including statutory clearances if applicable		Yes	
3.3	WATER SUPPLY			
3.3.1	For construction purposes: (Single point source provided by BHEL on chargeable basis)	Yes		
a	Making the water available from single point		Yes	Agency has to make his own
b	Further distribution as per the requirement of work including supply of materials and execution	arrange		arrangement at his own cost.
3.3.2	Water supply for bidder's office, stores, canteen etc.			
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.3	Water supply for Living Purpose			
а	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.4	LIGHTING			

	Description	Scope	/ to be	
Sl. No		taken care by		Remarks
	PART I	BHEL	Bidder	Ttorroir Ko
a	For construction work (supply of all the necessary materials) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
b	For construction work (execution of the lighting work/ arrangements) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
С	Providing the necessary consumables like bulbs, switches, etc during the course of project work		Yes	
d	Lighting for the living purposes of the bidder at the colony / quarters		Yes	
3.5	COMMUNICATION FACILITIES FOR SITE OPERATIONS OF THE BIDDER			
a	Telephone, fax, internet, intranet, e-mail etc.		Yes	
3.6	COMPRESSED AIR wherever required for the work		YES	
a	Supply of Compressor and all other equipments required for compressor & compressed air system including pipes, valves, storage systems etc		Yes	
b	Installation of above system and operation & maintenance of the same		Yes	
С	Supply of the all the consumables for the above system during the contract period		Yes	

	Description	Scope		
Sl. No			care by	Remarks
	PART I	BHEL	Bidder	
3.7	Demobilization of all the above facilities		Yes	
3.8	TRANSPORTATION			
а	For site personnel of the bidder		Yes	
b	For bidder's equipments and consumables (T&P, Consumables etc)		Yes	
3.9	Engineering works & Materials for construction:	Yes		
a	Providing the erection drawings for all the equipments covered under this scope	the equipments covered under this Yes		
b			Yes	In consultation with BHEL
С	As-built drawings – where ever deviations observed and executed and also based on the decisions taken at site- example – routing of small bore pipes Yes		In consultation with BHEL	
d	Shipping lists etc for reference and planning the activities	Yes		In consultation with BHEL
e	Preparation of site erection schedules and other input requirements		Yes	In consultation with BHEL
f	Review of performance and revision of site erection schedules in order to achieve the end dates and other commitments	Review of performance and revision of site erection schedules in order to achieve the end dates and other Yes Yes		In consultation with BHEL
g	Weekly erection schedules based on SL No. e	Weekly erection schedules based on SL		In consultation with BHEL
h	Daily erection / work plan based on SL		Yes	In consultation with BHEL
i	Periodic visit of the senior official of the bidder to site to review the progress so that works are completed as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two months.		Yes	

Sl. No	Description	Scope / to be taken care by		Remarks
	PART I	BHEL	Bidder	Remarks
j	Preparation of preassembly bay		Yes	
k	Laying of racks for gantry crane if provided by BHEL or brought by the contractor/bidder himself	NA	NA	Not Applicable
l	Arranging the materials required for preassembly	Yes		
m	COIVD-19 PREVENTIVE MEASURE		Yes	

3.10 ELECTRICITY:

- 3.10.1 The construction power (415V) will be provided at a single point for construction purpose only on chargeable basis. Further distribution is to be arranged by the bidder at his cost. Construction power shall be provided from the nearest Substation / tapping point at a distance of approx. 1000 M from site. The distance is only estimated; it may vary upto an extent depending on site condition.
- 3.10.2 Any duty, deposit involved in getting/consuming the electricity shall be borne by the bidder. As regards to contractor's office shed also, all such expenditure shall be borne by the contractor.
- 3.10.3 Provision of distribution of electrical power from the given single central common point to the required places with proper distribution boards, approved cables and cable laying including supply of all materials like cables, switch boards, pipes etc., observing the safety rules laid down by electrical authority of the State / BHEL / their customer with appropriate statutory requirements shall be the responsibility of the tenderer / contractor.
- 3.10.4 BHEL is not responsible for any loss or damage to the contractor's equipment as a result of variations in voltage / frequency or interruptions in power supply.
- 3.10.5 Necessary "Capacitor Banks" to improve the Power factor to a minimum of 0.8 shall be provided by the contractor at his cost. Penalty if any levied by customer on this account will be recovered from contractor's bills.
- 3.10.6 The required energy meter for measuring power consumption shall be arranged by the contractor and taken care by the contractor.
- 3.10.7 Contractor has to make his own arrangements for his electricity requirement for his labour colony at his cost.

3.10.8 As there are bound to be interruptions in regular power supply, power cut/load shedding in any construction sites, contractor should make his own arrangement for alternative source of power supply through deployment of adequate number of DG sets at their own cost during the power breakdown /failure to get urgent and important work to go on without interruptions. No separate payment shall be made for this contingency

3.11 CONSTRUCTION WATER

- 3.11.1 Water (Raw water) required for construction purposes will be provided at one single point within the plant area on chargeable basis. The further distribution is to be arranged by the bidder at his cost. Construction water shall be provided at a distance of 1000 M from site. Distance is only estimated; it may vary upto an extent depending on site condition.
- 3.11.2 The required water meter for measuring the consumption shall be provided and installed by the contractor. The required pumps & accessories, pipes for drawing water from the points and further distribution will be arranged by the contractor at their own cost. BHEL is not responsible for any loss or damage to the contractor's equipment due to any reason. For any dispute regarding water consumption and distribution, the BHEL engineer's decision shall be final and binding.
- 3.11.3 The water charges may vary from time to time as per PVUNL prevailing charges, any dispute regarding consumption, the BHEL engineer decision will be final.
- 3.11.4 In case of non-availability of water, the contractor shall make his own arrangements of **water suitable for construction purpose** to have uninterrupted work. No separate payment shall be made for any contingency arrangement made by contractor, due to delay / failure for providing water supply. Contractor has to make his own arrangements for his water requirement for his labour colony at his cost.

3.12 DRINKING WATER

Bidder shall arrange for drinking water at the work spot at their own cost.

3.13 ONLINE SITE CONSTRUCTION MANAGEMENT SYSTEM (SCMS):

3.13.1 The bidder will have to supply and install 01 Nos. of PC with Operator, 01 no multifunction higher capacity printer (preferably 1 printer should be have A3 size printing facility) and accessories along with power backup, for the online material management system, reporting of daily progress, billing and other

similar activities pertaining to contractor's scope of work. PCs & printers are to be installed at places as per instruction of BHEL Engineer.

Computers shall have minimum configuration multimedia PC work station Core i3/i5/i7,1 GHZ or above, 500 GB HDD or above, 6 GB RAM or above, 100 MBPS LAN card of DELL/HP/ASUS or equivalent make with window 10 O/S with required accessories like mouse, keyboard, UPS and required software like MS Office 2010 Professional, AutoCAD 2011 or higher, ADOBE PDF CREATOR (version 8.0 or higher) with one laser jet printer compatible for A4 and A3 size printing (ink/ cartridge for which to be supplied as and when required, (the consumption may be assumed as 1 cartridge per month).

3.13.2 These computers/ printers & accessories shall remain contractor's property/ ownership for all legal/technical purposes. However, contractor will be allowed to take out the same after completion of the site works as per instruction of BHEL Engineer.

Note:

If agency fails to provide computer/ printer or personnel as per requirement, for a continuous period of fifteen days or more, BHEL shall have the right to deduct the amount as per following rates on prorate basis, from contractor's RA bill or any other dues.

- i. @ Rs 15,000/- (Fifteen thousand)/ month for each computer operator.
 Or at actuals (rate +30%) if BHEL arranges this facility, whichever is lower
- ii. @ Rs 12,000/- (Twelve thousand) / month for each set of computer & printer. Or at actuals (rate +30%) if BHEL arranges this facility, whichever is lower.
- iii. In the event of the contract period getting extended beyond the stipulated time for reasons not attributable to agency, agency will be reimbursed at the above mentioned rate or (actual +15%), whichever is lower, if the services of operator / service staff are used by BHEL during the extended period.

3.14 CONSUMABLES:

- 3.14.1 Such of those consumables as indicated as consumables provided by BHEL alone will be provided to the contractor by BHEL free of charge for erection activities. Other required consumables like electrodes, all gases, and other materials for this scope of work are to be arranged by the contractor at their cost.
- 3.14.2 All the required electrodes as approved by BHEL shall be arranged by contractor at his cost. It shall be the responsibility of the contractor to obtain prior approval of BHEL, before procurement regarding, suppliers, type of electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by

BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number and date of expiry etc.

- 3.14.3 All other electrodes including stainless steel electrodes required for shall be arranged by the contractor at their own cost. However, BHEL will provide imported electrodes as provided by manufacturing units. The bidder shall use the Customer approved quality welding electrodes only. The utilization of the TIG welding wires issued by BHEL shall be duly accounted for exercising maximum care and ensuring economical usage for minimum wastage. If during erection, it is found that the consumption of filler wire is more than the actual requirement due to improper usage, the cost for the additional quantity so consumed shall be recovered from the contractor.
- 3.14.4 Within finally accepted price / rates, contractor shall provide all consumables like welding electrodes (including alloy steel and stainless steel), all gases (inert, welding, and cutting), soldering material, dye penetrants, radiography films. Other erection consumables such as tapes, jointing compound, grease, mobile oil, M-seal, Araldite, petrol, CTC / other cleaning agents, grinding and cutting wheels are to be provided by the contractor. Steel, H&S, packers, shims, wooden planks, scaffolding and pre-assembly materials, hardware items etc required for temporary works such as supports, scaffoldings, bed are to be arranged by him.
- 3.14.5 Sealing compounds and GI wires for insulation mattress binding shall be provided by the contractor within finally accepted price/rates.
- 3.14.6 Gaskets, gland packing, wooden sleepers, for temporary work, required for completion of work except those which are specifically supplied by manufacturing unit are also to be arranged by contractor.
- 3.14.7 All the shims, gaskets and packing, which go finally as part of equipment, shall be supplied by BHEL free of cost.

Note: List of approved vendors attached as file Named: 'Approved Vendor List' (Annexure-2).

3.15 MATERIAL SUPPLY:

BHEL will supply the materials / equipments indicated in the weight schedule from their respective manufacturing units which are to be executed / incorporated in the permanent system. In addition, the material such as lube oil, grease required for commissioning of the erected equipments and will be supplied free of cost by BHEL.

3.16 LIGHTING FACILITY:

Adequate lighting facilities such as flood lamps, hand lamps and area lighting shall be arranged by the contractor at the site of construction, pre-assembly yard and contractor's material storage area etc. at his cost.

3.17 GASES:

- 3.17.1 All the required gases like Oxygen / Acetylene / argon / Nitrogen required for work shall be supplied by the Contractor at his cost. It shall be the responsibility of the contractor to plan the activities and store sufficient quantity of these gases. Non-availability of gases cannot be considered as reason for not attaining the required progress.
- 3.17.2 The contractor shall submit weekly / fortnightly / monthly statement report regarding consumption of all consumables for cost analysis purposes.
- 3.17.3 The contractor shall ensure safe keeping of the inflammable cylinder at a separate place away from normal habit with proper security etc.
- 3.17.4 BHEL reserves the right to reject the use of any gas in case required purity is not maintained.

3.18 ELECTRODES SUPPLY AND STORAGE

- 3.18.1 The bidder shall use the BHEL / Customer approved quality welding electrodes only.
- 3.18.2 It shall be the responsibility of the contractor to obtain prior approval of BHEL, before procurement, regarding suppliers, type of electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number and date of expiry etc.
- 3.18.3 Shortage of any of the electrodes or the equivalent suggested by BHEL shall not be quoted as reason for deficiency in progress or for additional rate.
- 3.18.4 Storage of electrodes shall be done in an air conditioned / controlled humidity room as per requirement, at his own cost by the contractor.
- 3.18.5 All low hydrogen electrodes shall be baked / dried in the electrode drying oven (range 375 deg. C 425 deg. C) to the temperature and period specified by the BHEL Engineer before they are used in erection work and each welder should be provided with one portable electrode drying oven at the work spot. Electrode drying oven and portable drying ovens shall be provided by contractor at his cost.

- 3.18.6 In case of improper arrangement of procurement of above electrodes BHEL reserves the right to procure the same from any source and recover the cost from the contractor's first subsequent bills at market value plus 5% overhead. Postponement of such recovery is not permitted.
- 3.18.7 BHEL reserves the right to reject the use of any electrodes at any stage, if found defective because of bad quality, improper storage, date expiry, unapproved type of electrodes etc. It shall be the responsibility of the contractor to replace at his cost without loss of time.

3.19 OTHER FACILITIES

- 3.19.1 Adequate water less urinals (at least 2 nos, at identified locations) shall be arranged by the contractor within quoted rates, at site of construction with proper disposal arrangement.
- 3.19.2 Vendors have to comply requirements of HSE & Statutory requirement in line with BHEL HSE plan (Annexure-5), NTPC Safety requirement, Jharkhand/Central statutory requirement.
- 3.19.3 Vendors have to arrange labour rest sheds, drinking water facility, toilets, canteen facility as per local labour act/BOCW act. Maintaining hygiene and disposal of debris, scraps, canteen items and area cleaning is included in vendor's scope.
- 3.19.4 Agency has to arrange trained scaffolding experts with accreditation from statutory agencies with proper experience and they will issue fitness certificates for safe use. Such kind of qualified scaffolding experts will vary as per job requirement. At the same time, training has to be given by these experts at regular intervals for their own workers for increasing no. of experts.
- 3.19.5 Agencies HSE officers should have sufficient experience as per rule 209 of BOCW act central rule 1998. Agencies HSE officers will be part of BHEL HSE Team and they will be responsible for giving training on HSE issues in addition to normal field works and other normal site requirements.
- 3.19.6 Preparation of method statement, HIRA, Job Safety analysis, permit to work, Lifting plans, and all supporting documents as required for starting & continuation of work/job is in contractor's scope.
- 3.19.7 Hydras are not allowed for materials transport, only pick and carry / Farana cranes shall be deployed by the agency.

- 3.19.8 First aid centre will be maintained by BHEL and cost will be proportionately recovered from vendors.
- 3.19.9 Vendor has to arrange land within his quoted rate for making labour colony. Vendors labour colony has to be maintained with proper hygiene, drinking water, bathroom water, lighting arrangement, sewerage system. These facilities are to be regularly maintained including drains, surrounding, upkeeping of labour colony. BHEL/Customer & local statutory authorities will visit labour colony from time to time and all healthy conditions are to be maintained by vendor.
- 3.19.10 Scaffolding pipes, clamps, safety nets, floor grills for working platforms are to be made of good quality with proper certifications as per IS Codes.

3.19.11 DEWATERING:

Contractor shall ensure at all times that the work area & approach/ access roads are free from accumulation of water, so that the materials are safe and the erection/ progress schedule are not affected. No separate claim in this regard shall be admitted by BHEL.

3.20 SITE ORGANISATION

- 3.20.1 The contractor shall provide adequate staffing in the following areas in addition to the staffing requirements of execution as instructed/informed by BHEL:
 - i. Overall planning, monitoring & control.
 - ii. Quality control and quality assurance.
 - iii. Materials management.
 - iv. Safety, fire & security.
 - v. Industrial relations and fulfilment of labour laws and other statutory obligations.
- 3.20.2 The contractor shall maintain a site organization of adequate strength in respect of manpower, construction machinery and other implements at all times for smooth execution of the contract. This organization shall be reinforced from time to time, as required to make up for slippage from the schedule without any commercial implication to BHEL. The site organization shall be headed by a competent construction manager having sufficient authority to take decisions at site.
- 3.20.3 The contractor should also submit to BHEL for approval a list of construction equipment, erection tools, tackle etc. prior to commencement of site activities. These tools & tackles shall not be removed from site without written permission of BHEL.

- **4.0 Tools and Plants:** Number of T&Ps to be deployed at site shall be decided w.r.t. monthly plan and review format (F-14) based on site requirement.
- **4.1 Major T&P**: The following **Major Tools & Plants** (T&P) shall be arranged by the Contractor for execution of work as per Technical Conditions of Contract of this tender within the quoted rate.

	Major T&Ps						
SN	DESCRIPTION	CAPACITY (MINIMUM)	QUANTITY	REMARKS			
1	Crawler/ Tyre Mounted crane	75 MT	02 No.	Crane to be made available at site in consultation with BHEL Site management, BHEL decision is final and agency has to deploy the crane as per BHEL instructions till Site requirement.			

Note for clause 4.1:

- 1. Contractor shall mobilise aforementioned cranes/T&Ps at site, in case stated capacity crane could not be made available, for any reason what so ever, a higher capacity crane shall be mobilised by the contractor without any extra cost.
- **2.** Contractor shall Mobilize/de-mobilize/re-mobilise the Major T&Ps as per BHEL instruction without any extra cost to BHEL.
- **4.2 Other T&Ps:** The following **Other Tools & Plants** (**T&Ps**) shall be arranged by the Contractor for execution of work as per Technical Conditions of Contract of this tender within the quoted rate. Below given Quantities are tentative for planning purposes by the bidder.

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
1.	Tyre mounted mobile crane	12/14/18/20 MT	06Nos.	As per requirement
2.	Trailer with prime mover	22/30 MT	02 No	As per requirement
3.	DG SET – (Capacity as per requirement)	As required	01 set	For continuous/ uninterrupted back up power during welding & post weld heat treatment of welding joints

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
4.	Air compressor (electric/diesel operated)	210 CFM, 7 KG/CM2	02 nos.	As per requirement
5.	Tig welding set	As required	As required	As per requirement.
6.	Submerged ARC WELDING M/C		As required	As per requirement.
7.	Oxy Acetelyne Gas cutting Machine		As required	
8.	DC arc welding machine		As required	
9.	3-phase distribution board with complete set up for drawl of construction power	As required	As required	
10.	Power cable for drawl of construction power	As required	As required	
11.	Pre heating / stress relieving set (heating control panel, cables, heating elements, thermometers etc.)	As required	As required	As per requirement.
12.	Radiography arrangement with radioactive isotope source	As required	2 sets	As per Requirement, (quantity may vary as per site requirement.)
13.	Radiography arrangement with radioactive isotope source	Cobalt 60	Not Applicable	Not Applicable
14.	Theodolite of required accuracy	To ensure verticality of structural columns.	01Nos.	As per site requirement
15.	Self-drilling cum tapping machine for screws	As required	As required	As per site requirement
16.	Arrangement for UT of higher thickness joints with recording facility	Type USN 50 or equivalent/ up graded type	As required	As per site requirement

SN	DESCRIPTION	CAPACITY	MINIMUM	REMARKS
		(MINIMUM)	QUANTITY PER UNIT	
	& required calibration blocks.			
17.	Electro-hydraulic pipe bending machine	Up to 2" nb and 12 mm thick pipes	2 Nos	As per site requirement
18.	Welding rectifiers (electrical)	300 ampere rating	As required	As per site requirement
19.	Welding generator (diesel operated)	300 ampere rating	As required	As per site requirement
20.	Radiography film viewer	As required	As required	As per site requirement.
21.	Hydraulic pipe bending machine (manual)	For bending of pipes up to 50 mm NB size	4 Nos	As per site requirement
22.	Pipe chamfering machine /Tube Cutting	4-14"	As required	As per site requirement
23.	Pipe chamfering machine /Tube Cutting	14-20"	As required	As per site requirement
24.	Pipe cutting & beveling machines		As required	As per site requirement
25.	Chain pulley blocks of various & Suitable capacities		As required	As per site requirement
26.	Baking oven with thermostat and temperature gauge for welding electrodes	As required	As required	As per site requirement
27.	Holding oven with thermostat and temperature gauge for welding electrodes	As required	As required	As per site requirement
28.	Portable oven for welding electrodes	As required	As required	As per site requirement
29.	Electric winch	2/3/5/10/15 ton capacity	As required	As per site requirement

C 3.7	DEGCDIDET CT	OAD A CITTLE		DWW
SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
30.	Hand winch	0.5 ton/1.0 MT capacity	As required	
31.	Scaffolding materials with clamps.	Suitable for working at various heights	As required	For Erection, Alignment, welding & Insulation, painting works
32.	Profile making m/c	For aluminium sheet cladding work	As required	
33.	Nibbling m/c	For refractory and other	As required	
34.	Shearing m/c	required activities	As required	
35.	Portable grinding m/c	As required	As required	
36.	Portable drilling m/c	As required	As required	
37.	Portable hole drilling m/c	As required	As required	Minimum 01 from the start of work.
38.	Portable broaching m/c	As required	As required	Minimum 01 from the start of work.
39.	Hoisting and pulley devices/pulleys	Assorted capacities	As required	
40.	Fire retardant tarpaulins	As required	As required	
41.	Fire extinguisher	As required	As required	
42.	Hydraulic Jacks	10/20/50/100 MT	As required	
43.	Dewatering pumps(Electrical & Diesel engine operated)		As required	
44.	Various sizes of clamps/ fixtures for assembling		As required	

ON T	DECODIDATON	CARACITY	B # T D T T D # T T T T T T T T T T T T T	DESTABLE
SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
45.	Portable hardness tester		As required	
46.	Magnetic particle testing equipment-DRY & WET Type		As required	
47.	Temperature recorder for 0-1000C 6/12 points with thermo couples / rods and compensating cable		As required	
48.	elcometer for paint thickness checking		As required	
49.	Hand Operated Megger 500 / 1000 V		As required	
50.	Tong Tester 10, 20 Or 50 Amp + / - 3 % Accuracy		As required	
51.	Digital and Analogue Multimetres		As required	
52.	U Tube Manometer 0- 2000 mm Water Column		As required	
53.	Inclined Manometer 0- 50 mm Water Column		As required	
54.	Bolt Tension Calibrator		As required	
55.	Concrete Blocks		As required	For making bed of steel structure for checking dimensional accuracy, configuration and minor rectification.
56.	Wooden/Concrete sleeper 1.5-2.0 Mtr length	Since beginning	As required	For material storage at site.
57.	Calibrated Power driven HSFG bolt tightening machines with set value facility.		06 Nos	As per Site requirements

SN	DECCDIDITION	CAPACITY	MINIMUM	REMARKS
SIN	DESCRIPTION	(MINIMUM)	QUANTITY PER UNIT	REMARKS
58.	Impact wrench + Socket	Desired Size	10 nos.	05 no. to be deployed within 30 days from the date of start of work. Additional deployments as per requirement.
59.	Torque wrench	Desired Size	10 nos.	05 no. to be deployed within 30 days from the date of start of work. Additional deployments as per requirement.
60.	Equipment for carrying out preheating, postheating, radiography, and other NDT test like LPI/MPI etc along with consumables.	As required	As required	
61.	Stress relieving equipment with automatic recording devices such as heating elements, thermocouples, thermo-chalks, temperature recorders, thermocouple attachment units, graphs, sheets insulating materials like asbestos cloth, ceramic beads, asbestos ropes etc. required for heat treatment/ stress- relieving operations.	As required	As required	
62.	Portable Drilling machine		01 Nos	Having capacity to make a drill the Upto 32 mm Dia
63.	Air tightness Test pumps	As required		As per site requirement
64.	T& Ps for chemical clea	ning		

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
65.	List of suggestive safety Equipments/PPEs to be included in List of minimum T&P:			
66.	Safety Net (Conforming I Safety Net (Net Size: 10n Rope: 2mm double co diameter Polypropylene rope (test Length shall be provided	n x 5m, Mesh Size ord, Border/Tie ted as per IS: 517	Min-40 Nos/unit	
67.	Fall Arrester 'Rope grab Anchorage Line: 14mm- twisted Polyamide rope. Rope Grab fall arrester: 0	16 mm diameter,	Min 20 nos. of Rope Grab Fall arrester and Karbiner each. Min 30 nos. anchorage line,	
	Arrestor (on flexible line on 14-16 mm diameter p Material: Nickel Chrome	conforming EN 3 olyamide rope.		30 metre long each,
	Connector: Karbiner con Strength 22 KN), material: Steel	forming to EN 36	2 (Minimum	30 nos. anchorage line, 20 metre long each
68.	Horizontal life line Stainless Steel Wire rope of 8mm diameter. Minimum			Min 20 nos. of wire rope, each 40 metre long
	six nos. of steel U-bolt of each wire rope to a rigid supp at each end).	clips are required	d for clamping	Min 90 nos. of wire rope, each 25 metre long.

4.2.1 PASSENGER CUM GOODS ELEVATOR

BHEL shall provide Two (2) passenger cum goods elevator common for all three-unit Erection. Electricity for E&C and Usage shall be on chargeable basis. Erection, commissioning, day to day maintenance of the Elevator shall be in the scope of the vendor. In the event vendor is not able to erect and commission the elevator, they may take the help of original equipment manufacturer details of which may be obtained from BHEL. During the first installation, charges for supervisory services from the OEM will be provided by BHEL. Thereafter, it shall be the responsibility of the contractor. The contractor will bear the cost of consumables/spares during usage period as the elevator will be extensively used for erection and commissioning activities by the contractor. Day to day maintenance of the elevator will be in the scope of the vendor.

Statutory Load Testing of the installed Elevator through accredited agency who are authorized to issue such kind of certificates shall also be in the scope of vendor within the quoted price. Throughout the entire period of job execution, the agency requires to maintain live certificate of "Elevator Fitness" issued by the authorized agency as per Statutory norms.

4.3 MEASURING AND MONITORING DEVICES (MMD):

As per requirement to be finalized at site, shall meet the requirements as per field quality plan and other erection, testing related activities.

NOTE:

- 1. All above T&Ps are to be deployed by contractor as and when required as per instruction of BHEL engineer. If works gets delayed due to non-availability of above T&Ps, BHEL reserves the right to deploy the same and recover the charges thereof from the contractor as per prevailing market rate/hiring rate/BHEL internal hiring rates, as the case may be, + 5% overhead rates.
- 2. This above list of T&Ps (apart from Major T&Ps) is only indicative and neither exhaustive nor limiting. Quantities indicated above are only the minimum required. Contractor shall deploy all necessary T&P to meet the schedules & as prescribed by BHEL engineer and required for completion of work.
- 3. Depending upon the nature of work and availability of facilities locally, contractor may have to arrange for a temporary workshop for facilitating uninterrupted progress of work.
- 4. Necessary electrical / water / air connection required for operation of any of the tools & tackles shall be to Contractor's account.
- 5. Contractor has to submit the Calibration certificates of all the precision Equipment to BHEL. BHEL may ask for recalibration of the MMEs /precision equipment for ensuring quality of work. Contractor must re-ascertain/ recheck range and accuracy of each IMTE from BHEL Engineer well in advance before arranging calibration/ deployment.
- Any T&Ps, Cranes, Slings, D-shackles and other lifting tackles, Trailers required for shifting of material from store to site shall be arranged by contractor over and above T&Ps/ crane provided by BHEL.
- 7. T&P and the mobilization shown in the above-mentioned list is suggestive requirement considering parallel working in Main plant structural area. Mobilization schedule as mutually agreed at site for major T&Ps, have to be adhered to. Numbers / time of requirement will be reviewed time to time at site and contractor will provide required T&P / equipments to ensure completion of entire work within schedule / target date of completion without any additional financial implication to BHEL.

Vendor will give advance intimation & certification regarding capacity etc. prior to dispatch of heavy equipments. Also, on completion of the respective activity, demobilization of T&P in total or in part can be done with the due approval of engineer in charge. Retaining of the T&Ps during the contract period will be mutually agreed in line with construction requirement.

- 8. In the event of need of change of type of any of major T&Ps, approval shall be taken from BHEL Engineer in-charge prior to mobilization. The decision of Number of T&P required due to replacing the enlisted T&P as per above table, shall be taken after analyzing the production capacity and suitability of both the T&Ps.
- The contractor shall submit the valid test certificate/calibration certificates for all the T&Ps before put into actual use at site. The certificates shall be renewed time to time as instructed by BHEL Engineer
- 10. Crane operators deployed by the contractor shall be tested by BHEL before they are allowed to operate the cranes.
- 11. APR (As per Requirement)- Contractor has to deploy T&P, MMD, IMTE as per requirement of site and as decided by BHEL Engineer.
- 12. Apart from above mentioned T&P, any additional item required in addition to above mentioned T&P for proper execution of scope of work, contractor has to arrange such T&P within quoted rate on the instruction of BHEL in writing in a reasonable period within two weeks from the written instruction from BHEL.
- 13. T&P's mentioned above shall be specifically deployed. However, as per work requirement and availability of T&Ps the inter use in Material Handling and Mechanical works may be permitted as per the instruction of the BHEL Engineer.
- 14. If the work related to T & Ps mentioned above is completed then, BHEL can release that T & P during contract period / extended period if any. However, written permission shall be taken by contractor from BHEL construction Manager for releasing the T&P.
- 15. In the eventuality of contractor not deploying cranes / abnormal down time of cranes in his scope during the period specified above, and BHEL arranges for the same [either BHEL's own cranes / hired cranes], prevailing BHEL Corporate Crane hire charges (may vary from time to time) shall be recovered from the contractor's running bills. Corresponding pages of Corporate Crane hire charges are enclosed as part of VOL I as File titled "Annexure-1- BHEL T&P Hire Charges". (Please note that these charges are as valid up to Aug 31, 2025 and may get revised further).

- 16. The loading, unloading and transportation of contractors T&Ps shall be in the scope of contractor. All necessary items such as Trailers, Cranes, Winches, welding generators, slings, jacks, sleepers, rails etc., are to be arranged by the contractor at his own cost.
- 17. Contractor shall mobilise Portable hole drilling machine and Broaching machine for various diameters at site, as hole mismatch issue is very common in bolted type structure. All structures are bolted type.
- 18. The contractor has to furnish a list of Tools and plants including cranes / tractors / trailers / trucks etc. which he has proposed to deploy for this work.
- 19. The contractor shall arrange crane operator, diesel, petrol and other consumables required for the tools and plants, equipments etc. Preventive and routine maintenance of T & P are also to be arranged by the contractor at his cost without any delay. Required number of experienced mechanics and helpers for routine maintenance of the above cranes shall be provided by the contractor within his quoted rate.

20. Penalty due to non-availability of T&Ps:

In order to meet the site requirement and in line with monthly plan and review format (F-14), Contractor has to mobilise their T&Ps and make it available at site for required activities.

If contractor fails, due to the cases mentioned hereunder, BHEL shall be entitled to impose penalty on Contractor till any alternate arrangement is made by 'Contractor' OR 'BHEL (on cost recovery basis)'.

Case 1: Contractor fails to mobilise the Crane within the mobilisation period of 30 days from the date of intimation by BHEL.

OR

Case 2: After mobilisation of a particular Crane at site, the work is getting hampered due to non-availability of that Crane for more than consecutive 5 days in a month.

In both the cases, Penalty shall be levied at the rate of 50% X "daily rate*" for total no. of days eligible for penalty.

For Case 1: Number of days eligible for Penalty = Difference of (date of availability of Crane by Contractor) - (Minus) (30 days from the Date of intimation).

In above case if bidder fails to mobilize referred T&Ps, BHEL may mobilize the same and in that case aforementioned 'date of availability of 'Crane' shall be reckoned from the date T&P is made available by BHEL.

For Case 2: Number of days eligible for Penalty = (Number of days in a month, in which work is getting hampered, due to non-availability the crane) – (Minus) (05 days)

Daily Rate*= Monthly hire Charge /30.

NOTE:

- I) FOR CALCULATION NO. OF DAYS IN A CALENDAR MONTH IS TAKEN AS 30.
- II) **MONTHLY CRANE CHARGES** AS DERIVED IN THE Annexure 1- BHEL T&P Hire Charges.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter – V: T&Ps and MMEs to be deployed by BHEL on sharing basis

5.1 LIST OF T&P TO BE PROVIDED BY BHEL FREE OF HIRE CHARGES ON SHARING BASIS:

SL NO DESCRIPT	ΓΙΟΝ & CAPACITY	QUANTITY	REMARKS
	OF T&P		
1 Cranes /To	wer cranes	As decided by BHEL	All cranes (except Contractor scope as mentioned in clause 4.1) required for mentioned work will be arranged by BHEL as per requirement.

- 5.2 All the T&Ps mentioned in clause 5.1 above shall be given to contractor on sharable basis and the allotment is made by BHEL on need basis.
- 5.3 BHEL will provide the services of higher capacity crane, on sharing basis, for erection & other activities viz. Load Bundle Loading/Unloading activity.
- 5.4 Contractor shall transport from BHEL stores, install, operate, carry out maintenance, dismantle after use and return to BHEL stores all T&Ps mentioned in Sr no 5.1 for his use.
- 5.5 BHEL provided cranes are owned or hired by BHEL. Operator for BHEL owned crane will be arranged by BHEL. Operators for hired crane will be provided by the hiring agency.
- 5.6 Contractor shall make necessary arrangements like laying of special sleeper beds and steel plates (sleepers for BHEL owned/hired cranes shall be provided by the BHEL), assembly and dismantling of heavy attachment, boom, jib etc. for movement and operation of the crane. Contractor shall provide necessary manpower assistance for initial and final assembly & dismantling and for subsequent operations of boom extension and reduction during execution of work. Levelled area in ACC area will be provided by BHEL/customer for the cranes. Consolidation of the ground, if required (Area required for movement of crane), and preparation (including civil work with material) for placing crane for operation shall be done by the contractor, at his cost. Necessary plates / sleepers required for marching operation shall also be provided by the BHEL only for BHEL owned cranes.
- 5.7 Contractor shall provide the fuel, and consumables for BHEL provided cranes (hired/owned) for his use. Lubricants for crane (hired/owned) shall be provided by the BHEL.
- 5.8 Cranes are only for erection purpose and shall not be available for material handling or transportation purpose. Contractor shall make their own arrangements for material transportation to erection site.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter – V: T&Ps and MMEs to be deployed by BHEL on sharing basis

- 5.9 All the distribution boards, connecting cables, hoses etc., and temporary connection work including electrical connections for the BHEL issued T&Ps shall have to be arranged by the contractor at his cost.
- 5.10 The contractor at his cost shall arrange for grouting of anchor points of T&Ps issued to him. Necessary grout materials are to be arranged by the contractor at his cost.
- 5.11 The day-to-day and routine maintenance including replacement of spares for the BHEL T&Ps will be carried out by the contractor at his own cost. However, BHEL shall supply spare parts free of charges for normal wear and tear only.
- 5.12 Any loss/damage of tools by the contractor shall have to be replaced or otherwise cost thereof shall be recovered from the contractor.

Note: For Crane:

- 1. The cranes may be BHEL owned or may be obtained on hiring basis including operating and maintenance crew.
- 2. Operator and O&M for BHEL owned crane will be provided by BHEL.
- 3. Contractor shall provide the fuel for BHEL provided cranes (Hired/owned) for his use.
- 4. Contractor shall provide necessary manpower assistance for initial and final assembly & dismantling and for subsequent operations of boom extension and reduction during execution of work. Contractor shall also make necessary arrangements like laying of special sleeper beds and steel pates (sleepers for BHEL owned cranes shall be provided by the BHEL) for movement and operation of the crane.
- 5. Cranes provided by BHEL will be on sharing basis with other agencies / contractors of BHEL. The allocation of cranes shall be the discretion of BHEL engineer, which shall be binding on the contractor. Cranes will be deployed at appropriate time as decided by BHEL for suitable duration and intended purpose. Augmentation of BHEL T & P under special circumstances shall be discretion of BHEL.

6. TIME SCHEDULE & MOBILIZATION

6.1 INITIAL MOBILIZATION

After receipt of fax/Email LOI, Contractor shall discuss with Project Manager / Construction Manager regarding initial mobilization. Contractor shall reach site, make his site establishment and be ready to commence the erection work within **15 days** from the intimation/directions of Construction Manager/ Project Manager of BHEL. Such resources shall be progressively augmented to match the schedule of milestones and commissioning.

6.2 MOBILIZATION FOR ERECTION, TESTING, ASSISTANCE FOR COMMISSIONING ETC.

The activities for erection, testing etc. shall be started as per directions of Construction Manager of BHEL. Contractor shall mobilize further resources as per requirement to commence the work of erection, testing etc. of ACC Unit#2 and auxiliaries,

6.2.1 The contractor shall have to mobilize his resources earlier than the start of contract period for preparatory work like taking over and chipping of foundations, blue-matching, grouting of packer plates etc. or start of fabrication. The contractor shall complete all the works in the scope of this contract within the contract period. Pending points identified by the customer/BHEL during the execution of the contract are to be liquidated during the contract period itself.

6.3 COMMENCEMENT OF CONTRACT PERIOD AND TENTATIVE SCHEDULE

Erection/placement on its designated foundation / location, of the first major permanent equipment / component / structure covered in the scope of these specifications, (whichever is earlier as decided by BHEL) shall be recognized as "Start of contract period". The actual date of start of work of ACC package will be certified by BHEL site in-charge/CM after adequate mobilisation of manpower, T&P by the contractor. This certificate date will be deemed as start of work of the ACC pkg. at site for purpose of the contract time schedule.

Smaller items like packer plates, shims, anchors, inserts etc. will not be considered as start of contract period. The date of Start of contract period shall be the mutually agreed date between the bidder and BHEL engineer to start the work. In case of discrepancy, the decision of BHEL engineer is final.

Based on the availability of civil foundations from BHEL and materials from manufacturing units, contractor may have to advance the start of erection after getting clearance from construction manager, or the start of erection may get delayed due to site condition.

The Contractor has to subsequently augment his resources in such a manner that following major milestones of erection & commission are achieved on specified schedules. The schedule of important milestones is as follows:

<u>A</u>	Air cooled Condenser Unit #2				
SL No.	Milestones	Tentative Completion schedule			
1.	ACC Erection Start	1st Month			
2.	Commencement of Air Leak Test of Overall ACC system	7th month			
3.	Overall Flushing through Steam Dumping of ACC	9th Month			
4.	Readiness of ACC	10th Month			

6.4 CONTRACT PERIOD

The contract period for completion of entire work under scope shall be **10 (Ten) months** from the "**START OF CONTRACT PERIOD**" as specified earlier for completion of the entire work.

6.5 PROVISION OF PENALTY IN CASE OF SLIPPAGE OF INTERMEDIATE MILESTONES:

In case of slippage of Two Major Intermediate Milestones, mentioned as M1 & M2 hereunder, Delay Analysis shall be carried out on achievement of each of these two Intermediate Milestones in reference to Contractor performance review format F-14.

Milestones	Activities	To be completed by
M1	Commencement of Air Leak Test of ACC system	07th Month from start date
M2	Overall Flushing through Steam Dumping of ACC	9th Month from start date

Note A:

Provision of Penalty in case of slippage of Intermediate Milestones:

- i) Two major Intermediate Milestones are mentioned as M1 & M2.
- ii) In case of slippage of these identified Intermediate Milestones, Delay Analysis shall be carried out on achievement of each of these two Intermediate Milestones in reference to Form 14.
- iii) In case delay in achieving M1 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value*, limited to maximum 2% of Executable Contract Value, will be withheld.

- iv) In case delay in achieving M2 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value*, limited to maximum 3% of Executable Contract Value, will be withheld.
- v) Amount already withheld, if any against slippage of M1 milestone, shall be released only if there is no delay attributable to contractor in achievement of M2 Milestone.
- vi) Amount required to be withheld on account of slippage of identified intermediate milestone(s) shall be withheld out of respective milestone payment and balance amount (if any) shall be withheld @10% of RA Bill amount from subsequent RA bills.
- vii) Final deduction towards LD (if applicable as per clause 2.7.9 above), on account of delay attributable to contractor shall be based on final delay analysis on completion / closure of contract. Withheld amount, if any due to slippage of identified intermediate milestone(s) shall be adjusted against LD or released as the case may be.
- viii) In case of termination of contract due to any reason attributable to contractor before completion of work, the amount already withheld against slippage of intermediate milestones shall not be released and be converted into recovery.
 - * Executable Contract Value Value of work for which inputs/ fronts were made available to contractor and were scheduled for execution till the date of achievement of that milestone.

Note B:

- 1. Above time schedule is tentative and in order to meet above schedule in general, and any other intermediate targets set, to meet customer/project schedule, contractor shall arrange & augment all necessary resources from time to time as per the instructions of BHEL.
- 2. The above schedule is tentative. In case the activities in the schedule are to be advanced, the related Erection activities in the scope of the contractor are to be advanced to meet the project requirement. No extra payment whatsoever shall be paid on this account.
- 3. The contractor shall submit and a detailed area/structure wise L3 schedule within 7 days in consultation with BHEL based on the tentative schedule provided as above. The detailed L3 schedule shall be approved by BHEL and same shall be implemented. Bidder shall submit L3 schedule in MS Projects to meet the agreed project schedule covering various mile stone activities and their split up details such as mobilization, procurement of materials, fabrication & erection activities. This schedule shall also clearly indicate the interface facilities / inputs applicable in the package.
- 4. Site Data Digitalization: Daily Activity Log, M-Book and Subcontracting Billing Module: -
 - I. Refer Vendor Portal System with links: for ref. https://pshq.bhel.in/sddvp/
 - II. Login ID and Password shall be provided by respective package manager.

- III. Contractor by clicking 'Daily Work Photos', shall upload area wise photos on daily basis.
- IV. Contractor by clicking 'Daily Activity Log', shall update site activities on daily basis.
- V. Contractor by clicking 'Measurement Book', shall enter Measurement Book in Format and BOQ.
- VI. Contractor shall raise their RA Bills along with supporting documents (such as Quality and HR Document Vetted by Customer Etc.) and checklist through SDD portal only.
- VII. Contractor shall comply the system requirement.
- VIII. Refer Vendor Manual for further details.
 - IX. The contractor shall be required to provide all facilities including manpower for the aforementioned activities, without any cost implications to the BHEL. Agency shall extend all support towards inputs for IPMS system for project monitoring and control.

7. Terms of payment

The progressive payment for erection, testing and commissioning on accepted price of contract value will be released as per the break up given hereinafter:

7.1 Progressive Payment against monthly running bills will be made upto 85 % of the

value of the erected Pro-rata as per SL no 7.1.1 to 7.1.5 of the following table.

	Contract (Main Package) Identification>		J		
SL NO	Rate schedule Identification>	Foundation & Structures etc. (GR-I)	(Rotating Machine & misc. eqp. (GR-II)	Ducting &Piping all type (III)	Lightly resin bonded mineral (rock) wool mattress (Gr-V)
I	PRO RATA PAYMENTS (85%)				
7.1.1	ON PRE-ASSEMBLY WHEREVER APPLICABLE (IF NOT APPLICABLE, THIS PORTION SHALL BE CLUBBED WITH PLACEMENT IN POSITION)	20%	20%	20%	
7.1.2	PLACEMENT IN POSITION	20%	20%	20%	50%
7.1.3	ALIGNMENT	20%	20%	20%	15%
7.1.4	WELDING/BOLTING/FIXING /Hangers completions/Grouting	20%	20%	20%	20%
7.1.5	COMPLETION OF NON-DESTRUCTIVE EXAMINATION & STRESS RELIEVING/ HEAT TREATMENT (if not applicable, then this portion to be paid along with WELDING/BOLTING/FIXING)	5%	5%	5%	
	TOTAL FOR PRO RATA PAYMENTS (85%)	85%	85%	85%	85%

7.2 Further 15 % payment on pro-rata basis shall be released on achievement of the following stage / milestones events (as per Cl no 7.2.1 to 7.2.11 of the following table) for the tonnage erected.

SL NO	Contract (Main Package) Identification>			
-------	---	--	--	--

	Rate schedule Identification>	Foundation & Structures etc. (GR-1)	(Rotating Machine & misc. eqp. (GR-II)	Ducting & Piping all type (III)	Lightly resin bonded mineral (rock) wool mattress (Gr-V)
II	STAGE/MILESTONE PAYMENTS (15%)				
7.2.1	Piping Pressure Test by Air Leak test method. (Payable for the respective items / Equipments which are linked with the segment wise testing completed)	5%		5%	
7.2.2	Equipment Trial Operation		5%		
7.2.3	Completion of hydraulic test/ATT			1%	
7.2.4	Completion of overall flushing of ACC through Steam dumping method	1%	1%	1%	5%
7.2.5	Commissioning of ACC system		1%		
7.2.6	Painting	1%	1%	1%	
7.2.7	Area cleaning, temporary structures cutting/removal and return of scrap	1%	1%	1%	3%
7.2.8	Punch List points/pending points liquidation	3%	3%	2%	4%
7.2.9	Submission of 'As Built Drawings'			1%	
7.2.10	Material Reconciliation	3%	2%	2%	2%
7.2.11	Completion of Contractual Obligation	1%	1%	1%	1%
	TOTAL FOR STAGE/MILESTONE PAYMENTS (15%)	15%	15%	15%	15%

7.3 VOID

7.4 The accepted rates for **Lifting Device (Group-VI)** shall be distributed in the following manner for releasing payments against RA bills (as per Cl no 7.4.1 to 7.4.4 of the following table) for the tonnage erected

SL NO	Rate schedule Identification→	LIFTING DEVICE" (GR-VI)
7.4.1	Erection of Complete Assembly	55%
7.4.2	Testing and Commissioning	20%

SL NO	Rate schedule Identification→	LIFTING DEVICE" (GR-VI)
7.4.3	Load Testing and obtaining statutory Fitness Certificate of the installed device.	15%
7.4.4	Final painting (if applicable) and handing over to BHEL/NTPC	10%
	Total	100%

7.5 PG test assistance. (On the basis of quoted/accepted rate).

SL NO	Rate schedule Identification>	PG test assistance
7.5.1	On completion of the PG test of the unit which is to be certified by the BHEL Engineer	100%

Note: In case the PG Test assistance is not required, the payment towards this will not be considered.

7.6 Note Common to all Rate schedule:

- 7.6.1 Out of above break up for progressive payment, 5% will be retained from each RA bill which will be released on completion of guarantee period. However, this 5% payment can be released against submission of performance bank guarantee valid for the guarantee period as stated above in prescribed proforma subject to receipt of certificate that all works are completed in all respects. The submission of bank guarantee towards performance guarantee is separate and the bank guarantee towards security deposit cannot be utilized for this purpose. The security deposit will be refunded as per GCC.
- **7.6.2** BHEL at their discretions may further split up the above percentages and effect payment to suit the site condition, cash flow requirement and according to the progress of work.
- 7.7 Progressive Payment/ Final Payment: The payments for works under the scope of this contract for both the packages shall be as per clause no 2.6; 2.22; 2.23 of General Conditions of Contract and Volume-IB, Chapter-X of SCC.

7.8 Documents required for RA Bill:

- 7.8.1 GST Complied Invoice of the work done as per approved BBU.
- 7.8.2 WAM -6 for RA Bill.
- 7.8.3 Jointly signed Measurement sheet.
- 7.8.4 Power of Attorney before submission of Bill.
- 7.8.5 Validity of Bank Guarantees as applicable under the contract.
- 7.8.6 Monthly HSE Compliance Certificate certified by BHEL- Safety

- 7.8.7 Monthly Material reconciliation statement along with RA Bill.
- 7.8.8 HR/IR compliance documents:
 - i. Wages payment sheet as per applicable minimum wages.
 - ii. Proof of PF contribution submission.
 - iii. Proof of ESI/WC contribution submission
 - iv. Proof of Bonus payment as per Bonus Act if applicable.
 - v. Proof of EL payment if applicable.
 - vi. Any other statutory document if applicable.
- **7.9 Documents required for Final Bill:** The final bill is drawn as soon as the entire work is completed. From the final amount due, all amounts already claimed up to the previous running account bill will be deducted. It should be ensured that in the final bill the following additional particulars have been provided:
 - 7.9.1 Final Bill in WAM-7 Format.
 - 7.9.2 'No claim' certificate from the contractor.
 - 7.9.3 Clearance certificates where ever applicable viz. Clearance Certificates from Customer, various Statutory Authorities like Labour department, PF Authorities, Commercial Tax Department etc.
 - 7.9.4 Final Material re-conciliation statement duly approved by BHEL.
 - 7.9.5 Indemnity Bond as per prescribed format.
 - 7.9.6 Deviation statement showing the difference between the actuals and as per the contract.
 - 7.9.7 Final Delay Analysis.
- 7.10 The payment for running bills will be released after submission of running bill complete in all respects with all documents. It is the responsibility of the contractor to make his own arrangements for making timely payments towards labour wages, statutory payments, outstanding dues etc. and other dues in the meanwhile. No interest shall be payable for the delayed payment (if any).
- **7.11** Few points of consideration are as below:
 - 7.11.1 The measurements sheets of work done in a month shall be submitted in triplicate duly agreed/signed by BHEL Engineer. The contractor shall extend all necessary assistance for verification of measurements of works without any extra cost.
 - 7.11.2 Material reconciliation shall be complied on monthly basis.
 - 7.11.3 The RA bill payments are interim payments and bills shall be submitted in prescribed formats.
 - 7.11.4 Recoveries on account of electricity, water, statutory deductions etc. shall be made as per terms of contract.
 - 7.11.5 BHEL will release payment through Electronic Fund Transfer (EFT)/RTGS.
 - 7.11.6 Final bill shall be submitted after completion of works and upon material reconciliation along with all prescribed formats.
- **7.12** Quoted Rates are inclusive of all labour, contractor's equipment, temporary works, consumables and all matters and things of whatsoever nature, charges for Safety Aspects/Compliance to Safety Rules including operations and maintenance

services (if applicable) etc., and other services, as identified in the tender Documents, as necessary for the proper execution of the subject work.

- 7.13 **SECURED RECOVERABLE ADVANCES:** Interest Free Secured Mobilization Advance as per GCC Clause No. 2.13.1 will be payable under exceptional circumstances on certification of BHEL Construction Manager at Site. Interest Free Mobilization Advance shall be disbursed in specifically mentioned stages of major respective resource mobilization as specified hereunder:
 - 7.13.1 For Mobilization of 01 no. of Crane of 75 MT capacity 2.0% of Contract value of each package.
 - 7.13.2 For Mobilization of balance required T&Ps and resources at site to start the work 1.5% of Contract value of each package.
 - 7.13.3 For Installation and Erection of Site Infrastructure by contractor i.e. site office stores etc. 1.5% of Contract value of each package.

Note:

- 1. BHEL Site-CM shall be the deciding authority for assessing the admissibility of advance payment to contractor.
- 2. In case contractor do not fulfil the agreed conditions of payment of earlier mobilization advance, BHEL Construction Manager will have the authority to not allow the subsequent mobilization advance to contractor.

7.14 EXTRA CHARGES FOR RECTIFICATION/ MODIFICATION:

- 7.14.1 Extra work shall be as per provision of G.C.C
- 7.14.2 Bills against Extra work covered under clause mentioned above, can be raised only on completion of that particular work. While 95% amount will be released on work completion, balance 5% shall be released on completion of guarantee period.
- 7.14.3 In the event of any dispute regarding acceptance of any work as "EXTRA", the work has to be carried out by keeping man-hour and consumables record jointly signed with remark "for HQ decision". Under no circumstances, the bidder can refuse to carry out such work with pre-condition, save and except of keeping daily record of category of man-hours and consumables spent for the particular job for further consideration by HQ at PSWR Nagpur.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

8.0	TAXES & DUTIES
8.1	The contractor shall pay all (save the specific exclusions as enumerated in this clause) taxes, fees, license, charges, deposits, duties, tools, royalty, commissions, other charges, etc. which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes/duties, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.
	However, provisions regarding GST on output supply (goods/service) and TDS/TCS as per Income Tax Act shall be as per following clauses.
8.2	GST (Goods and Services Tax)
8.2.1	GST as applicable on output supply (goods/services) are excluded from contractor's scope; therefore, contractor's price/rates shall be exclusive of GST. Reimbursement of GST is subject to compliance of following terms and conditions. BHEL shall have the right to deny payment of GST and to recover any loss to BHEL on account of tax, interest, penalty etc. for non-compliance of any of the following condition.
8.2.2	The admissibility of GST, taxes and duties referred in this chapter or elsewhere in the contract shall be limited to direct transactions between BHEL & its Contractor. BHEL shall not consider GST on any transaction other than the direct transaction between BHEL & its Contractor.
8.2.3	Contractor shall obtain prior written consent of BHEL before billing the amount towards such taxes. Where the GST laws permit more than one option or methodology for discharging the liability of tax/levy/duty, BHEL shall have the right to adopt the appropriate one considering the amount of tax liability on BHEL/Client as well as procedural simplicity with regard to assessment of the liability. The option chosen by BHEL shall be binding on the Contractor for discharging the obligation of BHEL in respect of the tax liability to the Contractor.
8.2.4	Contractor has to submit GST registration certificate of the concerned state. Contractor also needs to ensure that the submitted GST registration certificate should be in active status during the entire contract period.
8.2.5	Contractor/Vendor has to issue Invoice/Debit Note/Credit Note indicating HSN/SAC code, Description, Value, Rate, applicable tax and other particulars in compliance with the provisions of relevant GST Act and Rules made thereunder.
8.2.6	Vendor has to submit GST compliant invoice within the due date of invoice as per GST Law. In case of delay, BHEL reserves the right of denial of GST payment if there occurs any hardship to BHEL in claiming the input thereof. In case of goods, vendor has to provide scan copy of invoice & GR/LR/RR to BHEL before movement of goods starts to enable BHEL to

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

	meet its GST related compliances. Special care should be taken in case of month end transactions.
8.2.7	Vendor has to ensure that invoice in respect of such services which have been provided/completed on or before end of the month should not bear the date later than last working day of the month in which services are performed.
8.2.8	Subject to other provisions of the contract, GST amount claimed in the invoice shall be released on fulfilment of all the following conditions by the Contractor: -
	a. Supply of goods and/or services have been received by BHEL.
	b. Original Tax Invoice has been submitted to BHEL.
	c. Contractor/ Vendor has submitted all the documents required for processing of bill as per contract/ purchase order/ work order.
	d. In cases where e-invoicing provision is applicable, vendor/contractor is required to submit invoice in compliance with e-invoicing provisions of GST Act and Rules made thereunder.
	e. Contractor has filed all the relevant GST return (e.g. GSTR-1, GSTR-3B, etc.) pertaining to the invoice submitted and submit the proof of such return along with immediate subsequent invoice. In case of final invoice/ bill, contractor has to submit proof of such return within fifteen days from the due date of relevant return.
	f. Respective invoice has appeared in BHEL's GSTR - 2A for the month corresponding to the month of invoice and in GSTR-2B of the month in which such invoices has been reported by the contractor along with status of ITC availability as "YES" in GSTR-2B. Alternatively, BG of appropriate value may be furnished which shall be valid at least one month beyond the due date of confirmation of relevant payment of GST on GSTN portal or sufficient security is available to adjust the financial impact in case of any default by the contractor.
	g. Contractor has to submit an undertaking confirming the payment of all due GST in respect of invoices pertaining to BHEL.
8.2.9	Any financial loss arises to BHEL on account of failure or delay in submission of any document as per contract/purchase order/work order at the time of submission of Tax invoice to BHEL, shall be deducted from contractor's bill or otherwise as deemed fit.
8.2.10	TDS as applicable under GST law shall be deducted from contractor's bill.
8.2.11	Contractor shall comply with the provisions of e-way bill wherever applicable. Further wherever provisions of GST Act permits, all the e-way bills, road permits etc. required for transportation of goods needs to be arranged by the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

8.2.12	Contractor shall be solely responsible for discharging his GST liability according to the provisions of GST Law and BHEL will not entertain any claim of GST/interest/penalty or any other liability on account of failure of contractor in complying the provisions of GST Law or discharging the GST liability in a manner laid down thereunder.
8.2.13	In case declaration of any invoice is delayed by the vendor in his GST return or any invoice is subsequently amended/altered/deleted on GSTN portal which results in any adverse financial implication on BHEL, the financial impact thereof including interest/penalty shall be recovered from the Contactor's due payment.
8.2.14	Any denial of input credit to BHEL or arising of any tax liability on BHEL due to non-compliance of GST Law by the Contractor in any manner, will be recovered along with liability on account of interest and penalty (if any) from the payments due to the Contactor.
8.2.15	In the event of any ambiguity in GST law with respect to availability of input credit of GST charged on the invoice raised by the contractor or with respect to any other matter having impact on BHEL, BHEL's decision shall be final and binding on the contractor.
8.2.16	Variation in Taxes & Duties:
	Any upward variation in GST shall be considered for reimbursement provided supply of goods and services are made within schedule date stipulated in the contract or approved extended schedule for the reason solely attributable to BHEL. However downward variation shall be subject to adjustment as per actual GST applicability.
	In case the Government imposes any new levy/tax on the output service/goods after price bid opening, the same shall be reimbursed by BHEL at actual. The reimbursement under this clause is restricted to the direct transaction between BHEL and its contactor only and within the contractual delivery period only.
	In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer but before opening of the price Bid, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same before opening of price bid. Claim for any such impact after opening the price bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.
8.3	Income Tax:
	TDS/TCS as applicable under Income Tax Act, 1961 or rules made thereunder shall be deducted/collected from contractor's bill.

8.4 BOCW Act & Cess Act

8.4.1 BOCW Cess is not to be borne by contractor. Refer Annexure-I for BOCW Act & Cess Act.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

	Annexure-I:
worke	r may please note that the sub-contractor/bidder of BHEL engaging building or construction er in connection with building or other construction work, are required to follow the dures enumerated below:
1.	It shall be the sole responsibility of the contractor as employer to ensure compliance of all the statutory obligations under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
2.	It shall be sole responsibility of the contractor engaging Building Workers in connection with the building or other construction works in the capacity of employer to apply and obtain registration certificate specifying the scope of work under the relevant provisions of the Building and Other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 from the appropriate Authorities.
3.	It shall be responsibility of the contractor to furnish a copy of such Registration Certificate within a period of one month from the date of commencement of Work.
4.	It is responsibility of the contractor to register under the Building and other Construction Workers' Welfare Cess Act, 1996 and deposit the required Cess for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 at such rate as the Central Government may, by notification in the Official Gazette, from time to time specify. However, before registering and deposit of Cess under the Building and other Construction Workers' Welfare Cess Act, 1996, the contractor will seek written prior approval from the Construction Manager.
5.	It shall be sole responsibility of the contractor as employer to get registered every Building Worker, who is between the age of 18 to 60 years of age and who has been engaged in any building or other construction work for not less than ninety days during the preceding twelve months as Beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996.
6.	It shall be sole responsibility of the contractor as employer to maintain all the registers, records, notices and submit returns under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
7.	It shall be sole responsibility of the contractor as employer to provide notice of poisoning or occupation notifiable diseases, to report of accident and dangerous occurrences to the

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

	Ghapter VIII. Taxes and Battes
	concerned authorities under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the rules made thereunder and to make payment of all statutory payments & compensation under the Employees' Compensation Act, 1923.
8.	It shall be the responsibility of the sub-contractor as employer to make payment/deposit of applicable cess amount on the extent of work involving building or construction workers engaged by the sub-contractor within a period of one month from the receipt of payment. It shall also be responsibility of the Contractor to furnish BHEL on monthly basis, Receipts/Challans towards Deposit of the Cess under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder along with following statistics:
	 i) Number of Building Workers employed during preceding one month. ii) Number of Building workers registered as Beneficiary during preceding one month. iii) Disbursement of Wages made to the Building Workers for preceding wage month. iv) Remittance of Contribution of Beneficiaries made during the preceding month
9.	BHEL shall reimburse the contractor the Cess amount deposited for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder. However, BHEL shall not reimburse the Fee paid towards the registration of establishment, fees paid towards registration of Beneficiaries and Contribution of Beneficiaries remitted.
10.	It shall be responsibility of the Building Worker engaged by the Contractor and registered as a beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 to contribute to the Fund at such rate per mensem as may be specified by the State government by notification in the Official Gazette. Where such beneficiary authorizes the contractor being his employer to deduct his contribution from his monthly wages and to remit the same, the contractor shall remit such contribution to the Building and other construction Workers' Welfare Board in such manner as may be directed by the Board , within the fifteen days from such deduction.
11.	Bidders may please note that though the quoted price is exclusive of BOCW (which will be reimbursed by BHEL as per sub-clause 9 above), however, If at any point of time during the contract period, non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder is observed, BHEL reserves the right to deduct the applicable cess (1%) on the contract value and penalty (if any, imposed by Cess Authorities) from the payables on account of non-compliance.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-VIII: Taxes and Duties

The contractor shall declare to undertake any liability or claim arising out of employment of building workers and shall indemnify BHEL from all consequences / liabilities / penalties in case of non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.

BILL OF QUANTITY/WEIGHT SHCEDULE

9.0 Summary of Weight of BOQ for ACC #3

Table- 1: SUMMARY OF TOTAL TONNAGE CATEGORY WISE ACC#3			
Group (GR) Type	Descriptions	Qty (In MT)	
GR-I	Foundation & Structures etc. (GR-I)	8813	
GR-II	Rotating Machine & misc eqp. (GR-II)	1075	
GR-III	Ducting &Piping all type (III)	1643	
GR-IV	NIL	0	
GR-V	Insulation (Gr-V)	104	
GR-VI	Lifting Device (GR-VI)	11	
	Grand Total	11646	

9.1 Detailed (GR Type Wise) weight of BOQ for Structures Ducting, Piping Rotary & insulations, -

	ACC#2				
Sl no	Item Description	GR type	Unit	Quantity	Approx. Total Weight (MT)
A	Foundation & Structures etc. (GR-I)				
1	Anchor plate (EM)	GR-I	Set	20	54.4
2	Under deck structure (UD)	GR-I			
3	Fan beam & decks (OB+FD)	GR-I			
4	A frame, partition wall, Sheeting (AF)	GR-I	set	1	4000
8	Wind Wall structure (WW)	GR-I			
5	Finned tube bundles	GR-I	Set	1008	4032
6	Monorails for fan device	GR-I	Set	8	40
7	Mono rails on platforms	GR-I	Set	1	10
9	High strength bolts	GR-I	MT		49.6
10	Condensate Storage tank	GR-I	no	1	50
11	Vacuum Deaerator	GR-I	no	1	5
12	Condensate Storage tank support structure	GR-I	set	1	50
13	Gratings for ACC platform, pipe rack, CST tank support structure	GR-I	unit	1	200

			(- ()		
14	Cooled upper condenser platform and ladder	GR-I	nos	8	16
15	Access ladder to Bundle walkways	GR-I	set	8	4
16	Platforms and walk way	GR-I	set	1	10
17	Doors and frame	GR-I	set	80	12
18	Gearbox support	GR-I	set	72	40
19	Maintenance platform	GR-I	MT		20
20	Stair case and handrails	GR-I	MT		80
21	Steel corrugated sheets of wind wall & platform	GR-I	set	1	120
22	Steam Duct Support	GR-I	Set	1	20
	Total of Gr-I				8813
В	Rotating Machine & misc eqp.				
	(GR-II)	an u		=0	400
1	Fan Bridge	GR-II	set	72	432
2	Fan Motor	GR-II	set	72 	108
3	Gear Box	GR-II	set	72 - 2	108
4	Fan Hub & blades	GR-II	set	72	72
5	Fan ring/Bell	GR-II	set	72	324
6	Fan safe guard	GR-II			
7	Vacumm pump for holding	GR-II	nos	2	10
8	Vacumm pump for Hogging	GR-II	nos	2	20
9	Cleaning pump including Junction box	GR-II	nos	2	1
	Total of Gr-II				1075
C	Ducting &Piping all type (III)	T			
1	Tube bundle below header	GR-III	set	1	206
2	Steam distribution manifold	GR-III	set	1	567
4	Horizontal duct (Dia 8 mtr)	GR-III	set	1	157
5	Elbow/Y piece(Dia 8 mtr)	GR-III	set	1	170
6	Vertical Duct (Dia 8 mtr)	GR-III	360	1	170
7	Distribution Header (Dia 8 to 2.8 mtr)	GR-III	set	1	284
8	Riser (Dia 2.8 mtr)	GR-III			
10	lateral expansion joint (Dia 8 mtr)	GR-III	no	1	20
13	lateral expansion joint (Dia 2.8 mtr)	GR-III	nos	8	24
14	hinged expansion joint (Dia 2.8 mtr)	GR-III	nos	8	24

	SCOLE O.		(4)		
15	Main isolation valves (Dia 2.8 mtr)	GR-III	nos	8	16
16	Condensate Pipe and Support	GR-III			
17	Valve and accessary	GR-III			
18	Cooling water and make up water piping	GR-III	set	1	150
19	Instrument air piping	GR-III			
20	Rupture Disc	GR-III	nos	14	7
21	Drain pot	GR-III	no	1	8
22	Hp hose under platform	GR-III	Set	1	
23	HP SS tube	GR-III	Set	1	
24	HP Spring connector and valve platform	GR-III	Set	1	
25	HP hose and platform set	GR-III	Set	1	10
26	Washing Device Chassis	GR-III	Set	1	10
27	Driving device	GR-III	Set	1	
28	Nozzle panel	GR-III	Set	16	
29	Guide rail	GR-III	Set	16	
30	Control panel	GR-III	Set	1	
	Total of Gr-III				1643
D	NIL (GR-IV)		Uni t	Qty	Weight (MT)
1	NIL	Gr-IV	nos	0	0
	Total Of Gr-IV				
E	Insulation (Gr-V)				0
					0
1	Lightly resin bonded mineral (rock) wool	Gr-V	M3	648	100
2		Gr-V Gr-V	M3 M2	648 6800	-
	(rock) wool				-
2	(rock) wool Aluminium plate	Gr-V	M2	6800	100
2	(rock) wool Aluminium plate Accessories	Gr-V	M2	6800	100
3	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist	Gr-V	M2	6800	100
2 3 F	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI)	Gr-V Gr-V	M2 MT	6800 4	100
2 3 F	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist Electrical hoist (to be ins. Fan	Gr-V Gr-VI	M2 MT no	6800 4 8	100 4 104
2 3 F 1	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist Electrical hoist (to be ins. Fan deck level)	Gr-V Gr-VI Gr-VI	M2 MT no	6800 4 8 1	100 4 104
2 3 F 1 2	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist Electrical hoist (to be ins. Fan deck level) EOT crane for Vacumm pump	Gr-V Gr-VI Gr-VI Gr-VI	M2 MT no no	8 1 1	100 4 104
2 3 F 1 2	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist Electrical hoist (to be ins. Fan deck level) EOT crane for Vacumm pump EOT for drain pump	Gr-V Gr-VI Gr-VI Gr-VI	M2 MT no no	8 1 1	100 4 104
2 3 F 1 2	(rock) wool Aluminium plate Accessories Total Of Gr-V Lifting Device (GR-VI) Chain Hoist Electrical hoist (to be ins. Fan deck level) EOT crane for Vacumm pump EOT for drain pump	Gr-V Gr-VI Gr-VI Gr-VI	M2 MT no no	8 1 1	100 4 104

9.2 Note to weight schedule:

- 1. The weights/Quantities/Dimensions mentioned are approximate and liable to vary as per design consideration. There will be change in GR category/TYPE, weight, description etc. However, payments will be made for the tonnage actually erected at the quoted rate. Quantity Variation will be dealt as per clause 2.14 of General Conditions of Contract.
- 2. Besides GR Type indicated in the weight schedule, there is likely hood of addition product groups integral to Structure, rotary M/C, Insulations, ducting etc. and its aux. The quoted rate shall be applicable for such product groups /GT Type also. There may be variation or addition of GR type, description, weights etc., and any additional scope of work supplied under the above package shall be erected by the contractor and payment will be made as per the quoted / accepted rate in the respective category at the discretion of BHEL.
- 3. Rate Schedule Identified for GR Type are based on envisaged material specification. Payment shall be made on the basis of material specification of actual material received and erected at site. BHEL's decision in this regard shall be final.
- 4. The erection & dismantling of temporary piping, pumps, tanks, dummy plates & blanks, valves, pressure gauges and other miscellaneous equipment required for the test. for pre-commissioning and commissioning activities like hydraulic test, chemical cleaning, flushing etc. are covered in this contract and shall be carried out as a part of work. Payment will be made at the rate applicable for **GR Type-I** for items. Weight for the same will be based on jointly measured quantity and corresponding standard weights. No payment will be made for the equipments brought by the Contractor such as pumps etc and foundations made by the Contractor for temporary systems. Weight for the same will be based on jointly measured quantity and corresponding standard weights. Except contractor scope materials/Pump.

Payment terms for temporary piping:

- a. 50% on completion of installation of temporary piping.
- b. 25% on dismantling
- c. 15% on return of BHEL Stores
- d. 10% on Material reconciliation.

Note: Required pipes, valves, blanks, plates etc., will be given by BHEL. Temporary piping, pumps, valves, flanges, blanks etc shall be removed by him and returned to BHEL. All thermo well points are to be seal welded, with plug in position. All Temperature Element points are to be provided with blanks and welded.

5. Fixing components for insulation: The scope of works covers welding of all attachments on the piping/duct for fixing insulation & refractory.

10.1 GENERAL

Site Visit by the Bidder

- 10.1 The bidder shall, prior to submitting his tender for the work, visit and examine the site of works and its surroundings at his own expense, and obtain and ascertain for himself on his own responsibility all information that may be necessary for preparing his tender and entering into a contract, and take the same into account in the quoted contract price for the work.
- 10.2 The bidder shall satisfy themselves about the following factors:
- i) Site conditions including access to the site, existing and required roads and other means of transport/communication for use by him in connection with the work including diverting and re-routing of services.
- ii) Requirement and availability of land and other facilities of his enabling works, establishment of his nursery, office, stores etc.
- iii) Ground conditions including those bearing upon transportation, disposal, handling and storage of materials required for the work or obtained there-from.
- iv) Source and extent of availability of suitable materials, including water etc., and labour (skilled and unskilled) required for work, and laws and regulations governing their use and employment.
- v) Geological, meteorological, topographical and other general features of the site and its surroundings as are pertaining to and needed for the performance of the work.
- vi) The limit and extent of surface and subsurface water to be encountered during the performance of the work, and the requirement of drainage and pumping.
- vii) The type of equipment and facilities needed, for and in the performance of the work:
- viii) The extent of lead and lift required for the work in complete form over the entire duration of the contract, and All other information pertaining to and needed for the work including information as to the risks, contingencies and other circumstances which may influence or affect the work or the cost thereof under this contract.
- 10.3 Contractor shall execute the work as per sequence and procedure prescribed by BHEL at site. The applicable erection manuals which are available with BHEL site office are to be referred for compliance and guidance before taking up the work. Any rework on this failure to comply with will be to account of contractor only. BHEL engineer, depending upon the availability of materials, fronts etc., will decide the sequence of erection and methodology. No claims for extra payment from the contractor will be entertained on the grounds of deviation from the method of erection adopted in erection of similar jobs in other projects or for any reason whatsoever.
- 10.4 The contractor is strictly prohibited from using BHEL's regular components like angles, channels, beams, plates, pipe / tubes, and handrails etc. for any temporary supporting or approach platforms or scaffolding works or as bed for pre-assembly works. Contractor shall arrange himself all such materials. The Contractor shall make

all fixtures, temporary supports, steel structures required for jigs & fixtures, anchors for load and guide pulleys required for the work. Contractor shall arrange necessary steel (angles, channels, beams, plates etc) for such usage as normal scope of work without any cost implication on BHEL.

In case of such misuse of BHEL materials, a sum as determined by BHEL engineer will be recovered from the contractor's bill. The decision of BHEL engineer is final and binding on the contractor.

- 10.5 All the works such as cleaning, levelling, aligning, trial assembly, dismantling of certain components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per general engineering practice and as per BHEL Engineer's instructions at site, cutting, weld depositing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scrapping, lapping, fitting-up etc., as may be applicable in such erection works and are necessary to complete the work satisfactorily, shall be carried out by the contractor as part of the work within the quoted rate. Major machining work, which is only to be carried out in workshops, will be arranged by BHEL.
- 10.6 The contractor will be responsible for the safe custody and proper accounting of all materials in connection with the work. If the contractor has drawn materials in excess of design requirements, recoveries will be effected for such excess drawls at the rate prescribed by manufacturing units.
- 10.7 No member of the already erected structure, platform, pipes, grills, other component and auxiliaries should be cut without specific approval of BHEL engineer. In case it is necessary to cut, the contractor shall rectify / repair in a manner acceptable to BHEL / customer without any additional cost.
- 10.8 No temporary supports shall be welded on the permanent structures, piping ducts & other components of piping. Welding of temporary supports, cleats, etc. on the permanent component shall be avoided. In case of absolute necessity contractor shall take prior approval from BHEL Engineer. Further, any cutting or alternation of member of the structure of platform or other equipment shall not be done without specific prior approval of BHEL Engineer.
- 10.9 Contractors shall ensure that all their Staff / Employees are exposed to periodical training programme conducted by qualified agencies / personnel on ISO 9001 latest Standards.
- 10.10 Contractor has to clear the front, expeditiously and promptly as instructed by BHEL Engineer for other agencies, like piping, Turbine, Generator erection, Cabling, instrumentation, insulation etc., to commence their work from / on the equipments coming under this scope. Sometimes, more than one agencies may have to work in same location. Sometimes it may be required to re-schedule the activities to enable other agencies to commence / continue the work so as to keep the overall project schedule.
- 10.11 The terminal points decided by BHEL are final and binding on the contractor for deciding the scope of work and effecting the payment for the work done up to the terminals.

- 10.12 For the purpose of planning, contractor shall furnish the estimated requirement of power (month wise) for execution of work in terms of maximum KW demand.
- 10.13 All necessary certificates and licenses, permits & clearances to carry out this work from the respective authorities/statutory/ local authorities/ are to be arranged by the Contractor at his cost in time to ensure smooth progress of work and render all assistance, service required in this regard.
- 10.14 All registration and statutory inspection fees, if any, in respect of his work pursuant to this Contract shall be to the account of the Contractor.
- 10.15 The contractor must obtain the signature and permission of the security personnel of the customer for bringing any of their materials inside the site premises. Without the Entry Gate Pass these materials will not be allowed to be taken outside.
- 10.16 Upon completion of daily work, the contractor shall remove from the vicinity of work all scrap packing materials, rubbish, unused and other materials and deposit them in places to be specified by BHEL Engineer.
- 10.17 During the course of erection, if the progress is found unsatisfactory, or if the target dates fixed from time to time for every milestone are to be advanced, or in the opinion of BHEL, if it is found that the skilled workmen like fitters, operators, technicians employed are not sufficient BHEL will induct required additional workmen to improve the progress and recover all charges incurred on this account including all expenses together with BHEL overheads from contractor's bills.
- 10.18 On completion of work, all the temporary buildings, structures, pipe lines, cables etc. shall be dismantled and levelled and debris shall be removed as per instructions of BHEL by the contractor at his cost. In the event of his failure to do so, the expenditure towards clearance of the same will be recovered from the contractor. The decision of BHEL Engineer in this regard is final.
- 10.19 The intent of specification is to provide services according to the most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for proper and efficient execution of this work shall not relieve the Contractor of the responsibility of providing such facilities to complete the work without any extra compensation.
- 10.20 The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The Contractor and his personnel shall cooperate with personnel of BHEL, BHEL'S Customer, Customer's consultants and other Contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work of the project as a whole.
- 10.21 Contractor shall erect and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL Engineer's decision regarding correctness of the work and method of working shall be final and binding on the Contractor. No claims for extra payment from the Contractor will be entertained on the ground of deviation from the methods / sequence adopted in erection of similar sets elsewhere.

- 10.22 The work shall confirm to dimensions and tolerances specified in the various drawings / documents that will be provided during various stages of erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations due to Contractor's fault, the Contractor shall dismantle and redo the work duly replacing the defective materials at his cost, failing which the work will be got done by BHEL and recoveries will be effected from the Contractor's bills towards expenditure incurred including cost of materials and departmental overheads of BHEL as per GCC.
- 10.23 The Contractor shall perform any services, tests etc. which may not be specified but nevertheless, required for the completion of work within quoted rates.
- 10.24 The Contractor shall execute the work in the most substantial and workman like manner. The stores shall be handled with care and diligence.
- 10.25 BHEL reserves right to recover from the Contractor any loss which arises out of undue delay / discrepancy / shortage / damage or any other causes due to Contractor's lapse during any stage of work. Any loss to BHEL due to Contractor's lapse shall have to be made good by the Contractor as per GCC.
- 10.26 All cranes, transport equipment, handling equipment, tools, tackles, fixtures, equipment, manpower, supervisors/engineers, consumables etc, except otherwise specified as BHEL scope of free issue, required for this scope of work shall be provided by the Contractor. All expenditure including taxes and incidentals in this connection will have to be borne by Contractor unless otherwise specified in the relevant clauses. The Contractor's quoted rates should be inclusive of all such contingencies.
- 10.27 During the course of erection, testing and commissioning certain rework / modification / rectification / repair / fabrication etc may become necessary on account of feedback / revision of drawing etc. This will also include modifications / re-works suggested by BHEL / customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repair etc promptly and expeditiously. Daily log sheets signed by BHEL engineer and indicating the details of work carried out, man-hours etc shall be maintained by the Contractor for such reworks. Claim of Contractor if any, for such works will be governed by relevant clauses of 'General Conditions of Contract'.
- 10.28 The Contractor shall take delivery of the components, equipments, chemicals, and lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL Engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipments after usage shall be submitted to the BHEL and reconciled periodically
- 10.29 There are few locations of storage yard within/beside plant premises. Major storage yard is located outside the Main Plant Boundary, in more than one location, at a distance of approximately 3-4 KM from the erection site.
- 10.30 Contractor shall plan and transport equipments, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the Contractor's shed and at work areas in an

- orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, same shall be done by Contractor most expeditiously as incidental to work. No claim for extra payment for such work will be entertained.
- 10.31 Plant materials should not be used for any temporary supports / scaffolding/ preparing pre-assembly bed etc. The details of equipments to be erected under this contract are generally as per the schedule given in relevant appendices. These details are approximate and meant only to give a general idea to the tenderer about the magnitude of the work involved. Actual quantum and type of equipments will be based on the relevant erection documents which will be furnished to the Contractor in due course of erection and the weight and quantity as per the relevant engineering documents will only be admissible for the billing purpose.
- 10.32 Hangers & suspensions, supports etc for tubes, piping, & ducts etc will be supplied in running / random lengths / sizes which shall be cut to suitable sizes and adjusted as required with in the quoted cost.
- 10.33 Spring suspension / constant load hangers may have to be pre-assembled for required load and erection carried out as per instructions of BHEL. Adjustments, removal of temporary arrests/locks, cutting of excess thread length of hanger tie-rod etc have to be carried out as and when required. Load setting of spring hangers, as per BHEL's documents/instructions, during various stages of erection & testing and after floating of piping/ducting during cold and hot condition will have to be done as part of work. This exercise may have to be repeated till satisfactory results are achieved.
- 10.34 Layout of field routed, fine fittings, piping, oil system and other small bore piping have to be routed according to site conditions and hence shall be done only in position as per the site requirement. As such, layout of small bore piping in ACC and oil system shall be done as per the site requirement. Necessary sketch for routing these lines shall be prepared and got approved from BHEL by the contractor. There is a possibility of slight change in routing the above pipelines when after completion, to suit the site conditions. The contractor should absorb this cost in his quoted rate.
- 10.35 Erection and Welding of necessary instrumentation tapping points, thermowell, thermocouple pad, metal temp pad and clamps, root valve, condensing vessel, flow metering & measurement devices, and control valves to be provided on piping are covered within the scope of this specification. The installation of all the above items will be Contractor's responsibility even if:
 - a) Items are not specifically indicated under the respective product groups as given in the technical specifications.
 - b) Items are supplied by an agency other than BHEL.
- 10.36 Pre-heating, NDE, and Post weld heat treatment for above shall be done as per the specifications as part of work.
- 10.37 Certain instrumentation like pressure switches, air sets, filters, regulators, pressure gauges, junction boxes, power cylinders, dial thermometers, flow meters, valve

- actuators, flow indicators, centrifugal/speed switches of motors, accumulators etc. are received in assembled condition as integral part of equipments. Contractor shall dismount such instruments for calibration and hand over the same to BHEL. C & I erection agency will do storage / re-erection calibration etc.
- 10.38 Fixing and seal welding of thermowells & plugs before Hydro test/ Steam dumping/ flushing of equipment or other piping system is within the scope of work. Contractor shall also remove the seal welded plugs by process of grinding and fix and seal weld thermowells after hydro test/steam dumping of lines as part of work.
- 10.39 Actuators/drives of valves, dampers, gates, powered vanes etc may have to be serviced, lubricated, before erection, during pre-commissioning & commissioning, including carrying out minor adjustments required as incidental to the work. Assistance for calibrating / testing the power cylinders / valves, gauges, instruments, etc. and setting to actuators coming under various groups shall be provided by contractor within the quoted rates.
- 10.40 All electrical motors have to be tested for IR & PI values prior to the trial run. Where required, dry out may have to be carried out by using external heating source. Contractor shall make all arrangements in this regard and complete the work as instructed. BHEL will provide the motorized insulation testers.
- 10.41 In installation of various equipments it may become necessary to install these on temporary supports/ hanger due to various reasons including non-availability of suspension materials. Contractor shall install such temporary suspensions/hangers and later on shift the relevant equipments to their respective permanent hangers/ suspensions/ supports as incidental to work. Requisite materials for such temporary arrangements will be provided by BHEL on free -returnable basis which shall be returned to BHEL after the use.
- 10.42 The work shall be carried out strictly in accordance to the "Field Quality Plan" approved by BHEL/client. Contractor, jointly with BHEL, shall prepare all necessary records of measurements/readings/ protocols etc.
- 10.43 Interconnection/ hookup, if any, with the existing system shall form part of work. Such interconnections, hookups may require shut down of running plant and the relevant work have to be completed within such planned shutdowns. This may call for working with enhanced resources and on extended hours. Contractor's offer shall cover all such contingencies.
- 10.44 Contractor shall regulate flow of material to and from site in such a manner and sequence that material accumulation at site does not lead to congestion at site. In case it is necessary to shift and restack the materials kept at work areas / site to enable other agencies to carry out their work or further any other reason, it shall be done by the Contractor most expeditiously. No claim for extra payment for such work will be entertained.
- 10.45 It may so happen that certain components like manhole doors, hanger etc may be supplied in loose items. They need to be assembled as per relevant drawings or as per advice of BHEL engineer prior to erection. This forms the part of the scope of work.
- 10.46 The Contractor shall have total responsibility for all equipment and materials in his custody at Contractor's stores, loose, semi-assembled, assembled or erected by him

- at site. He shall effectively protect the finished works from action of weather and from damages or defacement and shall also cover the finished parts immediately on completion of work as per BHEL engineer's instructions. The machine surfaces/finished surfaces should be greased and covered.
- 10.47 BHEL is operating web based computerized E-store system that includes, inter-alia, issue of materials, daily progress reporting, Contractor's running monthly billing and material reconciliation through a computerized data management system. Contractor shall install necessary hardware to hook-up with the BHEL's system and use the same for his scope of work.
- 10.48 In the event the computerized E-store/SOMS is inoperative for any reasons, the Contractor shall take delivery of materials from the storage area/sheds of BHEL/customer after getting the approval of the engineer/customer on standard indent forms to be specified by BHEL/customer. All these records however shall be updated in the E-store/SOMS as and when the E-store/SOMS is reactivated/normalized.
- 10.49 Gases like argon, oxygen, acetylene etc that are required for erection related activities shall be arranged by the Contractor at his cost.
- 10.50 All lubricants and chemicals required for testing, preservation, chemical cleaning / acid cleaning, oil flushing, and the lubricants for trial runs of the equipments and trial operation of the unit will be supplied by BHEL free of charges.
- 10.51 It is not the intent to specify herein all details of all material. Any item related this work not covered by this but necessary to complete the system will be deemed to have been included in the scope of the work.
- 10.52 Site testing wherever required shall be carried out for all items / materials installed by the contractor to ensure proper installation and functioning in accordance with drawings, specifications and manufacturer's recommendations.
- 10.53 The contractor shall carryout additional tests if any, which the Engineer feels necessary because of site conditions and also to meet system specification.
- 10.54 The work shall be executed under the usual conditions without affecting power plant construction / operation and in conjunction with other operations and contracting agencies at site. The contractor and his personnel shall co-operate with the personnel of other agencies, co-ordinate his work with others and proceed in a manner that shall not delay or hinder the progress of work as a whole.
- 10.55 All the work shall be carried out as per instructions of BHEL engineer. BHEL engineer's decision regarding the correctness of the work and method of working shall be final and binding on the contractor.
- 10.56 Wherever Construction sequences are furnished by BHEL, the contractor shall follow the same sequence.
- 10.57 Contractor shall, transport all materials to site and unload at site / working area for inspection and checking. All material handling equipment required shall be arranged by the contractor.
- 10.58 Contractor shall retain all T&P / Testing instrument / Material handling equipment's etc. at site as per advice of BHEL engineer and same shall be taken out from site only after getting the clearances from engineer in charge. The contractor at his cost shall

- arrange necessary security measures for adequate protection of his machinery, equipment, tools, materials etc. BHEL shall not be responsible for any loss or damage to the contractor's construction equipment and materials. The contractor may consult the Engineer-in-Charge on the arrangements made for general site security for protection of his machinery equipment tools etc.
- 10.59 Contractor shall remove all scrap materials periodically generated from his working area and collect the same at one place earmarked for the same. Load of scraps is to be shifted to a place earmarked by BHEL. Failure to collect the scrap is likely to lead to accidents and as such BHEL reserves the right to collect and remove the scrap at contractor's risk and cost if there is any failure on the part of contractor in this respect.
- 10.60 The contractor shall ensure that his premises are always kept clean and tidy to the extent possible. Any untidiness noted on the part of the contractor shall be brought to the attention of the contractor's site representative who shall take immediate action to clean the surroundings to the satisfaction of the Engineer in- Charge.
- 10.61 Completion of work, all the temporary buildings, structures, pipe lines, cable etc. shall be dismantled and levelled and debris shall be removed as per instruction of BHEL by the contractor at his cost. In the event of his failure to do so, the expenditure towards clearance of the same will be recovered from the contractor. The decision of BHEL Engineer in this regard is final.
- 10.62 It is the responsibility of the contractor to do the checking, testing etc. if necessary, repeatedly to satisfy BHEL Engineer with all the necessary tools and tackles, manpower etc. without any extra cost. The testing will be completed only when jointly certified so, by the BHEL Engineer.
- 10.63 The contractor's work shall not hinder other work, either underground or over ground, such as electrical, phone lines, water or sewage lines, etc. In areas of overlap, the contractor shall work in coordination with other related contractors.
- 10.64 Any damage by the landscape contractor's team to such utilities will be penalized and contractor shall be responsible for cost for such damages.
- 10.65 Contractor at his cost shall lay all necessary temporary piping including cutting and edge preparation, install the pumps, blanks, valves required for the test, pressure gauges etc. Required pipes, valves, plates etc., will be given by BHEL. Temporary piping, pumps, valves, flanges, blanks etc shall be removed by him and returned to BHEL. All thermo well points are to be seal welded, with plug in position. All Temperature Element points are to be provided with blanks and welded. Necessary blanks will be provided by BHEL.

10.66 SITE INSPECTION

10.66.1 The owner / employer or his authorized agents may inspect various stages of work during the currency of the contract awarded to him. The contractor shall make necessary arrangements for such inspection and carry out the rectification pointed out by the owner / employer without any extra cost to the owner / employer. No cost whatsoever such duplication of inspection of work be entertained.

- 10.66.2 BHEL / Customer will have full power and authority to inspect the works at any time, either on the site or at the contractor's premises. The contractor shall arrange every facility and assistance to carry out such inspection. On no account will the contractor be allowed to proceed with work of any type unless such work has been inspected and entries are made in the site inspection register by customer / BHEL.
- 10.66.3 Wherever the performance of work by the contractor is not satisfactory in respect of workmanship, deployment of sufficient labour or equipment, delay in execution of work or any other matter, BHEL shall have the right to engage labour at normal ruling rates and get the work executed through other agency and debit the cost to the contractor and the contractor shall have no right to claim compensation thereof. In such a case, BHEL shall have the right to utilize the materials and tools brought by the contractors for the same work

10.67 UTILITY POINTS

- 10.67.1 Number of utility points (Service / plant air, service / plant water, service / washing steam, inert gas (N2) etc., shall be indicated in the P & I diagram. Contractor to locate the utility points as advised by site engineer and shall route the piping to these points as per site conditions, and shall submit as built layout with 'BILL OF MATERIAL' to BHEL for approval.
- 10.67.2 The utility points shall be located at convenient point to handle and to be terminated with brass / bronze valve with suitable connection for hose pipe.

10.68 DOCUMENTATION

- 10.68.1 Contractor shall be supplied with two extra copies of the layout & isometrics drawings. Contractor to incorporate in one of the copy with Red ink all the changes / deviations / alterations etc. carried out at site due to various reasons, with site engineer's endorsement. Marked up drawings shall be submitted to BHEL for approval.
- 10.68.2 After successful completion, testing and commissioning of installation work, as built drawings / documents if any, in line with the actual work carried out as per site routing drawing shall be submitted by the contractor as agreed for the project.
- 10.68.3 The contractor shall maintain a record in the form as prescribed by BHEL for all operations carried out on each weld and maintain a record indicating the number of welds, the name of welders who welded the same, date and time of start and completion, preheat temperature, radiographic results, rejections if any, percentage of rejection, etc. and submit copies of the same to the BHEL Engineer as required.
- 10.68.4 Other documents as specified in of other Chapter of Technical Conditions of Contract.

10.69 AS BUILT DRAWING:

After successful completion, testing and commissioning of installation work, Purchaser's drawings / documents shall be updated in line with the actual work carried out and as built drawings / documents shall be submitted by the contractor as agreed for the project. Contractor shall be supplied with one extra copies of the

layout & isometrics drawings. Contractor to incorporate in one of the copy with red ink all the changes / deviations / alterations etc., Carried out at site due to various reasons, with site engineer's endorsement. Marked up drawings shall be submitted to BHEL for approval.

10.70 PLATFORMS, CROSSOVERS & CANOPIES

Platforms, ladders, crossovers and canopies shall also be provided at places where it has not been shown in drawings but if felt necessary by site engineer.

Contractor has to fabricate and install canopies for all outdoor pumps and motors, actuators, lub oil units, control valves and at places as instructed by BHEL Engineer etc. Platforms, ladders, crossovers and canopies shall have to be fabricated from raw materials supplied by BHEL and erected by contractor as per instruction of BHEL and shall be paid as per accepted tonnage rate for "GR-I"

10.71 Inspection, cleaning of tube bundles, platforms,

During erection, pre-commissioning, commissioning, operation, Stabilisation period trial Run - Inspection, cleaning of Tube bundles, platforms etc.

10.72 Statutory approval for Lifts, hoists, Cranes

Necessary approval for drawings, documents, Load Testing, license of hoists, EOT, lifts, Misc cranes erected by bidders has to be arranged for getting statutory fitness certificates, drawings/documents from Statutory agency/Third party inspectors without any extra commercial implication on BHEL treating as normal scope of work.

Contractor has to arrange sufficient manpower (fitters, electricians with supporting helpers) and T&P /other resources with sufficient testing instruments, IMTE/MMD for erection and commissioning of these systems without any extra commercial implication on BHEL treating as normal scope of work. D.S.L / equivalent system for hoisting equipments are also to be erected and commissioned within the quoted rates.

Weight/loads required for load test of hoists shall be provided by BHEL free of cost.

10.73 Support for Handing Over of T&P, spares to BHEL/Customer, diversion to other BHEL Sites/Units

Vendor will assist in handing over of Special T&Ps for Erection/commissioning which were issued to them free of charge for returning to BHEL /Customer store.

10.74 Dewatering

Dewatering of Low Lying areas within the designated working area like lift pits, ACC working areas, other low lying areas (as per scope applicability) till handing over to customer is in bidders scope for which vendor has to arrange and maintain adequate no. of Diesel & electrical pumps of suitable capacities, operators, necessary manpower with sufficient quantity of suction discharges hoses, pipes, Clamps, cables, Electrical

panels/starters, diesel, consumables without any extra commercial implication on BHEL treating as normal scope of work. Dewatering pumps will be required to run to ensure job progress is not hampered & if required pumps are to be run on round the clock basis on working days & holidays, Sundays.

10.75 Housekeeping/Area Cleaning

The contractor has to do area cleaning on every date on daily basis. Non-compliance of the above cleaning shall call for penal recovery of Rs.2,000.00 on each instance and at the same time, cleaning of the area shall be done by BHEL at the risk and cost of the contractor. No excuses on this above account shall be entertained by BHEL on whatsoever account.

Contractor shall engage separate gangs throughout the contract period, exclusively for proper housekeeping of the site. The contractor has to make necessary arrangements for collection and for bringing down the scrap from all locations and taking them away from the erection areas to various locations as indicated by BHEL Engineer. The house keeping must be a routine and continuous activity. in the various work fronts.

10.76 Approach platforms, fixtures

Steel items like angles, scaffoldings for erection of bracings, Tie beams are to be arranged by vendor for structural erection treating it as normal scope of work without any cost implication on BHEL.

10.77 Assistance during commissioning of panels, Equipment, system, actuators for valves (motor operated/pneumatic), gates, dampers

Agency has to give assistance for commissioning during initial period and subsequently during unit operation during stabilization period/trial run/PG Test. For this purpose, items erected by agency has to provide manpower, other resources, diesel, other consumables, scaffoldings, Other T&Ps as required from time to time. These types activities will be repetitive in natures for no. of times and in cases dismantling, reinstallation of items/parts has also to be done till handing over of unit to customer. During case of dismantling /reinstallation logistic supports like Tyre mounted crane/Crawler Crane/crane/truck/trailers as applicable including manpower are to be arranged by vendor. These types of activity is treated as vendor's normal scope of work without any extra commercial implication on BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XI: PROGRESS OF WORK

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

- 11.1 Refer forms F -14 to F-18 of volume I D (Forms & Procedure). Plan and review will be done as per the formats.
- 11.2 The progress reports shall indicate the progress achieved against plan, indicating reasons for delays, if any. The report shall also give remedial actions which the contractor intends to make good the slippage or lost time so that further works can proceed as per the original plan the slippages do not accumulate and affect the overall programme.
- 11.3 It is the responsibility of the contractor to provide all relevant information on a regular basis regarding progress of work, labour availability, equipment deployment, testing, etc.
- 11.4 Contractor is required to draw mutually agreed monthly work programs in consultation with BHEL well in advance. Contractor shall ensure achievement of agreed program and shall also timely arrange additional resources considered necessary at no extra cost to BHEL.
- 11.5 Progress review meetings will be held at site during which actual progress during the week vis-a-vis scheduled program shall be discussed for actions to be taken for achieving targets. Contractor shall also present the program for subsequent week. The contractor shall constantly update / revise his work program to meet the overall requirement. All quality problems shall also be discussed during above review meetings. Necessary preventive and corrective action shall be discussed and decided upon in such review meetings and shall be implemented by the contractor in time bound manner so as to eliminate the cause of nonconformities.
- 11.6 The contractor shall submit daily, weekly and monthly progress reports, manpower reports, materials reports, consumables (gases / electrodes) report, cranes availability report and other reports as per Performa considered necessary by the Engineer. The periodicity of the reports will be decided by BHEL Engineer at site.
- 11.7 The contractor shall submit weekly / fortnightly / monthly statement report regarding consumption of all consumables for cost analysis purposes.
- 11.8 The contractor shall submit a report of any damage, shortage, discrepancy etc., every week detailing in this regard.
- 11.9 The manpower reports shall clearly indicate the manpower deployed, category wise specifying also the activities in which they are engaged.
- 11.10 The monthly report as a booklet (PDF) shall be submitted at the end of every month and shall contain the following details:
 - a) Progress photographs in colour.
 - b) Erection progress in terms of tonnage, welding joints, radiography, stress relieving, etc., completed as relevant to the respective work areas against planned.
 - c) Site Organization chart of engineers & supervisors as on the last day of the month with further mobilization plan.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XI: PROGRESS OF WORK

- d) Category- wise man hours engaged during the previous month under the categories of fitters, welders, riggers, khalasis, grinder-men, gas cutters, electricians, crane operators and helpers. Data shall be split up under the work areas like Structure, Duct, Piping & rotary works.
- e) Consumables report giving consumption of all types of gases and electrodes during the previous month.
- f) Availability report of cranes.
- g) Safety implementation report in the format.
- h) Pending material and any other inputs required from BHEL for activities planned during the subsequent month.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XII: FOUNDATIONS & GROUTINGS

12 PREPARATION OF FOUNDATIONS, AND GROUTING OF EQUIPMENT OF ACC & AUXILIARIES

- 12.1 Building foundations and other necessary civil works for supporting structures, equipments etc will be provided by BHEL / Customer. The checking of dimensional accuracy, axes, elevation, levels etc, with reference to bench marks of foundations and anchor bolt pits have to be checked and logged by the Contractor. The permanent benchmark / reference marks will have to be transferred to new locations with sufficient care to maintain the accuracy and protected / preserved with adequate care (to enable rechecking at later dates) as per BHEL instruction.
- 12.2 Minor adjustment of foundation level, dressing and chipping of foundation surfaces and blue-matching (wherever required) for of all equipments as per BHEL Engineers instructions, should be done by the Contractor as part of the work. Contractor/BHEL shall prepare protocols before taking over the foundations. Dressing and chipping of foundations up-to **30 mm** for achieving proper levels will be within the scope of work/specification.
- 12.3 It shall be contractor's responsibility to check the various equipment foundations for their correctness with respect to level, orientation, dimensions etc., and ascertained dimensions shall be measured and submitted to BHEL for approval before erection. Foundation pockets are to be cleaned thoroughly before placing the supports / columns / equipments. Verticality of foundation bolts to be checked along with correctness of the threads and freeness of the nuts movement. If required cleaning of the threads to be done with proper dies.
- 12.4 The concrete foundation, surfaces shall be properly prepared by chipping, as required to bring the top of such foundation to the required level to provide the necessary roughness for bondage and to ensure enough bearing strength. All laitance and surface film shall be removed and cleaned and the packers placed with suitable mortar prior to erection of the equipment. Packer plates should not only be blue matched with foundation but also inter-packer contact surfaces between the packers and foundation frame etc., shall also be blue matched by Prussian Blue match checks and required percentage contact shall be achieved by chipping and scrapping as per BHEL Engineer's instructions.
- 12.5 All temporary foundations and anchor points required for installing erection Equipments and winches, foundations for pumps, tanks etc are in the scope of Contractor. All building materials like cement, steel including re-enforcement bars, grits cements etc for such temporary foundations shall have to be arranged by the Contractor within the quoted rates. All such foundations shall be demolished and normal ground conditions restored after the usage.
- 12.6 The surface of foundations shall be dressed to bring the surface of the foundations to the required level and smoothness prior to placement of equipments / equipments based on the foundations including shear lug provisions / openings.
- 12.7 BHEL will provide free of cost only the shims and packer plates (either machined or plain) which go as permanent part of the equipment. Certain packer plates and shims over and above the quantity received as a part of supplies from manufacturing units

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XII: FOUNDATIONS & GROUTINGS

- of BHEL will have to be cut out from steel plates / steel sheets at site to meet site requirement. Contractor shall cut and prepare packers and shims by gas cutting / chiseling / grinding and de-burr the same. However, machining of the packers wherever necessary, shall be arranged by contractor.
- 12.8 Complete grouting of structures equipments, including anchor/ foundation bolts, beneath base, base hollows etc, as may be applicable, is included in the scope of Contractor. Arranging all labour, building materials including cement, ordinary portland as well as quick setting free flow non-shrink grout mix (e.g. conbextra GP-I/GP-II), form work, shuttering, and any other requirements is in the Contractor's scope. Contractor shall obtain approval of BHEL for cement (Ordinary Portland aswell-as quick setting free flow- non-shrink grout mix) prior to use. Cleaning of foundation surfaces, pocket holes and anchor bolt pits and de-watering and making them free of oil, grease, sand and other foreign materials by soda washing, water washing, compressed air and other approved methods are within the scope of this specification/ work.
- 12.9 After the grouting has finally set and cured, alignment of equipments involved shall be checked again to verify for any disturbance or any other reason. If required, decoupling of equipments has to be done for conducting the verification. In case any disturbance is noticed the cause, if any, shall be removed and re-alignment done as part of work.
- 12.10 The concrete foundation, surfaces shall be properly prepared by chipping, as required to bring the top of such foundation to the required level to provide the necessary roughness for bondage and to ensure enough bearing strength. All laitance and surface film shall be removed and cleaned and the packers placed with suitable mortar prior to erection of the equipment. Packer plates should not only be blue matched with foundation but also inter-packer contact surfaces between the packers and foundation frame etc., shall also be blue matched by Prussian Blue match checks and required percentage contact shall be achieved by chipping and scrapping as per BHEL Engineer's instructions.
- 12.11 Total grouting of the columns / equipments including pocket grouting, grouting at the gap between foundation and base plates top surface of column / equipments is in the scope of the contractor. All the grouting should be carried out by non-shrink cement like Conbextra GP-I / Conbextra GP-II / Shrinkkomp or its equivalent etc. This special non-shrink cement shall be arranged by the contractor at his cost. The quoted rate shall be inclusive of the same.
- 12.12 All equipment bases and structural steel bases and foundations pockets shall be grouted and finished as per these specifications after surface preparation unless otherwise recommended by the equipment manufacturers. The surface preparation includes soda washing of the foundations to remove oil, grease etc. to ensure proper grouting.
- 12.13 The certificates of the grout are to be submitted to BHEL. If necessary test cubes are to be made and tested at site to ensure the quality of the grout as per relevant IS standards. In case grouting with Portland cement is approved, necessary cement, sand etc. to be arranged by the contractor including the fine aggregates.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XII: FOUNDATIONS & GROUTINGS

- 12.14 All the materials required for grouting including special cements as approved by BHEL and other materials like Portland cement, sand chips, gravel etc., are to be arranged by the contractor at his cost. It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding suppliers, type of grouting cements before procurement of grouting cements.
- 12.15 Certain packer plates and shims over and above the quantity received as part of supplies from manufacturing units of BHEL will have to be cut out from steel plates / sheets at site by the contractor to meet site requirement. However, machining of the packers, wherever necessary, will be arranged by BHEL at free of cost.
- 12.16 For pre-assembly of ACC components, necessary pre-assembly bed shall be constructed by the vendors. Concrete blocks required for preparing such pre-assembly bed shall be cast/brought by the vendor within his quoted price
- 12.17 **PROCEDURE FOR GROUTING:** Contractor has to carry out the grouting as per the work instructions for grouting available at site or the grouting is to be carried out as per the supplier's recommendation / IS standard. Copy of those recommendations is to be submitted to BHEL for records.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XIII: MATERIAL HANDLING, TRANSPORTATION AND SITE STORAGE

The scope of the work will comprise of but not limited to the following:

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

- 13.1 Loading at BHEL / Customer stores and storage yard, transport to site, unloading at site / working area of equipment, placement on respective foundation / location, fabrication yard, pre-assembly bay or at working area are in the scope of work. The scope includes taking materials / Equipments from customer stores / storage yard also. Contractors Quoted / Accepted rate shall be inclusive of the same. Required cranes, tractors, trailer or trucks/ slings/ tools and tackles / labour including operators, fuel, lubricants etc. for loading & unloading of materials will be in the scope of contractor.
- 13.2 The storage yard is located outside the Main Plant Boundary, in more than one location, at a distance of approximately 3-4 KM from the erection site.
- 13.3 Transportation of all items including ODC items from BHEL Store/Yard to Erection site shall be in the contractors scope. However, in some cases, consignments including ODC may be unloaded near erection site as per space availability and site requirements.
- 13.4 Loading at storage yard and transporting to site, unloading at site / pre assembly area or at working area, is in the scope of work. Required cranes for loading & unloading of materials, trailer shall be in the scope of contractor. The contractor shall provide any fixtures, concrete blocks & wooden sleepers, sandbags which are required for temporary supporting of the components at site.
- 13.5 The equipments / materials from the storage yard shall be moved in sequence to the actual site of erection / location at the appropriate time as per the direction of BHEL Engineer so as to avoid damage / loss of such equipment at site.
- 13.6 Contractor shall plan and transport equipments, components from storage yard to erection site in such a manner and sequence that material accumulation at site does not lead to congestion at site of work.
- 13.7 The contractor shall satisfy himself of the quality and quantity of the materials at the time of taking delivery from BHEL stores. No claims whatsoever will be entertained by BHEL because of quality or quantity after the materials are taken by the contractor from BHEL stores.
- 13.8 Sometimes it may become necessary for the contractor to handle certain unrequited components in order to take out the required materials. The contractor has to take this contingency also into account. No extra payment is payable for such contingencies.
- 13.9 Contractor shall plan and transport equipments, components from storage yard to erection site in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. However, in specific cases "as a special case to expedite the job" the consignment received at BHEL stores can directly be diverted to the work site, as decided by BHEL, following issuance procedure of BHEL. Such

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XIII: MATERIAL HANDLING, TRANSPORTATION AND SITE STORAGE

- direct issues shall be as per the Challan/dispatch document/LR received with the consignment. In such cases, contractor shall do unloading of materials from trucks/lorry at their own cost.
- 13.10 All materials issued by BHEL shall be stacked neatly, preserved, stored in the contractor's shed / work area above ground level by use of concrete or wooden sleepers. No materials shall remain on ground at any time. All concrete or wooden sleepers required for stacking the materials shall be arranged by contractor at his own cost within the quoted rates. In case it is necessary to shift and re-stack the materials kept at work area / site to enable other agencies to carry out their work, same shall be done by the contractor at no extra cost.
- 13.11 All pipe and tube ends shall be covered with plastic caps or will be closed with wooden plugs as the case may be.
- 13.12 The contractor shall take care of material issued by BHEL and shall protect the same from damage and weathering. The contractor shall take necessary measures to see that all the machined surfaces are preserved and covered. Contractor has to arrange required fire proof tarpaulins to protect the machined components / assembled parts drawn from BHEL store before and after erection as required at their cost.
- 13.13 The contractor shall take all such measures as may be reasonably necessary to ensure that its arrangements and those of its sub-contractors with respect to the transport of Goods, Materials and Labour to the site do not interfere with local traffic in the vicinity of the site and where such interference is unavoidable shall make such special arrangements as may be reasonably required to minimize the effect of such interference.
- 13.14 The contractor shall take all such measures as may be reasonably necessary to ensure that its arrangements and those of its sub-contractors with respect to the transport of Goods, Materials and Labour to the site do not interfere with local traffic in the vicinity of the site and where such interference is unavoidable shall make such special arrangements as may be reasonably required to minimize the effect of such interference.
- 13.15 The contractor shall in no case be entitled for any compensation on account of any delay in supply or non-supply thereof for all or any such materials. However in case of non-availability of any specific materials which delays the completion of work, such cases shall be recorded separately in monthly planning format (F 14) and shall be considered for time extension of contract.
- 13.16 The contractor shall solely be responsible for the safety & security of material after it is handed over and issued to contractor by the BHEL. BHEL reserves the right to recover from the contractor any loss arising out of damage/ theft or any other causes or during verification/stacking or at any time under the custody of the contractor.
- 13.17 Contractor shall also carryout in complete association with BHEL, the material management functions and execution like day-to-day update of materials, issued to contractor, accounting for surplus/scrap material returned etc. These functions shall also be carried out through computerized system utilizing suitable software.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XIII: MATERIAL HANDLING, TRANSPORTATION AND SITE STORAGE

- Contractor shall engage experienced software personnel to associate on dedicated basis for efficient discharge of the same in time.
- 13.18 Open land for storage purposes shall be provided by BHEL on free of cost/as available basis. Temporary barbed wire fencing, as required, of the open storage yard is to be done by the contractor and is included under the scope of his work. Contractor shall also remove grass, bushes, trees etc wherever required off the land provided to him and shall make proper continuous up keeping of the open yard /land by removing grass, bushes trees etc and same is included under the scope of his work & No extra payment shall be made to the contractor in this regard. The bidder shall make complete arrangement of necessary security personnel's to safeguard all such materials in his custody. The contractor shall take care of material issued by BHEL and shall protect the same from theft, damage and weathering. In case, loss of any materials for whatsoever reasons attributable to the contractor, then cost of such materials shall be recovered from the running bill payment with applicable overheads.
- 13.19 All surplus materials shall be returned to BHEL store. All wastage / scrap (including melting scrap, wastage, and unusable scrap) shall be returned to the stores on weighment basis in consultation with BHEL Engineer and a receipt obtained for material accounting purposes. Scrap materials shall be sorted section-wise and returned separately at a place directed by BHEL Engineer within the project area. Return of such materials will not be entitled for any handling and incidental charges.

The scope of the work will comprise of but not limited to the following:

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

14.1 Erection

- 14.1.1 The contractor will have to follow the instructions provided in the technical manuals, drawings, and specifications provided by BHEL, to the contractor from time to time. In case of ambiguity or deviation the decision/clarification of BHEL engineer will have to be followed.
- 14.1.2 In case of any class of work for which there is no such specifications as laid down in the contract such as blue matching, welding of stainless steel parts etc., the work shall be carried out in accordance with instructions and requirements of the BHEL engineer at the quoted rates only.
- 14.1.3 The contractor is strictly prohibited in using any of permanent members' components like angles, channels, hand-rails for any temporary supporting or scaffolding work. In case of such misuse, a sum as determined by BHEL shall be recovered from contractor's bills. Also the contractor will be responsible for the safe custody and proper accounting of all materials in connection with the work. If the contractor has drawn materials in excess of design requirements, recoveries will be effected for such excess drawls at the rate prescribed by manufacturing units.
- 14.1.4 Any fixtures, scaffolding materials, approach ladders, concrete block supports, steel structures required for temporary supporting, pre assembly, checking, welding, lifting & handling during pre-assembly and erection shall be arranged by the contractor at his cost.
- 14.1.5 The temporary structures/ items welded to permanent members/pipes are to be cut and removed without any damage. Any damage so to permanent members/ pipes to be made good by the contractor at his cost.
- 14.1.6 In the case of structural members / ducts in certain cases, the raw material will be supplied in random lengths and the contractor will have to make up the length / prepare the edges to suit the matching profiles, weld / bolt connects the joints at no extra cost.
- 14.1.7 All welded joints should be painted with anti-corrosive paint, once NDE works are over.
 - 14.1.8 All welded joints shall be subjected to acceptance by BHEL Engineer.
 - 14.1.9 Work such as minor rectification of foundation bolts, reaming of holes, drilling of dowels, matching of bolts and nuts, making new dowel pin, etc. are covered in the scope of work.
 - 14.1.10 All piping items including pipes, valves, flanges, fittings etc. shall be supplied as commercially available. Hence Fit-ups, edge preparation including welding of

- stubs, shall be included in the contractor's scope. No separate payment will be made for the edge preparation of pipes, Standard fittings such as bends, Tees etc
- 14.1.11 Pipes above 2" diameter have to be cleaned by means of wire brush as per the instruction of BHEL Engineer and subsequently flushed with air before lifting them into position. For pipes below 2" diameter, shall be sponge cleaned with air flushing. After cleaning is over, the end caps shall be put back in tube openings till such time they are welded to other tubes. Required compressors shall be arranged by the contractor at his cost.
- 14.1.12 In case of piping connected to equipment, matching of flanges for achieving the parallelism and alignment at equipment end by suitably resorting to heat correction or other method as instructed by BHEL Engineer is within scope of work.
- 14.1.13 Wherever elbows of 45 deg. or any other angle are required, the same shall be cut from 90 deg. elbow supplied and used as per BHEL engineer instruction. No extra cost shall be paid.
- 14.1.14 Erection of flow switches, filters, flow meters, other metering elements, flow orifices, flow indicators, control valves supplied either by BHEL or customer forming part of the system is in the scope of work. This will include collecting from BHEL/Customer stores, transportation to site, suitably cutting the erected piping, cleaning, erection, welding, radiography and stress relieving and commissioning.
- 14.1.15 Contractor shall also weld small length of piping with root valve to the pressure, flow and level tapping points on piping or flow nozzles/orifices/ metering elements fixed on piping as per the instructions of BHEL Engineer.
- 14.1.16 Welding of all thermo wells, draft, pressure and temperature instrumentation points and all other instrumentation points on piping and auxiliaries and welding of thermocouple pads for permanent system as well as for performance guarantee test is in the scope of work.
- 14.1.17 Plate / Pipe shoes for piping supports shall be fabricated at site by the contractor at no extra cost. Other supports namely Hangers, U-clamps etc., shall be supplied by BHEL duly bent and threaded. Assembly and necessary cutting work etc., shall be carried out at site by contractor within the quoted rate.
- 14.1.18 Wherever hanger and support materials are not received from manufacturing unit in time to suit the erection schedule, contractor shall erect the system on temporary supports to ensure the progress of work. The required structural steel materials will be issued on free of charges by BHEL, either from scrap/spare materials. The same shall be removed and returned to BHEL store after erection of permanent supports.
- 14.1.19 Contractor has to carryout fabrication works such as welding of stubs / nipples, attachments etc., preparation of surface for rust preventive coating and application of rust preventive is within the quoted / accepted rate.

- 14.1.20 All the equipments /material to be taken inside the plant building shall be cleaned thoroughly before taking them inside. The contractor shall clean, wherever necessary and paint inside surfaces of the equipments like coolers, oil tanks, Rubber expansion joints and other components as per instruction of BHEL Engineer during erection within the quoted rate.
- 14.1.21 Contractor shall cut / open works, if needed, as per BHEL Engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over. This contingency shall be included within the quoted value. During commissioning, opening of valves, changing of gaskets, attending to leakages, minor modification, and rectification works may arise. The contractor has to carry out these works at his cost by providing required manpower with T & Ps in all the three shifts. In case any rework is required because of contractor's faulty erection and which is noticed during commissioning, the same has to be rectified by the contractor at his cost.
- 14.1.22 Contractor shall engage separate gangs throughout the contract period, exclusively for proper housekeeping of the site. The contractor has to make necessary arrangements for collection and for bringing down the scrap from all locations and taking them away from the erection areas to various locations as indicated by BHEL Engineer. The house keeping must be a routine and continuous activity.
- 14.1.23 Prior to erection of any components inspection to be done for any foreign materials and damages and they are to be removed / attended as per BHEL engineer.
- 14.1.24 Field Quality Assurance Formats:-It is the responsibility of the contractor to collect and fill up the relevant FQA log sheets of BHEL and present the same to BHEL after carrying out the necessary checks as per the log sheets and obtaining the signature of BHEL and customer as token of their acceptance. Payment to the contractor will be linked with the submission of these FQA log sheets.
- 14.1.25 All test requires as per FQP (Field Quality Plan) will be in bidder's scope. Tentative FQP for erection is attached **Annexure-4**.

14.2 ERECTION OF ACC STRUCTURES AND ROTATING MACHINES

- 14.2.1 Brief list of System / sub-system to be erected by the contractor & approximate weight of individual "GR type" mentioned in this Tender Specification are meant for giving general idea to the tenderer only about magnitude of the work involved. This should not be taken for billing or any other claims. All weights for such purposes will have to be taken from design documents only (shipping list). This section also gives general idea about various components to be erected with expected accuracy level. However, the contractor shall get the correct details from the engineer to avoid mistakes and rework.
- 14.2.2 Preparation of preassembly bed is very much essential for preassembly of structures, pipes. modules etc. on consolidated ground and to avoid sagging and

- shrinking the temporary supports are to be provided. The preassembled component should have minimum three supports to avoid sagging.
- 14.2.3 The structures members are to be measured individually to check for camber, sweep etc. The level markings to be checked before erection.
- 14.2.4 The following measuring and test equipments with proper calibration certificates are to be made available by the contractor before taking up the structural and other pressure parts erection. Steel tapes minimum 5M,30M in sufficient numbers, torque wrench 650-1000 ft pounds, bolt tension calibrator, torque wrench with calibration, temperature recorder, two theodolites with one second accuracy etc. Periodic calibration of the measuring instruments is to be done once in six months and certificate for the same to be submitted to BHEL for records.
- 14.2.5 The tightening procedures for HSFG bolts are to be obtained from BHEL at site before taking up the work. Normally it is done by turn of nut method. Torque wrenches also can be used. The bolted joints will be checked jointly by BHEL/Customer engineers for required tightness and retightening is to be done as per requirement. The tightened bolts will be marked with colour paints. Facility for random checking by torque wrench will have to be done. The required calibrated torque wrench will be provided by the contractor.
- 14.2.6 Some platform materials, approach ladders, suspension materials etc. will be supplied in running meters. The contractor has to fabricate these materials wherever they are supplied in running meters to the required size / shape, to be welded and erect them within the quoted rates.
- 14.2.7 All normal erection and assembly techniques necessary for completion of works under this specification and magnitude have to be carried out. It is not possible to specifically list out all of them. Absence of any specific reference will not absolve the contractor of his responsibility for the particular operation. These would include
 - a) Machine / flame / electric cutting, grinding, welding, radiography and stress relieving.
 - b) Fitting, fettling, filing, straightening, chamfering chipping, scrapping, reaming, cleaning, checking, levelling, blue matching, aligning and assembly.
 - c) Machining, surface grinding, drilling, doweling, shaping.
 - d) Temporary erections for alignment, dismantling of certain equipment for checking, cleaning, servicing and site fabrication.
- 14.2.8 Certain adjustments in length of steel /pipe/tube members may be necessary while erecting pipelines and the contractor should remove the extra lengths to suit the final layout after preparing edges afresh and adopting specified heat treatment procedures at no extra cost, wherever indicated. Depending upon the type of deviation BHEL will consider the reimbursement at man hour rates. If the drawing provides for erection allowance, then it becomes part of the work and no compensation is payable. The prepared edges in pressure parts shall be applied with wieldable primer as preservation and supply of the primer is in contractor scope.
- 14.2.9 Ducts / expansion pieces are dispatched to site in loose walls / plates and these are to be assembled at site before erection.(Walls with stiffeners in

welded condition will be provided).

- 14.2.10 All the dampers, valves, lifting equipments, power cylinders, etc., shall be serviced and lubricated to the satisfaction of BHEL engineer before erecting the same and also during pre-commissioning. The bearings of dampers shall be properly cleaned, serviced and lubricated before commissioning at no extra cost. Even after commissioning, if there are problems in the operation they have to be attended by the contractor during the tenure of the contract.
- 14.2.11 Spring suspensions / constant load hangers have to be pre-assembled and adjusted for the required loading and erected as per instructions, of BHEL Engineer. Any adjustments, removal of temporary arrestors / lockers, etc., have to be carried out as and when required at no extra cost to BHEL.
- 14.2.12 No temporary supports shall be welded on the ACC Components. In case of absolute necessity contractor shall take prior approval from BHEL Engineer. Further, any cutting or alternation of member of the structure of platform or other equipment shall not be done without specific prior approval of BHEL Engineer.
- 14.2.13 The contractor shall fabricate piping, install lube oil systems and carry out the acid cleaning of fabricated piping. The contractor shall also service the lube oil system, carry out the hydraulic test of oil coolers. etc.
- 14.2.14 All hangers, supports and anchors (including concreting or welding) shall be installed as per drawing to obtain a reliable and complete pipe installation as per instructions of BHEL Engineer. Normally supports are issued in running meters. Any additional supports as called for by BHEL Engineer shall be fabricated by the contractor and provided at no extra cost. However, the raw material required for fabrication of such supports shall be supplied by BHEL free of cost. (Any machining or threading is involved will only be done by BHEL).
- 14.2.15 Normally the high pressure valves will have prepared edges for welding. But if it becomes necessary the contractor shall prepare new edges or recondition the edges by grinding or chamfering to match the corresponding tubes and pipes. All fittings like "T" pieces, weld neck flanges, reducers etc., shall be suitably matched with pipes for welding. Edge preparation becomes the part of erection work. No extra payment shall be made for this.
- 14.2.16 All valves will have to be checked, cleaned, lapped or overhauled in full or in part before erection, after chemical cleaning and during commissioning as may be necessary. After the chemical cleaning has been successfully completed, removing all temporary piping, fittings of tanks etc. checking all the valves for any accumulation of foreign materials, welding the valves, pipes which were cut and cleaning, over hauling, re-fixing as per BHEL Engineer's instructions is within the scope of work/specification. The contractor, at his own cost, shall arrange experienced technicians for the above work, including required consumables.
- 14.2.17 Adjustments like removal of ovalities in pipes and opening or closing the fabricated bends of all piping including high pressure piping to suit the layout shall be considered part of work and the contractor is required to carry out such work free of cost, as per instructions of BHEL, which shall include specific heat treatment procedures etc..
- 14.2.18 Pipes are sent in standard length and will be cut to suit the site conditions and the

layouts. Tubes or pipes wherever deemed to be convenient will be sent in running lengths with sufficient bends. Bends up to NB 65 mm will have to be fabricated at site adopting specified heat treatment procedures, wherever required at no extra cost. Only cold cutting methods are to be employed for cutting of pipes and tubes irrespective of the size and material. Gas Cutting, if any, will be allowed only in CS LP piping as per instruction of BHEL Engineer.

- 14.2.19 All attachment welding including those for insulation and refractory work coming on the piping, ducts shall have to be done by the contractor. The hooks are suitable for stud welding machines. Contractor's quoted rate shall include all these contingencies. Attachment welding on pressure parts shall be done by qualified and certified welders only. Welding of Insulation hooks at site shall be welded on the fins by manual welding / stud welding machines.
- 14.2.20 It is the responsibility of the contractor to do the alignment, checking, etc., if necessary, repeatedly to satisfy BHEL Engineer / customer Engineers with all the necessary tools and tackles manpower, etc., without any extra cost. The alignment will be complete only when jointly certified so, by the BHEL Engineer & customer. Also the contractor should ensure that the alignment is not disturbed afterwards.
- 14.2.21 Fine fittings, small bore piping have to be routed according to site conditions and hence shall be done only in position. As such, layout of small bore piping in ACC and oil system shall be done as per the site requirement. Necessary sketch for routing these lines should be got approved from BHEL by the contractor. There is a possibility of slight change in routing the above pipelines when after completion, to suit the site conditions. The contractor should absorb this cost in his quoted rate.
- 14.2.22 Additional platforms for approaching different equipments as per the site requirement, which may not be indicated in drawings, shall be assembled and erected by contractor. However, the contractor shall be paid for this work on accepted tonnage rate for erection of GR-I. The steel materials required for these works shall be supplied by BHEL free of cost and the contractor will have to install them to suit the requirement. Works of major nature not covered under this clause.
- 14.2.23 Certain extra lengths of various tubes/pipes and fabricated ducts are provided as erection allowance and the same have to be cut/adjusted to suit the site conditions and layouts or certain small lengths may have to be added for adjustments to suit the site conditions. For any mismatch while matching the joints in tubes, the cutting, adjusting, re welding, addition spool pieces should be done by the contractor to match site conditions without any extra payment.
- 14.2.24 Assistance for calibrating / testing the power cylinders / valves, gauges, instruments, etc. and setting to actuators coming under various groups shall be provided by contractor within the quoted rates.
- 14.2.25 For all the site routed piping as built drawings are to be submitted by the contractor immediately after erection.
- 14.2.26 **Heavy component lifting:** Before lifting the heavy components like Tube bundles, manifolds, fans, structures assemblies, etc. soft materials like gunny bags to be used while lashing the rope to avoid dents, rubbing marks etc. The capacity,

- number of sheave pulleys, size of the rope, guide pulley locations are to be decided at site with respect to the capacity and positioning of the winch. The end caps provided at shop for various stubs are to be removed during final fit up only.
- 14.2.27 The required accuracy level to be ensured before welding as per drawing. Necessary radiography/NDT along with heat treatment to be done.
- 14.2.28 All the drain lines should have sufficient slope towards drain. Provide expansion loops in all the vents and drains as per the drawings. All the motor operated valve stems should be vertical preferably. All the valve packing with asbestos base to be lubricated once in 6 months till handing over. Necessary gland packing will be supplied by BHEL.
- 14.2.29 All Rotating machineries and equipment shall be cleaned, lubricated, checked for their smooth rotation, if necessary dismantling and refitting before erection. If in the opinion of BHEL Engineer, the equipment is to be checked for clearance, tolerance at any stage of work or during commissioning period, all such works are to be carried out by contractor at his cost.
- 14.2.30 The fans shall be checked for blade clearance and other vital tolerances. Necessary assistance for trial of equipment during trial run shall be provided by the contractor.
- 14.2.31 Vital clearance of mill should be checked at site and adjusted if required.
- 14.2.32 D.S.L / equivalent system for hoisting equipments are also to be erected and commissioned including load testing by the contractor within the quoted rates. Required manpower including electricians is to be arranged by the contractor for carrying out commissioning of electrical hoist and load testing of the above electrical hoist. Required loads will be provided by BHEL free of cost.
- 14.2.33 The contractor shall take all reasonable care to protect the materials and equipment during erection. Touch up painting required to be done on any equipment or part during the course of erection will have to be done by the contractor.
- 14.2.34 All the bearings, gearboxes etc., of the equipment / actuators and electrical motors to be erected are provided with protective greases only. Contractor shall arrange as and when required by the engineer for cleaning the bearing / gear boxes etc., with kerosene or some other agent if necessary by dismantling some of the parts of the equipment during erection and shall arrange for re-greasing / lubricating them with recommended lubricants and assembling back. Lubricants will however be supplied by BHEL at free of cost.
- 14.2.35 The actuators / motors of valves may be supplied in loose parts, contractor shall have to match / assemble and align at site as per instructions BHEL Engineer including placement on foundation.
- 14.3 MAIN SUPPORTING STRUCTURES, EXTERNAL STRUCTURES, ELEVATOR STRUCTURES, STAIRWAYS, GALLERIES & PLATFORMS & HANDLING ARRANGEMENT
- 14.3.1 In some cases, the structural material will be supplied in random lengths, which have to be fabricated to suit the requirement as incidental to work. Also, it may sometimes be necessary to remove some of the erected members to facilitate

- erection of bigger/ pre-assembled equipments. In such cases, the removal and reerection of such members as agreed by the BHEL Engineer, will have to be done by the Contractor as incidental to work.
- 14.3.2 Contractor shall arrange materials required for temporary cat ladders & working platforms during erection of support structures platforms and other structural components. Such arrangements shall, as far as possible, be only of clamping & bolting type, as welding on columns etc will not be permitted. After the completion of work these shall be removed.
- 14.3.3 All the hand rails and toe guards shall be provided as per drawings and site requirement. hand rails supplied in running lengths shall be suitably cut, edge prepared and welded. Also, hand rails/ guards may have to be provided from the safety point of view in certain places though not indicated in the erection drawings. The weld joints of hand rails shall be ground smooth to flush finish.
- 14.3.4 Electro forged floor grills will be supplied for this project. These may have to be cut to suit requirement. Cutting shall be done only by mechanical cutters **and not by gas cutting**. Cold galvanizing compound is to be applied on the cut surface/edge. Cold galvanizing paint supply is in Contractor scope.
- 14.3.5 Fixing of floor grills shall be done by self-tapping screws **and not by weldable studs.** Special purpose electrically operated hand tools are available in the market for this, which drills, taps and fixes the screws in a single operation. Supply of necessary self-drilling-cum-tapping screws and fixing clips are in contractor scope. Contractor shall deploy the **drilling cum fixing machine** required for this purpose as a regular scope of work.
- 14.3.6 The Contractor shall also install additional platforms of permanent nature for approaching different equipment as per the site requirement and to meet 0&M requirements, though these may not have indicated in the erection drawings. Materials required for such platforms will be supplied by BHEL in random sizes on free issue basis. These have to be fabricated to suit the requirement. Payment only for erected weight as certified by BHEL engineer shall be made at the rate applicable for structures. All relevant provisions as above shall apply, mutatismutandis, to the work of external structures, interconnecting structures, elevator structures & equipment handling system etc.
- **14.4 Piping/Ducting**: The piping components are sent in parts for convenient transportation / layout requirements. They are to be cleaned, pre-assembled in stage by stage, welded, erected and aligned as per the drawing dimensions / tolerance and instructions of BHEL Engineers.
- 14.4.1 The work on piping systems (air, water, oil, steam, gas etc.,) will include laying, edge preparation, fixing and welding of the elbows / fittings / valves etc., welded on the lines, fixing and adjustment of supports / hangers / shock absorbers and carrying out all other activities / works to complete the erection and also carrying out all pre-commissioning / commissioning operations mentioned in the specification as per BHEL Engineer's instructions and / or as per approved drawings / documents.

- 14.4.2 Pre Assembly joints to be marked in isometrics drawings in consultation with BHEL Engineers and submit to BHEL before starting work. Contractor to maintain Line History sheet (LHS) of all Pipe lines as per BHEL Format and submit before HT to BHEL/Customer for getting HT Clearance.
- 14.4.3 Erection of all drains / vents / relief / escape / safety valve, piping to various tanks/ sewage / drain canal / flash box / flash tank / condenser / sump / atmosphere etc. from the stubs on the piping to the equipments erected by the contractor is completely covered in the scope of work.
- 14.4.4 Contractor has to carryout fabrication works such as welding of stubs / nipples, attachments etc., preparation of surface for rust preventive coating and application of rust preventive within the quoted / accepted rate.
- 14.4.5 Pipes shall not be dropped to avoid impact or bump.
- 14.4.6 The scope of work includes marking of labelling & flow direction on the piping over insulation/other parts at the one place or number of places as instructed by BHEL Engineer. All consumable required for this work shall be in the scope of contractor.
- 14.4.7 Normally weld neck valves will have prepared edges for welding. But if it becomes necessary the contractor shall prepare new edges or recondition the edges by grinding or chamfering to match the corresponding tubes and pipes. All fittings like tees, weld neck flanges, reducers, elbows, flanges, inserts etc., shall be suitably edge prepared and matched with pipes for welding. No extra cost shall be paid for this.
- 14.4.8 In case of any class of work for which there is no such specifications as laid down in the contract such us blue matching, welding of stainless steel parts etc., the work shall be carried out in accordance with instructions and requirements of the BHEL engineer at the quoted rates only.
- 14.4.9 Erection of platform and supporting structures around the equipments / valves / filters etc., is covered in the scope of contract and shall be erected by the contractor as per accepted tonnage rate for structure.
- 14.4.10 The Contractor shall carry out the reaming and honing of coupling holes with his own reamers, honing machine and honing accessories etc at his own cost.
- 14.4.11 Wherever pipes / bends / equipments are supplied in pre-fabricated / assembled packages, there may be necessity to make minor changes, including strengthening by additional welds. This shall be treated as part of the contractor's scope.
- 14.4.12 All the oil & gas piping flanges, wherever provided are to be blue matched using surface plates for at least 80% contact area to attain leak proof of joints, as per the instruction of BHEL Engineer.
- 14.4.13 All piping supplied in running meter has to cut and edge prepare as per the standards / drawings and as per the instruction of BHEL Engineer within the quoted rate.
- 14.4.14 Wherever drawings indicate site routing and site fabrication, such pipes (in general equal to and less than 2" dia) will be issued in running meters as straight length. These are to be cut and edge prepared at site to required length to suit layout as given in the erection drawing. In some cases attachments like lugs, stoppers, cleats etc., will be supplied as loose items and to be cut and welded to the pipes at site as per erection drawing necessary drilling of holes on main pipe for welding stubs shall also be done at site by the contractor.

- 14.4.15 Fittings like bends, tees, elbow, mitre bends, reducers, flanges, thruster blocks, etc., will be supplied as loose items and edge preparation if required shall be carried out by the contractor.
- 14.4.16 Certain adjustments in length may be necessary while erecting pipelines. Removing / adding extra lengths / to suit the final layout, preparing edges afresh and adopting specified heat treatment procedure are in the scope of work.
- 14.4.17 For pipes nominal size 2" and below routing shall not be shown in piping layouts or in isometrics and the same to be routed / connected as shown in schematics. For the above sizes if the routing is shown in layouts it is only for guidance and the same shall be routed and supported as per site requirement / convenience as per BHEL Engineer's advice.
- 14.4.18 Piping below size 2", valves, flanges, fittings etc. shall be supplied as commercially available. Hence fit-ups, edge preparation including welding of stubs, shall be included in the contractor's scope.
- 14.4.19 Contractor should fabricate bends of </=2|| diameter size at site from running meters of piping for the above and cut, edge prepare and lay the piping as per BHEL Engineer's instructions.
- 14.4.20 Minor adjustment like removal of ovalities in pipes and opening or closing of the fabricated bends by process of heat correction or any other method approved by BHEL Engineer to suit the layout, with specified heat treatment procedure shall be carried out by the contractor within the quoted rate.
- 14.4.21 Contractor shall use only bolted clamps for achieving alignment of piping. Wherever "L" shaped stoppers and wedges are to be used for aligning piping and equipments, the same shall be subject to the approval of BHEL Engineer. Contractor shall remove the bridge, stopper etc., by grinding / gouging and not by hammering. Any burrs left on the equipments / piping, after welding, shall be ground off or any scar or cavity made good by welding and grinding. NDT tests shall be carried out if necessary to detect surface and sub-surface cracks in these ground areas.
- 14.4.22 The surface of the pipes to be joined shall be suitably prepared as per instructions of BHEL Engineers. Edge preparation shall be done by chamfering machine, whenever required and all welding surfaces must be cleaned thoroughly. All works due to the mistake of the contractor shall be repaired / redone at contractor's cost. Instrumentation drains, stubs which are sent in loose from manufacturing units are to be welded at site as per BHEL Engineer's instructions.
- 14.4.23 All the weld joints on equipments and piping shall be ground or filed after completion of welding and before radiography as per instructions of BHEL Engineer so as to achieve smooth surface to avoid of ripples, undulations etc.,
- 14.4.24 Flow nozzles, orifice, spray nozzles etc., shall be mounted / erected after chemical cleaning / flushing / or steam blowing at site.
- 14.4.25 Erection of Flow nozzles, flow switches, steam traps, filters, flow meters, other metering elements, spray nozzles, steam traps, flow orifices, flow indicators, control valves, aux. control valves, NRVs, suction strainers, servomotors, etc forming part of the system (under this scope of work) irrespective of the suppliers is also to be carried out by the agency without any extra cost after chemical and /

- or steam blowing / oil flushing at site. This will include collecting from BHEL / Customer stores, transport to site, suitably cutting the erected piping, cleaning, erection, welding, radiography and stress relieving and commissioning.
- 14.4.26 Certain instruments like pressure switches, gauges, air sets, regulators, filters, junction boxes, power cylinders, dial gauges, thermometers, flow meters, valve actuators, flow indicators etc., are received in assembled conditions as integral part of equipments. Contractor shall dismount such instruments and re-erect whenever required prior to commissioning. Sometime this may have to be handed over to store or instrumentation contractor.
- 14.4.27 Fixing, fitting, welding of thermo wells, stubs, hoses, tapping points, root valves and instruments etc., on different lines / equipments (which will be supplied by BHEL) is within the scope of work. Fixing of Pick-Ups, Probes & Accessories for vibration monitoring system for the erected equipments / pipe lines is the scope of this specification.
- 14.4.28 The contractor shall also weld all thermo wells, small length of pipes to all pressure, flow and level tapping points, isolating valves and root valves on all equipment under scope of erection of this contract. All embedded temperature measuring elements provided in the bearings will have to be terminated at the junction box by the contractor. Thermo wells tapping point connections incorporated shall be plugged during the pressure testing and steam blow out of piping systems. Upon completion of blow out operation all thermo wells and flow elements with branch pipes be installed and welded.
- 14.4.29 For hangers and supports the instruction given in the drawings and documents must be followed for handling, erection and setting of cold / hot values and locking etc
- 14.4.30 The hangers and supports for pipelines may be supplied in dismantled / knocked down condition. It is the responsibility of the contractor to assemble them as per approved drawings and install them in position as per site engineer instructions.
- 14.4.31 Contractor has to fabricate and erect temporary spool pieces wherever required due to non-receipt of valves in time and after receipt of valves the spool pieces are to be replaced with regular valves at free of cost. For spool pieces materials will be supplied free of cost by BHEL.
- 14.4.32 All welded joints should be painted with anti-corrosive paint, once radiography and stress relieving works are over.
- 14.4.33 Welding, non-destructive testing and heat-treatment as prescribed in BHEL Welding / Heat treatment manual is to be carried out by the contractor. The contractor shall conduct non-destructive tests like radiography, ultrasonic test for weld defects etc., ultrasonic test for finding thickness, dye penetrant tests, magnetic particle test etc. on weld joints, castings, valve bodies and other equipments etc. as per BHEL Engineer's instructions within the quoted rate.
- 14.4.34 Contractor shall arrange all equipments, alignment bolts, tools, Consumables like welding electrodes in their scope (all types except those supplied by BHEL), and argon gas cylinders etc., for welding of pipes at his cost. Consumables like jute, cotton waste, hacksaw blades, petrol, Kerosene oil etc. are in contractor's scope. Only filler wires as stipulated by manufacturing units and identified in relevant

shipping list will be supplied to the contractor free of cost. Any excess requirement shall be arranged by the contractor / BHEL at contractor's cost. Argon / Nitrogen gas for stainless steel tubes purging during welding to be arranged by contractor within the quoted rates.

- 14.4.35 Cutting and removal of dummies for all the shop welded stubs (irrespective of the equipments supplier for the above) for all the terminal points and preparation of edge where the piping is to be terminated is also in the scope of the contractor without any extra payment.
- 14.4.36 For skid mounted equipment, the checking and re-alignment required at site is in the scope of work.
- 14.4.37 All dimensions / elevations refers to center line of pipe unless otherwise specified, the pipe routing shall be carried out as per the drawing. Wherever the dimensions are not specified / shown as approximate the same may be routed as per site requirement / convenience as per site engineer's advice.
- 14.4.38 Pipelines shall be cleaned off welding slag and burrs by hand files, wire brushes and flexible grinders wherever required and using cloth.
- 14.4.39 Contractor has to arrange required fire retardant covering material at their cost to protect the machined components, assembled parts and insulation materials drawn from BHEL before and after erection.
- 14.4.40 Prior to erection of any components, inspection to be done for any foreign materials and damages and they are to be removed / attended as per instructions of BHEL engineer.
- 14.4.41 The temporary structures / items welded to permanent members / pipes are to be cut and removed without any damage. In case of any damage, the same has to be made good by the contractor at his cost.
- 14.4.42 Erection of all the items/piping systems, supplied by BHEL's Manufacturing units or Vendor as integral part of the systems covered under this scope of work, shall be done by the contractor as per the accepted tonnage rate.
- 14.4.43 The contractor shall ensure lowering of pipes in position with adequate precautions as to avoid any damage to either material or men. Only the anchoring points earmarked for the purpose of lowering the pipes are to be used.
- 14.4.44 It is possible that a few flanges may not be matching. The contractor shall be required to cut and re-weld the same as and when required without any additional cost.
- 14.4.45 Wherever piping erected by the contractor is connected to equipment / piping erected by the other agencies the joint at the connecting point shall be the responsibility of the contractor who is erecting the piping under this specification.
- 14.4.46 Normally the high-pressure valves will have prepared edges for welding. But, if it becomes necessary, the contractor will prepare new edges or recondition the edges by grinding or chamfering to match the corresponding tubes and pipes within the scope of the work.
- 14.4.47 All fittings like `T'-pieces, weld neck flanges, reducers etc., shall be suitably matched with pipes for welding. The valves will have to be checked, cleaned or over hauled in full or in part before erection and during commissioning.

- 14.4.48 The contractor shall be responsible for correct orientation of all valves so that seats, stems and hand wheels will be in desired location. It is the responsibility of the contractor to obtain the information regarding orientation of valves not fully located on drawings before the same are installed.
- 14.4.49 The adjustment of all hangers & supports erected in both cold & hot conditions for maintaining the proper slopes towards the drain pots and application of cold pull in the piping wherever required is also included in the scope of the contractor.
- 14.4.50 Contractor shall install piping in such a way that no excessive or destructive expansion forces exists in either the cold condition or under conditions of maximum temperature and pressure. All bends, expansion joints and any other special fittings necessary to take care of proper expansion shall be incorporated as per the advice of Engineer. During installation of expansion joints, anchors, care must be taken to see that full design movement is available at all times from maximum and minimum temperature.
- 14.4.51 The hanger assemblies shall not be used for attachment of rigging to hoist the pipes into position. Other means shall be used to securely hold the pipe in position till pipe supports are completely assembled and attached to the pipe and building structure.
- 14.4.52 All the valves, including motorized valves, flap valves, dampers, actuators, etc. shall be serviced and lubricated to the satisfaction of Engineer before erecting the same and during pre-commissioning also. Welding or jointing of extension spindle for valves to suit the site conditions and operational facility shall be part of erection work within the quoted rates.
- **14.5 Rotary machines:** Certain rotating machinery after initial runs and commissioning of the equipment have to be hot aligned as per the instructions of BHEL engineer. Cleaning fans, ducting etc., free of extraneous steel, scaffolding materials electrodes, all foreign materials etc., before trial run of rotating machinery, and at various stages of pre-commissioning activities as per BHEL engineer's instruction, is within the scope of work.
- 14.5.1 Some of the rotating equipment and electrical motors are provided with protective greases only. Contractor shall arrange for cleaning of the same with kerosene or some other reagent. If necessary, dismantling some of the parts of the equipment would be necessary. He shall arrange for re-greasing / lubricating them with recommended lubricants and for assembling back the dismantled parts, at quoted rate. Lubricants will, however, be supplied free of cost by BHEL.
- 14.5.2 After initial trial of rotating equipment, control and power cabling for motors and other equipment / instrumentation shall have to be disconnected for checking alignment and re-setting / re-alignment / hot alignment. Contractor shall have to arrange for disconnecting control and power cabling as per BHEL engineer's instructions and clearance and reconnect the control and power cabling after realignment. Quote tonnage rate shall be inclusive of the above.
- 14.5.3 Packer plates supplied may have to be machined to the correct dimensions. It may also be necessary to blue match the same with each other/ with equipment / with foundations as per BHEL instructions

- 14.5.4 Contractor shall arrange changing of preservative oil in the gearboxes, journal and other bearing assemblies of rotating equipment when in storage areas or after erection of equipment as the case may be as per the instructions of BHEL engineer. Necessary lubricants / oil will be supplied by BHEL and the same will be drawn by contractor from BHEL / customer's stores and transporting to site. Prior to the commissioning of the equipment, oil should be drained and collected in drums provided by BHEL and returned to BHEL / customer's stores.
- 14.5.5 The fans, and other rotating machines shall be checked for clearances and other vital tolerances. Necessary assistance for balancing of equipment during trial run, if required, shall be provided by the contractor free of cost.
- 14.5.6 Whenever required the contractor shall arrange for pre-qualification of process task Performers.
- 14.5.7 Non specified jobs at the interface / terminal points like bolting welding, gasket changing etc. have to be done by the contractor within the quoted price.
- 14.5.8 The terminal points decided by BHEL should be final and binding on the contractor for deciding the scope of work and effecting payment for the work done.
- 14.5.9 Actuators / drives of dampers, gates, powered vanes etc. may have to be serviced, lubricated, before erection, during pre-commissioning & commissioning, including carrying out minor adjustments required as incidental to the work.
- 14.5.10 All rotating machines and equipment shall be cleaned, lubricated, checked for their smooth rotation, if necessary by dismantling and refitting before erection. If, in the opinion of Engineer, the equipment is to be checked for clearance, tolerance at any stage of work or during commissioning period, all such works are to be carried out by contractor at his cost.
- 14.5.11 All the shafts of rotating equipment shall be properly aligned to those of the matching equipment within design tolerances All bearings, shafts and other rotating parts shall be thoroughly cleaned and suitably lubricated before starting.
- 14.5.12 All the motors and equipment shall be suitably doweled after alignment of shafts with taper / parallel machined dowels as per the direction of the Engineer. Dowel pins required are be machined by the contractor at his own cost. However the materials for dowel pins shall be issued by BHEL free of cost.
- 14.5.13 The HT motor bearings shall be blue matched at site and checked for bearing clearances. The contractor if required shall carry out scraping of bearing housing. No extra claim for blue matching up to 1mm initial gap will be entertained.
- 14.5.14 The contractor at no extra cost to BHEL shall carry out servicing and realignment of skid mounted equipment.
- 14.5.15 Certain instruments like pressure gauges, pressure transmitters, temperature gauges, flow switches and indicators, etc., are received in assembled condition as integral part of equipment. Contractor shall be responsible for safe receipt, installation and custody of these instruments supplied mounted on skids / equipment. The calibration of skid / equipment mounted instruments shall be arranged by BHEL through other agency engaged for C&I. Contractor will be informed by BHEL engineer about the details of C&I agency. The contractor shall coordinate with the C&I agency for removal, calibration and re-installation of the instruments. Though C&I agency will remove and reinstall the instruments after

- calibration, the contractor for this package will maintain the list of all the instruments removed & reinstalled. Instruments prior to removal and after reinstallation shall be considered in custody of the contractor for this package.
- 14.5.16 All electrical panels, control gears, motors and such other devices shall be properly dried by heating to improve IR valve, before they are energized. Bearings, slip rings commutators and other exposed parts shall be protected against moisture ingress and corrosion during storage and periodically inspected.
- 14.5.17 The contractor shall carry out the tightening of the field bolts on the equipment and piping covered under this specification by using either the calibrated torque wrench method or the turn of part method. The methods used the tools and the equipment deployed shall be subject to the approval of Engineer. The competent technicians shall carry out the bolting work.
- 14.5.18 The contractor shall prepare as built piping drawing & submit to BHEL Engineer for approval & verification of material used.
- 14.5.19 BHEL will provide free of cost only the shims and packer plates (either machined or plain) which go as permanent part of the equipment. Certain packer plates and shims over and above the quantity received as a part of supplies from manufacturing units of BHEL, will have to be cut out from steel plates / steel sheets at site to meet site requirement. Contractor shall cut and prepare packers and shims by gas cutting/chiseling / grinding/machining and de-burr the same. However, machining of the packers wherever necessary shall be arranged by the contractor.
- 14.5.20 All lifting tackles including wire-ropes slings, shackles, used by the contractor, shall be got approved by BHEL Engineer. It will be the responsibility of the contractor to ensure safe lifting of the equipment taking due precautions to avoid any accidents and damages to equipment and personnel. Calibration/fitness testing certificates from recognized agency are to be submitted to BHEL site office for equipment/instrument/appliances to be used, as per requirement of BHEL/ISO system. Expenditure on such works forms a part of the scope of work.
- 14.5.21 The contractor shall erect scaffoldings/Temporary platforms supports etc required during erection before the permanent supports are erected. These should be of adequate capacity and shall never be overloaded. These should be replaced when not found suitable during erection work. All structure materials required for the above shall be arranged by the contractor at his own cost. No such material shall be supplied by BHEL in any case. Welding of temporary supports, cleats etc on the columns shall be avoided. In case of absolute necessity, contractor shall take prior approval from BHEL Engineer. Further, any cutting or alteration of member of the structure or platform or other equipment shall not be done without specific prior approval of BHEL Engineer.

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

WELDING, HEAT TREATMENT & RADIOGRAPHY AND NON-DESTRUCTIVE TESTING The scope of the work will comprise of but not limited to the following:

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

- Welding high tensile structural steel, Piping shall be done by certified high pressure welders who possess valid certificate and who are approved by BHEL Engineer.
- 15.2 All welders including tack welders, structural and piping welder shall be tested and approved by BHEL Engineer before they are actually engaged on work even though they may possess a valid certificate. BHEL reserves the right to reject any welder if the welder's performance is not found to be satisfactory. The contractor shall maintain the records of qualification and performance of welders. BHEL Engineer will issue all the welders qualified for the work, an identity card. The welder will keep the same with him at work place at all times. He may be stopped from work if he is not found in possession of the same.
- 15.3 Site-Welding assemblies are foreseen and shall be indicated on drawing. Welding shall be done as per approved WPS. Bidder shall prepare Welding procedure and submit the same for approval of BHEL/PVUNL.
- 15.4 Engineer may stop any welder from the work if his performance is unsatisfactory for any technical reason or if there is a high percentage of rejection in the joints welded by him. The welders having passed qualification tests does not absolve the contractor of contractual obligation to continuously check the welder's performance.
- 15.5 Faulty welds caused by the poor workmanship shall be cut and re-welded at the contractor's expense. The Engineer prior to any repair being made shall approve the procedure for the repair of defective welds. After the repair has been carried out, the compliance shall be submitted to the quality engineer.
- 15.6 The contractor shall carry out the root run welding of all HP / LP piping, valves by TIG welding method only. The contractor shall have to carry out full TIG welding of butt weld joints of tubes / pipes of lesser thickness if required. During the root runs of stainless steel joints, the contractor shall before and during welding have to purge the pipes with inert gas.
- 15.7 All expenses for testing of contractor's welders including destructive and Non-destructive tests conducted by BHEL at site or at laboratory shall have to be borne by the contractor only. Limited quantity of tube and pipe material required for making test pieces will be supplied by BHEL free of cost.
- 15.8 Only BHEL approved electrodes and filler wire will be used. All electrodes shall be baked and dried in the electric electrode-drying oven to the required temperature for the period specified by the Engineer before these are used in erection work. All welders shall have electrodes drying portable oven at the work spot. The electrodes brought to the site will have valid manufacturing test certificate. The test certificate should have a co-relation with the lot number / batch number given on electrode packets. No electrodes will be used in the absence of above requirement. The thermostat and thermometer of electrode drying oven will be also calibrated and test certificate from Govt. approved / accredited test house traceable to National /

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

International standards will be submitted to BHEL before putting the oven in use. The contractor shall also arrange periodical calibration for the same. Separate ovens shall be used for baking and holding.

- 15.9 All butt / fillet welds shall be subject to Non –Destructive testing as per the Drawing/Procedures/Welding Schedules/Documents at no additional cost. applicable percentage of RT shall be guided by the field welding schedule.
- 15.10 The contractor shall maintain a record in the form as prescribed by BHEL of all operations carried out on each weld. He has to maintain a record indicating the number of welds, the names of welders who welded the same, date and time of start and completion, preheat temperature, radiographic results, rejection if any, percentage of rejection etc. and submit copies of the same to the BHEL Engineer as required. Interpretation of the BHEL Engineer regarding acceptability or otherwise of the welds shall be final.
- 15.11 The contractor shall carry out the edge preparation of weld joints at site in accordance with the details acceptable to BHEL Engineer. Wherever possible machining or automatic flame cutting should be done. Gas cutting will be allowed only wherever edge preparation otherwise is impractical. All slag / burrs shall be removed from the edge and all the hand cuts shall be ground smooth to the satisfaction of engineer. Prepared edges to be preserved / applied with wieldable primer.
- 15.12 All welds shall be painted with anticorrosive red oxide paint once radiography and stress reliving works are over. Necessary consumables and scaffolding etc including paints shall be provided by contractor at his own cost.
- 15.13 Pre-heating, radiography and other NDT tests, post heating and stress relieving after welding of tubes, pipes, Non Pressure Parts like Crown Plate support assy, including attachment welding wherever necessary, are parts of erection work and shall be carried out by the contractor in accordance with the instructions of the Engineer. Contractor at his cost shall arrange all equipment and consumables essential for carrying out the above process.
- 15.14 Contractor shall arrange all necessary stress relieving equipment with automatic recording devices. The contractor shall arrange for labour, heating elements, thermocouples, thermo-chalks, temperature recorders, thermocouple attachment units, graphs, sheets insulating materials like asbestos cloth, ceramic beads, asbestos ropes etc. required for heat treatment/ stress-relieving operations. The contractor should take a note of the following,
 - Temperature shall be measured by thermocouple and recorded on a continuous printing type recorder. All the recorded graphs for heat treatment works shall be the property of BHEL.
 - All stress relieving equipment will be used after due calibration and submission of test certificate to BHEL. Periodic calibration from Govt. Approved / accredited Test Houses traceable to National / International standards will also be arranged by the contractor for such equipment at his cost.
 - The contractor shall obtain the signature of Engineer or his representative on the strip chart of the recorder prior to the starting of SR operations.

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- 15.15 The contractor shall also be equipped for carrying out other NDT like LPI /MPI / Hardness test etc. as required as per welding schedules / drawings within the finally accepted price / rates. Ultrasonic testing, wherever required, will be arranged by contractor within the quoted rate.
- 15.16 The technical particulars, specification and other general details for radiography work shall be in accordance with ASME, IBR or ISO as specified by BHEL.
- 15.17 The contractor for radiography work shall use iridium-192/ Cobalt 60; the geometric un-sharpness shall not exceed 1.5 mm. The contractor should take adequate safety precautions while carrying out radiography. Contractor at his cost shall arrange necessary safe guards required for radiography (including personnel from BARC).
- 15.18 Low speed high contrasts, fine grain films (D-7 or equivalent) in 10 cm width only are used for weld joint radiography. Film density shall be between 1.5 and 2.0.
- 15.19 All radiographs shall be free from mechanical, chemical or process marks, to the extent they should not confuse the radiographic image and defect finding. Penetrometer as per ASME or ISO must be used for each exposure.
- 15.20 Lead numbers and letters are to be used (generally 6mm size) for identification of radiographs. Contract number, joint identification, source used, welder's identification and SFD are to be noted down on paper cover of radiograph.
- 15.21 Lead intensifying screens for front and back of the film should be used as per the above-referred ASME specification. The joint is to be marked with permanent mark A, B, C to identify the segments. For this a low stress stamp shall be used to stamp the pipe on the down streamside of the weld. For multiple exposures on pipes, an overlap of about 25-mm of film should be provided.
- 15.22 Radiography personnel with sufficient experience and certified by M/s BARC for conducting radiographic tests in accordance with safety rules laid down by Division of Radiological protection only have to be deployed. These personnel should also be registered with DRP / BARC for film badge service.
- 15.23 All arrangements for carrying out radiography work including dark room and air conditioner and other accessories shall be provided by contractor within the space allotted for office at his cost. As an alternative the contractor may deploy an agency having all above facilities and who are duly approved / accredited by BARC and / or other Regulatory authorities. Detailed particulars of such agencies will be submitted and got approved by BHEL Engineer before the actual deployment of agency for radiography work.
- 15.24 The contractor shall have a dark room & pit room fully equipped with radiography equipment, film (un-exposed), chemicals and any other dark room accessories. All radiography films shall be developed in the dark room at site.
- 15.25 In case of radiography of less than 100%, the joints identified by BHEL at random shall be radiographed.
- 15.26 Contractor shall note that 100% radiography will be done at the initial stages on all the piping welding joints. Subsequently radiographic inspection will be done on the basis of quality of welding. However minimum percentage of joints to be radio graphed shall not be less than the requirement of BHEL welding schedule / IBR / Customer's requirements. The percentage may be increased depending upon the

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- quality of joints and at the discretion of BHEL. Radiography on LP piping joints is not envisaged. However other NDT test as called for in the FQP including LPI, MPI and HT will have to be carried out.
- 15.27 All the Radiographs shall be properly preserved and shall become the property of BHEL. They are to be reconciled with the work done, joints radio graphed and submitted to BHEL / customer.
- 15.28 Since radioisotopes are being used, all precautions and safety rules as prescribed by BHEL/BARC/ Customer shall be strictly followed. BARC /DRP certificate to be provided before taking up the work.
- 15.29 Radiography of joints shall be so planned after welding, that the same is done either on the same day or next day of the welding to assess the performance of HP welders. If the performance of welder is unsatisfactory, he is to be replaced immediately.
- 15.30 Wherever radiographs are not accepted, on account of bad shot, joints shall be reradiographed and re- submitted for evaluation.
- 15.31 However, if the defect persists after first repair, further repair work followed with radiography shall be repeated till the joint is made acceptable. In case the joint is not repairable, the same shall be cut, re-welded and re-radio graphed at contractor's cost.
- 15.32 Heat treatment and radiography may be required to be carried out at any time (day and night) to ensure the continuity of the progress. The contractor shall make all necessary arrangements including labour, supervisors/ Engineer required for the work as per directions of BHEL.
- 15.33 The contractor shall assist BHEL Engineer in preparing complete field welding schedule for all the field welding activities to be carried out in respect of piping and equipment erected by him involving high pressure welding at least 30 days prior to the scheduled start of erection work at site. The contractor shall strictly adhere to such schedules.
- 15.34 The contractor shall deploy required number of H.P. welders to carry out the H.P. weld joints. The welding works should not be held up due to shortage / want of I.B.R./H.P. welders.
- 15.35 All welded joints shall be subjected to acceptance by BHEL Engineer.
- 15.36 The technical particulars, specifications and other general details of work shall be in accordance with BHEL welding, Heat treatment and NDE manuals or equivalent as decided by BHEL Engineer.
- 15.37 Contractor shall carryout Radiography as per welding Manual booklet applicable as per IBR, enclosed. However, percentage radiography shown in the respective drawings shall be final and binding on the contractors.
- 15.38 The field joints are to be radiographed and preheating and post weld heat treatment to be done as per BHEL procedure and manuals.
- 15.39 The percentage of Radiography are tentative, which may be increased depending upon the quality of joints at the discretion of BHEL.
- 15.40 Penetrometer as per ASME/ISO shall be used for all exposures.
- 15.41 Lead numbers and letters (generally of 6mm size) are to be used for identification of radiographic contract No., joints identification, sources used welders identification, SFD used are to be noted down in the paper cover of radiography. Lead intensifying

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- screens for front and back of the film shall be used as per the instructions of BHEL Engineer
- 15.42 The contractor shall be fully equipped with radiography equipments, films, chemicals and other dark room facilities. There must be a number of radiographic personnel with sufficient experience and certified by BARC for field radiographic inspection. Further, the contractor must follow strictly the safety rules laid down by BARC, from time to time, contractor's radiographers shall also be registered with BARC for film badge service.
- 15.43 Contractor shall provide all skilled, unskilled work men required for the job, which will include Engineers, supervisors, operators, as required for timely and satisfactory execution of radiography work.
- 15.44 All the radiographs shall be properly preserved in air-conditioned rooms and shall become the property of BHEL.
- 15.45 Radiography of joints shall be so planned after welding that the same is done either on the same day or next day of the welding to assess the performance of high pressure welders. If the performance of the welder is unsatisfactory, he shall be replaced immediately.
- 15.46 The defects as pointed out by the Engineer shall be rectified immediately to the satisfaction of Engineer and Re-radio graphed. The decision of Engineer regarding acceptance or otherwise of the joint shall be final and binding on the contractor.
- 15.47 Wherever radiographs are not accepted on account of poor exposure, joints shall be re-radiographed and new film submitted for evaluation. Radiographs shall be taken again on joints after carrying out repairs. However, if the defect persists after first repair as per radiograph, carrying out radiography shall be repeated till the joint is made acceptable. In case the joint is not repairable, the same shall be cut, re-welded and re-radio graphed at contractor's cost.
- 15.48 The contractor shall also be equipped for carrying out other NDT like liquid penetrant inspection, magnetic particle inspection, etc. as and when required in the interest of work within the quoted rates.
- 15.49 For carrying out ultrasonic testing of welded joints of large size tubes and pipes, it will be necessary to prepare the surface by grinding to a smooth finish and contour as desired by BHEL Engineer. The contractor's scope of work include such preparation and no extra charges are payable for this.
- 15.50 It may also become necessary to adopt inter layer radiography / MPT / UT depending upon the site/technical requirement necessitating interruptions in continuity of the work and making necessary arrangements for carrying out the above work. The contractor shall take all this into account and quote the price inclusive of all such work and radiography.
- 15.51 The welded surface irrespective of place of welding shall be cleaned of slag and painted at the center with primer paint to prevent corrosion at no extra cost towards this.
- 15.52 All welders shall be tested and approved by BHEL Engineer before they are actually engaged on work though they may possess the required certificate. BHEL reserves the right to reject any welders without assigning any reason. The welder

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- Identification code as approved by the BHEL Engineer shall be stamped by the welder on each joint done by them. The contractor will be responsible for the periodic renewal, retesting of the welders as demanded by BHEL.
- 15.53 BHEL Engineer is entitled to stop any Welder from the work if his work is unsatisfactory for any technical reasons or there is a high percentage of rejection of joints welded by him, which in opinion of the BHEL Engineer will adversely affect the quality of the welding though the Welders, has earlier passed the tests prescribed by BHEL Engineers. The welders having passed qualification tests do not relieve the contractor of a contractual obligation to check the welder's performance.
- 15.54 All charges towards testing of Welders for destructive and non-destructive test, testing and approval of welders for engaging in the erection work shall be borne by the contractor.
- 15.55 The welding process, weld joint details, joint configuration and material specification may change to suit the design requirements. The contractors quoted rates shall be inclusive of each contingency. All welds involved in the erection of temporary pipe lines for hydraulic test, chemical cleaning, steam blowing etc. to be carried out within the quoted rates. The number of joints to be welded as mentioned in the welding schedule consists of butt welds.

15.56 MPI must be done on joints, those are undergone ultrasonic testing.

15.57 Preheating, inter-pass heating, post weld heating and stress relieving after welding are part of erection work and shall be performed by the Contractor in accordance with BHEL engineer's instructions. Where the electric resistance heating method is adopted Contractor shall make all arrangement including heating equipment with automatic recording devices, all heating elements, thermocouples and attachment units, graph sheets, thermal chalks, & insulating materials like mineral wool, asbestos cloth, ceramic beads, asbestos ropes etc, required for all heating and stress relieving works.

15.58 List of Penalties on Violations on Quality Provisions

Sr no	Violation	Penalty in Rs	
1	Mother oven not working	500 per day & ban on its use	
2	Slackness in control over baking of	200 per incident	
	welding electrodes(Doc.)		
3	Holding oven not working/plugged in	500 per incident/day & ban	
		its use	
4	Portable oven not working/Plugged in	100 per incident & welder to	
		be sent home	
5	Use of cold electrodes(Except E6013)	1000 per incident & welder	
		to be sent home	
6	Unauthorized welder on job	5000 per incident & welder	
	·	to be sent home	

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

7	Delay in NDT Agency deployment w.r.t	500 per incident & welder to	
	jointly agreed Ere. Prog	be sent home	
8	Failure to monitor Welder's Performance	5000 per week	
	(RT, SR, Penalty Joint etc.)	_	
9	Improper acts w.r.t maintain SR Charts	10000 per incident	
10	Site Welding/QLY Engineer not deployed	500 per day	
	w.r.t mutually agreed Ere. Plan		
11	Delay in (RT, SR, UT) report submission &	10,000 per week	
	customer acceptance Log sheets esp. for		
	Billed qty. from dt. of Billing (Vendor)		
12	Lack of safe approach Scaffolds/Platform	1000 per incident.	
	for inspection & non-availability of		
	calibrated MMDs –		

15.59 GUIDELINES FOR WELDING, NDE AND HEAT TREATMENT

For NDT & Heat Treatment agencies has to follow the guidelines as per Volume –IE (Annexure-6).

15.60.1 RECEIPT INSPECTION OF WELDING ELECTRODES / FILLER WIRES

- 1. All electrodes / filler wires received at site stores shall be segregated for type and size of electrode.
- 2. Ensure that electrode packets received are free from physical damage.
- 3. Where electrodes are damaged, the same shall be removed from use.
- 4. Only electrodes identified in the "Rationalized List of Electrodes" are to be accepted.
- 5. Where filler metals are supplied by manufacturing unit, inspect for damages, if any.
- 6. Ensure availability of relevant test certificates. Refer tables of chemical compositions and mechanical properties for acceptance.
- 7. Endorse acceptance / rejection on the test certificate.

15.60.2 STORAGE & IDENTIFICATION OF WELDING ELECTRODES / FILLER WIRES

- 1. **Scope**
- 1.1 This procedure is applicable for storage of welding electrodes / filler wires used at sites.
- 2. **Procedure:**
- 2.1 Only materials accepted (based on receipt inspection) shall be taken into account for storage.
- 2.2 Storage Facility:
- 2.2.1 The storage facility shall be identified.
- 2.2.2 Access shall be restricted to authorized personnel.
- 2.2.3 The storage area shall be clean and dry.
- 2.2.4 Steel racks may be used for storage.
- 2.2.5 Avoid storing wood inside the storage room.

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- 2.2.6 Maintain the temperature of the storage facility above the ambient temperature.
- 2.2.7 This can be achieved by the use of appropriate heating arrangement .
- 2.3 The electrodes / filler wire shall be segregated and identified for
 - 1. Type of electrode e.g. E7018.
 - 2. Size of electrode e.g. Dia 3.15 mm.
- 2.4 Colour coding for filler wires:
- 2.4.1 On receipt of GTAW filler wires, codify the filter wires as per table I below . Both ends shall be coloured.

Table - 1

Specification	Brand Name*	Colour Code
RT 1/2 Mo (ER80s-D2)	TGSM	Green
RT 1 Cr 1 / 2 Mo (ER80S-B2)	TGS 1CM	Silver grey/White
RT 2 1/4 Cr 1 Mo (ER90S-B3)	TGS 2CM	Brown / Red
RT 347 (ER 347	TGS – 347	Blue

(* or other approved equivalents)

- 2.4.2 Where another set of colour code is followed, maintain a record of coding used
- 2.4.3 Where the filter wire is cut, apply the appropriate colour code at both ends of the piece.
- 2.4.4 For other filler wires, a suitable colour distinct from table 1 shall be applied

15.60.3 BAKING AND HOLDING OF WELDING ELECTRODES

A. Purpose:

This section details activities regarding baking and holding of welding electrodes used at sites.

B. Procedure:

- 1. While handling, avoid contact of oil, grease with electrodes. Do not use oily or wet gloves.
- 2. It is recommended that not more than two days requirements are baked.

C. GTAW Filler Wires:

1. These wires do not require any baking.

D. Covered Electrodes:

- I. Baking and holding
- II. Identify baking oven and holding oven.
- III. They shall have a temperature control facility upto 350 °C for baking oven and 200 Deg. C for holding oven.
- IV. A calibrated thermometer shall be provided for monitoring temperature.

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- V. On opening a packet of electrodes, segregate and place them in the baking oven. Avoid mix up.
- VI. After loading, raise the baking oven temperature to the desired range as per Table below.
- VII. Note the time when the temperature reaches the desired range. Maintain this temperature for the duration required as per Table below.
- VIII. On completion of baking, transfer the electrodes to holding oven, maintain a minimum temperature of 100°C till issue.
 - IX. The electrode shall not be subjected to more than two cycles of baking. Maintain a register containing following details:
- a. Brand name (e.g. Supratherme)
- b. Size (e.g Dia 4.0 mm)
- c. Quantity (e.g. 110 pieces)
- d. Time at required temperature ie. Above 2500C
- e. Time of Transfer to holding oven. Activities a, b, c to be recorded before loading into the oven.

Baking and Holding Parameters

AWS	Baking		Holding
Classification (*)	Temperature ⁰ C	Time (Hours)	Temperature ⁰ C (@)
E7018	250 – 300	2	100 min
E7018-1	250 – 300	2	100 min
E7018-A1	250 – 300	2	100 min
E8018-B2	250 – 300	2	100 min
E9018-B3	250 – 300	2	100 min
E8018-B2L	250 – 300	2	100 min
E9018-B3L	250 – 300	2	100 min
E309 & E347	250 - 300	1	100 min

Note: (*) For other electodes, supplier's recommendations shall be followed.

(@) Maintain the temperature in the oven till issue.

15.61 Steel Structure and platforms.

Chapter-XV: Welding, Heat Treatment & Radiography and Non-destructive Testing

- (a) Only material which has been identified against mill sheet or test certificates shall be used for construction. All plates above $40 \, \mathrm{mm}$ thickness shall be $100 \, \mathrm{\%}$ ultrasonically tested.
- (b) Visual inspection of all welds shall be performed in accordance with AWS D.1.1.
- (c) NDT requirements of structural steel welds (other than Coal Bunkers) shall be as under:-
- (i) 100% RT/UT on butt-welds of plate thickness > 32 mm.
- (ii) For plates of 25mm < thickness < 32mm 10% RT/UT and 100% MPI
- (iii) For plates of thickness < 25mm 10% MPI/LPI.
- (iv) All fillet welds of built up plate girders shall be inspected 100% by MPI.
- 15.62 Non-destructive examination of welds shall be carried out in accordance with the relevant design/manufacturing codes. However, as a minimum, the following requirements shall be met. Further, statutory requirement, wherever applicable, shall also be complied with.
- (1) Temperature > 400 Deg, C or pressure exceeding 71 bar.
- (i) 100% RT/UT on butt welds and full penetration branch welds.
- (ii) 100% MPE.
- (2) Temperature > 175 Deg, C upto 400 Deg. C or pressure exceeding 17 bar and upto 71 bar.
 - i. 100% RT/UT on butt welds and full penetration branch welds for pipe dia more than 100 NB.
 - ii. 10% RT/UT on butt welds and full penetration branch for pipe dia upto 100NB.
 - iii. 100% MPE.
- (3) For all other pipes not covered above, shall be subjected 100% MPE/DPT in case of under ground pipes and 10% MPE/DPT in case of piping above the ground. Further, 10% of butt welds of underground piping shall be subjected to RT.

15.63 Quality Check OF Pressure vessels

A. Pressure vessels:

- a) NDT on weld joint shall be as per respective code requirements or the minimum as specified as below:
 - i. DPT on root run of butt weld, nozzle welds and finished fillet welds.
- ii. 10% DPT on all finished butt welds.
- iii. 10% RT (covering all 'T'/cross joints) of butt welds.
- b) Butt welds of dished ends shall be stress relieved and subjected to 100% RT.

Each finished vessels shall be hydraulically tested to 150% of the design pressure for a duration of 30 minutes.

The scope of the work will comprise of but not limited to the following: (All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

- 16.1 The pressure testing for piping /Duct system shall be carried out as per Customer / customers' consultant specification / BHEL. Customers' consultant specification forms the part of this tender specification.
- All Piping and some of the Low Pressure parts shall be subjected to hydraulic test as per the Standard / statutory requirements. The contractor shall supply necessary labour and other services and make necessary arrangements to carry out the required tests as per the instructions and directions of the BHEL Engineers.
- 16.3 The contractor shall make all necessary arrangements including making of temporary closures on piping / equipment for carrying out the hydro-static testing on all piping, equipment covered in the specification at no extra cost.
- 16.4 Soundness of the welds shall be tested hydraulically under the supervision of the BHEL Engineer and Customer, to the pressure indicated in the drawing. Prior to the test, the ACC/piping system shall be inspected by the BHEL Engineer to the extent necessary to ensure compliance with clearance for the test, which will be obtained by the contractor from the Engineer.
- 16.5 Hydraulic testing, as required shall be carried out by the contractor. The servicing, installation, electrical connection, erection, testing and dismantling of Hydraulic Test pump, temporary pipelines, fittings, etc. shall be carried out by the contractor as part of this work.
- All the hydraulic tests shall be repeated till all the pipelines to satisfy the requirements / obligation of BHEL to their customer. As far as the hydraulic pressure test is concerned, the same shall be conducted at various stages to the satisfaction of IBR inspectorate / BHEL / Customer Engineers. Any rectifications required shall have to be done / redone by the contractor at his cost. The contractor shall carry out all the required tests and pre-commissioning and commissioning activities required for successful and reliable operation. These would include hydraulic test of piping, chemical cleaning, steam blowing, water washing etc. as instructed by BHEL.
- 16.7 Test records shall be made for pressure testing of above piping system. These records shall contain the following information:
 - a) Date of test
 - b) Identification of piping tested
 - c) Test fluid
 - d) Test pressure
 - **e)** Approval of the Engineer.
- 16.8 Contractor has to arrange required pumps with sufficient capacity for filling water in the tubes and pipes for conducting Hydraulic testing of LP lines. Contractor has

- to arrange Hydraulic Test pump / Hand Pump at his cost for Hydraulic testing of LP lines.
- 16.9 Contractor shall lay all necessary electric cables and switches etc. required for the hydraulic tests and other tests, flushing etc., and maintain the system till the tests are completed satisfactorily.
- 16.10 In certain places blanking has to be resorted prior to Hydraulic test and spool pieces have to be erected in place of control valves, orifices and other fittings and these spool pieces have to be subsequently replaced with the regular valves/ fittings by the contractor at no extra cost.
- 16.11 Contractor at his cost shall lay all necessary temporary piping, install the pumps, blanks, valves required for the test, pressure gauges etc. Required pipes, valves, plates etc., will be given by BHEL. Temporary piping, pumps, valves, flanges, blanks etc shall be removed by him and returned to BHEL. All thermowell points are to be seal welded, with plug in position. All Temperature Element points are to be provided with blanks and welded. Necessary blanks will be provided by BHEL.
- 16.12 Welding and stress relieving of temporary blanks or suitably fixing temporary blank flanges with gaskets and fasteners and welding and providing suitable deaeration / venting / draining points with valves as per BHEL Engineer's instructions, for performing hydro-test of piping and other equipments is within the scope of work. Gaskets, valves, fasteners will be provided free of cost by BHEL. Contractor shall cut steel blanks from steel provided without charging extra. After completion of hydraulic test, welded blanks shall be cut and removed and weld burrs ground finished and cavities/scars of cutting weld filled and ground as per BHEL Engineer's instructions.
- 16.13 The contractor shall make all necessary arrangements including making of temporary closures / dummy on piping / equipment for carrying out the hydrostatic testing on all piping, equipment covered in the specification at no extra cost. Necessary blanks will be provided by BHEL.
- 16.14 The contractor shall see that the water shall not be allowed to accumulate in open trenches where work is in incomplete stage, precautionary works such as blank flanging the open ends of the pipe line and filling the pipe line with water etc. shall be taken as directed by the engineer. Such works shall be to the contractor's account and no separate payment will be made for the same.
- The contractor shall carryout the required test on the pipelines such as Hydraulic Test of various piping systems, Ultrasonic Test for weld defects and finding thickness, Dye penetrant test, Magnetic particles test for Weld defects and materials defects etc. All facilities (manpower, materials, equipment, consumables etc.) including proper approaches wherever required shall be provided by the contractor for satisfactory conduction of above tests. Special equipment such as magnetic particle tester, ultrasonic test kit and engineers required for these tests

- shall be arranged by the contractor along with Qualified technician within finally accepted rates.
- 16.16 Hanger adjustment / re-adjustment during erection, before and after Hydraulic Test, before and after steam blowing, during and after full load operation, are to be carried out by the contractor within Quoted Rate.
- 16.17 In general Hydraulic testing of piping shall be performed after all eventual pipe branches have been completed and valves installed. Should it be required to hasten erection work, pressure tests may be performed by sections. For this scope of work, the erected pipe lines shall be hydraulically tested as per site requirement in segments. For conducting hydraulic test, both ends of pipe lines shall be blanked by welding of plates. Only one or two set of plates and structural materials for blanking required for one segment will be provided by BHEL free of charge. After completion of hydraulic test in one segment, the same plates are to be cut and removed and utilized / welded on the other segment of the pipe lines, to carry out the hydraulic test for the respective segments. No separate plates for blanking for each segment will be provided. After completion of Hydraulic test, the required edge preparations shall be carried out on the end of pipe lines and to be welded with the respective pipe lines. In such cases joint connection shall be checked during a final and additional test, if required. The contractor shall note this aspect and quote accordingly.
- 16.18 During hydraulic test, the pipes being tested shall be isolated from the equipments to which they are connected.
- 16.19 Openings on piping for pressure / temperature impulse connections shall be fully closed during the test to prevent dust or foreign matter entering into the instrument piping inadvertently.
- 16.20 The following specifications shall also be completed with during hydrostatic test.
 - **a.** Vent nozzles with valves shall be provided at the highest point of the runs, to eliminate air pockets. At the lowest point drain nozzles, with valves shall be provided to drain water from pipes. The nozzles and valves shall be of the same materials as the pipe.
 - **b.** The lowest part of the pipe shall always be filled first with water.
 - **c.** Pressure shall be slowly increased (without shocks) to the stipulated value and maintained as long as required to visually check all joints.
 - **d.** Following the control specified above the pressure shall be slowly decreased to the design pressure after which the pipe shall be subjected to the peening test, applying knocks every 150 mm approx. especially in the welded joint areas, with a 0.5 1.5 kg. Hammer (depending on the pipe wall thickness). The hammer used shall be a round headed one.
 - **e.** Following the peening test, the pressure shall be increased to the stipulated value and all welded joints shall be visually inspected.

- f. Following these test, the pipe shall be drained or pumped out to the other section to be hydro test using the drain out pump to be provided by Contractor and wherever necessary shall be flushed with air for all pipes.
- g. The pressure test is considered satisfactory if no cracks, unjustified pressure reductions, leakages, seepages etc., appear.
- h. Should defects be found, these shall be repaired in the same manner as these during radiographic examination. Hydraulic test shall be repeated after defects have been repaired.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING, COMMISSIONING AND POST COMMISSIONING

The scope of the work will comprise of but not limited to the following:

TESTING, PRE - COMMISSIONING, COMMISSIONING AND POST COMMISSIONING

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

- 17.1 The Contactor shall carry out all the required tests and pre-commissioning and commissioning activities required for their successful and reliable operation. These would include.
 - a. Trial run of individual equipments.
 - b. Suitable chemical cleaning of Piping (if required).
 - c. ATT/Hydraulic test of ACC
 - d. ATT/Hydraulic test of Piping
 - e. Piping Pressure test by Air-Leak testing method.
 - Segment wise
 - For overall system
 - f. Overall flushing through Steam Dumping of ACC system including all piping, tubes, headers etc.
 - -Full Load Operation, Trial run, PG test and handing over.
- 17.2 All required tests (Mechanical and electrical) indicated by BHEL and their clients for successful commissioning are included in the scope of these specifications though some of the tests / activities are not listed in these specifications.
- 17.3 All the tests may have to be repeated till all the equipment satisfy the requirement / obligation of BHEL to their client and also the relevant statutory authority at various stages of work.
- 17.4 The scope of pre-commissioning, commissioning and post commissioning activities cover installation of all necessary temporary piping, supports, valves, blanking, pumps, tanks etc. and other accessories with access platforms valves, pressure gauges, electric cables, switches, cutting of some of existing valve, placing of rubber wedges in the valves etc., required for hydro test, chemical cleaning, steam blowing or any other tests as the case may be and will carry out above activities under this scope of work as per instructions of BHEL. The scope also covers the offsite disposal of effluents of the tests under the scope of this contract as per instruction of BHEL Engineer.
- 17.5 Laying of insulation of temporary piping, tanks are to be carried out by the contractor within quoted rate, and required insulation materials will be provided by BHEL. The welding joints in the temporary pipe lines for hydro test acid cleaning and steam blowing /steam dumping are to be welded by HP welders only. Required NDT tests are to be carried out for the above joints as part of work as per customer / BHEL requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

- 17.6 All materials, equipments necessary for installation of temporary system as above will be supplied by BHEL in random sizes/lengths. However, servicing, fabrication, erection, dismantling of the same after completion of the process, and returning to BHEL stores shall be the responsibility of the contractor.
- 17.7 Contractor shall lay all necessary electric cables and switches etc. required for the hydraulic test and other tests, flushing etc., and maintain the system till the tests are completed satisfactorily.
- 17.8 It shall be the responsibility of the contractor to provide various categories of workers in sufficient numbers along with Supervisors during pre-commissioning, commissioning and post commissioning of equipment and attending any problem in the equipment erected by the contractor till handing over. The contractor will provide necessary consumables, T&Ps, IMTEs etc., and any other assistance required during this period. Association of BHEL's / Client's staff during above period will not absolve contractor from above responsibilities.
- 17.9 It shall be specifically noted that the contractor may have to work round the clock during the pre-commissioning, commissioning and post-commissioning period along with BHEL Engineers. Hence contractor's quoted rate shall take into consideration of all expenses that will be incurred for such arrangement of personnel including engineers/supervisors.
- 17.10 It shall be specifically noted that the above employees of the contractor may have to work round the clock along with BHEL Engineers and hence overtime payment by the contractor to his employees may be involved. The contractors finally accepted rates should be inclusive of all these factors also.
- 17.11 In case, any rework is required because of contractor's faulty erection, which is noticed during pre-commissioning and commissioning, the same has to be rectified by the contractor at his cost. If any equipment / part is required to be inspected during pre-commissioning and commissioning, the contractor will dismantle / open up the equipment / part and reassemble / redo the work without any extra claim.
- 17.12 During commissioning, opening / closing of valves, changing of gaskets, Realignment of rotating and other equipment, attending to leakage and adjustments of erected equipment may arise. The finally accepted price /rates shall also include all such work.
- 17.13 In case any defect is noticed during tests, trial runs and commissioning such as loose components, undue noise or vibration, strain on connected equipment etc., the contractor shall immediately attend to these defects and take necessary corrective measures. If any readjustment and re-alignment are necessary, the contractor at his cost shall do the same as per Engineer's instructions including repair, rectification and replacement work. The parts to be replaced shall be provided by BHEL.
- 17.14 All temporary supports shall be removed in such ways that pipe supports are not subjected to any sudden load. During hydraulic testing of pipes, all piping having

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

variable spring type supports shall be held securely in place by temporary means while constant spring type support hangers shall be pinned or blocked solid during the test.

- 17.15 The contractor shall carry out cleaning and servicing of valves and valve actuators prior to pre-commissioning tests and / or trial operations of the plant. A system for recording of such servicing operations shall be developed and maintained in a manner acceptable to BHEL Engineer to ensure that no valves and valve actuators are left un-serviced. Wherever necessary as required by BHEL Engineer, the contractor shall arrange to lap / grind valve seats.
- 17.16 Cleaning and servicing of all the filters / strainers, in the system shall be done by the contractor within the accepted price. All oils and greases to be filled in the main equipments as first fill and subsequent topping up's will be furnished by BHEL.
- 17.17 At the time of each inspection, the contractor shall take note of the decisions / changes proposed by the BHEL Engineer and incorporate the same at no additional cost. The contractor shall carry out any other test as desired by BHEL Engineer/ Manufacturer on erected equipment covered under scope of this contract during testing and commissioning to demonstrate the physical completion of any part or parts of the work performed by the contractor.
- 17.18 The valves, actuators etc. will have to be checked cleaned and overhauled in full or in part before erection, after and during commissioning as may be necessary.
- Welding and stress relieving of temporary blanks or suitably fixing temporary blank flanges with gaskets and fasteners and welding and providing suitable deaeration / venting / draining points with valves as per BHEL Engineer's instructions, for performing hydro-test of piping and other equipments is within the scope of work. Gaskets, valves, fasteners will be provided free of cost by BHEL Contractor shall cut steel blanks from steel provided within quoted rate. After completion of hydraulic test, welded blanks shall be cut and removed and weld burrs ground finished and cavities / scars of cutting weld filled and ground as per BHEL Engineer's instructions. Seal welding of thermo-wells and blanks of Temperature Element are to be removed by grinding only after steam blowing.
- 17.20 The hydraulic testing of the equipment and piping, covered under this scope of work has to be carried out by the contractor as per instructions of BHEL Engineer. The contractor shall provide all facilities required for hydraulic testing. Before hydraulic test, all the hangers are to be locked by locking pin / plate or temporary support. After completion of Hydraulic test, these are to be removed and all hangers are to be readjusted if required, to the desired value within quoted value.
- 17.21 Transportation of oil drums from customer/BHEL's stores, filling of lubricants and filling of oil for flushing and first filling and subsequent topping up during commissioning and post commissioning is included in the scope of this contract. The contractor shall have to return all the empty drums to the customer / BHEL stores. Similarly, transport of chemicals for various pre-commissioning activities /

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

processes mentioned in the above clauses and returning of remaining and / or the empty containers of the chemicals to customer / BHEL stores is the responsibility of the contractor.

- 17.22 Replacing / cleaning of filters of the erected equipments, piping system etc. during pre-commissioning / commissioning stage are within the scope of work.
- 17.23 During the initial stages of work, trenches for draining water may not be available for hydro test, chemical cleaning, flushing or mass flushing for discharging and draining the system and piping. Necessary low point drains and temporary piping for this will have to be erected by contractor from materials provided by BHEL.
- 17.24 After the chemical cleaning has been successfully completed, removing all temporary piping, fittings of tanks etc. checking all the valves for any accumulation of foreign materials, welding the valves, pipes which were cut and cleaning, re-fixing as per BHEL Engineer's instructions is within the scope of work/specification.
- 17.25 The contractor as per BHEL requirements will suitably make preservation of cleaned surfaces.
- 17.26 Contractor may have to replace old/damaged gaskets / packing etc. for equipments and the same shall be carried out by contractor as per requirement. Materials will be given by BHEL.
- 17.27 In case any erection defect is detected during various tests / operations trial runs as detailed above such as loose components undue noises or vibration strain on connected equipment steam or oil or water leakage etc. the contractor shall immediately attend these defects and take necessary corrective measures. The parts to be replaced shall be provided by BHEL free of cost. If the insulation is to be removed to attend any of the defects the cost of removal and reapplication of insulation should be borne by the contractor.
- 17.28 Necessary scaffolding and approaches for conducting the above shall also be within the scope of the contract.
- 17.29 The contractor shall carryout any other test as desired by BHEL Engineer on erected equipment covered under the scope of this contract during testing, precommissioning, commissioning, and operation, to demonstrate the completion of any part or whole work performed by the contractor.
- 17.30 During this period though the BHEL's / Client's staff will also be associated in the work, the contractor's responsibility will be to arrange required tools, man and plants till such time the commissioned units are taken over by BHEL's client.
- 17.31 Contractor shall cut / open works if needed, as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over. This contingency shall be included within the quoted value. During commissioning opening of valves, changing of gaskets, attending to leakages, minor modification / rectification works may arise. The contractor has to carry out

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

these works at his cost by providing required manpower in all the three shifts. In case any rework is required because of contractor's faulty erection and which is noticed during commissioning the same has to be rectified by the contractor at his cost.

- 17.32 Contractor has to remove the all temporary supports, structures from inside of ducts /pipes ,manifolds and grind the all points after cutting and proper clean the duct and make it free from duct, weldments and burrs.
- 17.33 Contractor to provide necessary commissioning assistance from precommissioning state onwards and up to continuous operation of the unit & handing over to customer. The category of personnel to be as per site requirement and to meet the various pre-commissioning and commissioning programs made to achieve the schedule agreed with customer.
- 17.34 After the start of continuous operation with coal firing, the commissioning tests and maintenance activities will continue. It shall be the responsibility of the contractor to provide the following category of workers with necessary consumables, tools and tackles and supervision till handing over of the unit to the customer.. The various categories of workers required for pre-commissioning, commissioning and post-commissioning activities are as follows:
 - a) Pipe fitters
 - b) Millwright Fitters
 - c) HP & structural welders
 - d) Riggers
 - e) Unskilled workers
 - f) Supervisors
 - g) Electricians
 - h) Laggers
 - i) Sheet metal fabricator/fitter
 - j) Any other category of workers as may be required.

Further in addition to the above, contractor has to arrange the following minimum manpower exclusively for assisting BHEL commissioning engineers during stabilization and trial operation period. This manpower will be directly controlled by BHEL commissioning engineers.

- 1. One Engineer in charge for three shifts.
- 2. Two supervisors per shift for three shifts
- 3. Three fitters per shift for three shifts
- 4. Six helpers per shift for three shifts

It shall be specifically noted that the above employees of the contractor may have to work round the clock along with BHEL commissioning Engineers and hence, overtime, may be involved. The contractor's quoted rate shall be inclusive of all these factors also.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

- 17.35 During commissioning any improvement or rectification due to design requirement is involved and if the contractor is asked to carry out the job, they shall be paid at man-day rates. For this purpose, daily labour report indicating therein nature of work carried out, consumables used, etc. shall be maintained by contractor, and got signed by BHEL Engineer every day. It is not obligatory on the part of BHEL to get the works done by the contractor. They can employ any other agency if they so desire at that time.
- 17.36 During commissioning any improvement / repair / rework / rectification / fabrication / modification due to design improvement / requirement is involved, the same shall be carried out by the contractor promptly and expeditiously.
- 17.37 The contractor has to provide required man power assistance during precommissioning and commissioning checks of motor operated valves, actuators, control valves etc. without any extra charges.
- 17.38 It shall be specifically noted that the employees of the contractor may have to work round the clock along with BHEL Engineers and hence overtime payment by the contractor to his employees may be involved. The contractors finally accepted rates should be inclusive of all these factors also
- 17.39 No payment will be made for temporary installations made for testing of systems & similarly no payment will be made for electrical installations made for any temporary system.

All materials, equipment's necessary for installation of temporary system as above will be supplied by BHEL as free returnable issue in random sizes / lengths. However, servicing, fabrication, erection, dismantling of the same after completion of the process, and handing over back to BHEL stores will be the responsibility of the Contractor.

In accounting of temporary materials following wastage allowances are provided:

1. Structural items : 4%

- ✓ Contractor shall cut / open / dismantle work, if needed, as per BHEL Engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over.
- ✓ Similarly, during the course of erection, if certain portion of equipments erected by the Contractor has to be undone for enabling other Contractors / agencies of BHEL / customer to carry out their work, Contractor shall carry out such jobs expeditiously and promptly and make good the job after completion of work by other Contractors / agencies of BHEL / customer as per BHEL engineer's / agencies of BHEL / customers instructions. Claims, if any, in this regard shall be governed as relevant clauses of 'General Conditions of Contract.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XVII: TESTING, PRE – COMMISSIONING & COMMISSIONING AND POST COMMISSIONING

- 17.40 Contractor shall provide assistance in conducting of performance guarantee test (PG test) of the equipments under the scope of work. Contractor shall install all necessary tapping points; instruments etc and provide necessary assistance within the quoted rates. In case PG test is getting delayed beyond the contract period (normal plus extension if any) due to reasons not attributable to the Contractor, PG test issue will be mutually discussed and decided. However installation of necessary tapping points, impulse pipes, approaches etc are to be completed by the Contractor.
- 17.41 The 'Initial Operation'/trial operation of the complete facility as an integral unit shall be conducted for continuous upto period specified. During the period of trial operation, all systems in the scope shall operate continuously at full load at designated fuel for a period not less than 72 hours. The Initial Operation shall be considered successful, provided that each item/ part of the facility can operate continuously at the specified operating characteristics, for the period of Initial Operation with all operating parameters within the specified limits and at or near the predicted performance of the equipment/ facility.
- 17.42 Specialized test equipment, if any, shall be provided by BHEL / its client free of hire charges. However contractor has to take proper care of the equipment issued to him.
- 17.43 It is possible that due to any reason the final supporting may not be completed before conducting Hydraulic Test. The contractor may have to strengthen or install any additional supports as per instruction of BHEL. This work is a part of the work and no additional payment shall be made on this account.
- 17.44 All the shafts of the equipment shall have to be properly aligned to that of matching equipment to perfection, accuracy as required and the equipment shall be free from excessive vibration so as to avoid over-heating of bearings or other conditions, which may tend to shorten the life of the equipment. All bearings, shafts and other rotating parts shall be thoroughly cleaned and lubricated as per recommendations of BHEL engineer.
- 17.45 Lubricating oil units of the rotating machines are to be cleaned thoroughly before pouring of final lubricating oil. Topping up of lubricants during running of the set till handing over to be done by the vendor. Required lubricants both for first filling and topping up are to be supplied by BHEL free of cost. The empty containers of the lubricating oils should be returned to BHEL stores/place indicated by BHEL from time to time.
- 17.46 The instruction of the motor manufacturer regarding storage of the motors and re conservation must be strictly followed without any deviation.
- 17.47 It shall be the responsibility of contractor to attend all punch points post commissioning and resolve the deficiency as may be necessary for handing over the unit to BHEL's Client.

The scope of the work will comprise of but not limited to the following:

18 PAINTING

ACC structures/ components shall be supplied from BHEL units/ workshops with finish coats of paint, however in some equipment & component finish coat shall be done at site in line with attached Painting schedule as additional annexures. Touch up painting (wherever required) and finish painting, shall be in the scope of the contactor, including supply of the required paints and primers and associated consumables.

In case any shop painted structure/component is required to be repainted due to the reasons <u>attributable to the contractor</u> such as Mis-handling, damage during erection process, other reasons incidental to the work etc, such re-painting/finish painting of the components/structures shall be in the scope of the contractor including the supply of paints and primers along with all required consumables & deployment of tools e.g wire brush, paint brush, Spray M/c, cleaning agents etc.

Contractor shall carry out surface preparation and touchup painting/finish work as per BHEL/Customer specification and instruction of BHEL engineer at site.

- **18.1** Paints and painting work carried at site shall confirm to the following codes and standards:
- IS:5 Colour for ready mixed paints and enamels
- IS: 101 Part 1 to 9 Methods of sampling and test for paints, varnishes and related products
- IS: 1477 Part I&II Code of practice for painting of ferrous metals in building
- IS: 2932 Specifications for enamel, synthetic and exterior,
 - a) Under Coating
 - b) Finishing

IS: 9407 – Colour code for identification of pipelines used in thermal power plants.

Contractor shall satisfy himself, availability of all information in the specifications for proper selection of the paints and ensure their applications as per Codes.

18.2 Primer Painting: (wherever applicable incidental to touchup painting & preventive **painting)**

- a) After surface preparation, two coats of **epoxy resin based zinc primer** shall be applied. Dry film thickness of each coat shall be as per the recommendations of primer/paint manufacturer. Primer shall be applied by either spraying or bushing ensuring a continuous film without "holidays". Primer coat shall be immediately applied without any time lag after the surface preparation.
- b) Any equipment shall be carefully examined and where ever the primer coat is damaged shall be recoated with primer. However, over the field welds, bolts and nuts etc. two primer coats as per a) shall be applied.

18.3 Finish Painting

- a) After the primer coat has dried out, the surface shall be cleaned of dust without scratching or in any way damaging the primer coat. Over this, dry surface finish painting shall be carried out.
- b) Finish painting shall be carried out in two coats. Dry film thickness of each coat shall be as per the recommendation of the primer/paint manufacturer. Minimum thickness including primer and paint coating shall be as per specification.
- c) Paint shall be applied either by brushing or spraying. It shall be ensured that brush marks are a minimum and the requirements of workmanship are as specified in IS: 1477 (for site painting works on systems, structures and components).
- d) Paint used shall be stirred frequently to keep the pigment in suspension. Paint shall be of ready mixed type in original sealed containers as packed by the paint manufacturer. Addition of thinners shall not be permitted.
- e) No painting shall be done in frost/foggy weather or when the humidity is high enough to cause condensation on the surface to be painted. Paint shall not be applied when the temperature of the surface to be painted is 5° C or below.

18.4 Touch-up painting on damaged areas -

a) For coatings damaged up to metal surface

Surface preparation shall be carried out by manual cleaning. Minimum 6 inches adjoining area with existing coating shall be roughened by wire brushing, emery paper rubbing etc., for best adhesion of patch primer. Primer coat of touch-up primer has to be applied by brush immediately after the surface preparation.

Over this primer coat, finish coat and final finish coat shall be applied as covered above by brush within maximum seven (7) days of application of touch up primer.

- Painting of welded areas / painting of areas exposed after removal of temporary supports / touch-up painting on damaged areas of employer's structures, where inter-connection, welding / modification etc. has been carried out by the bidder. Clean the surface to remove flux spatters and loose rust, loose coatings in the adjoining areas of weld seams by wire brush and emery paper. (Painting procedure to be followed for touch-up painting on damaged areas.
- 18.6 The scope of work includes touchup painting, finish paint and colour bands, lettering, marking and signs for direction of flow/rotation, names etc of approved colours as per the standard colour codes and specifications specified in tender specification or as advised by BHEL/Customer engineer at site for the equipments / components covered in these specifications.
- **18.7** In certain isolated instances where it is not possible to clean the equipments as explained above, cleaning by grinding might have to be resorted to. No damage to the equipment/components should be caused.
- **18.8** Surface to be painted should be free of oil and grease. It should be removed by using suitable cleaning agents including permitted solvents. Surface cleaned by chemical agent, if required, shall be treated further as prescribed in use of such cleaning agents.
- 18.9 During the preparation of surface, if the shop coat is damage by chemical cleaning or by mechanical means, contractor shall repair the same free of cost.
- **18.10** Specified drying time shall be permitted from one to another coat.
- **18.11** This work requires working at higher altitudes from ground level to as high as 50 mtr and more. The work spread is also substantial involving substantial run of structures and piping. Contractor shall take sufficient precautions to avoid any accident and hazard in all respects. The ropes, ladders, scaffolding materials, clamps etc and climber used should be of standard quality for safe and smooth execution of work.
- **18.12** Contractor shall carry out the work in such a way that other erected equipment, structure, civil foundations and other property are not damaged. For damages in any of such cases due to lapses by Contractor, BHEL shall have the right to recover the cost of such damages from the Contractor.
- **18.13** Contractor shall take due care to cover/protect the equipment which are already painted while carrying out the painting of other adjacent equipment. If so happens, it shall be cleaned and repainted by the Contractor without any extra charges.
- **18.14** In general, painting of structural parts and colour bands, lettering, marking of direction of flow/rotation etc will be carried out by brush painting. However, areas/equipments inaccessible for manual painting have to be painted by spray

painting. The decision of BHEL engineer, in this regard, shall be final and binding on the Contractor. Laying of air hose pipe and any other line required shall be done by Contractor at his cost.

- **18.15** Final painting work shall be started after obtaining clearance from BHEL engineers and as per his instructions.
- **18.16** Acceptance of Final Painting for required thickness shall be as per the thickness measured by Elcometer by PVUNL/BHEL Engineer. Contractor shall have to carry out painting till the required thickness is achieved.
- 18.17 Certain equipment like control panels etc shall require spray painting. The contractor shall make arrangements of the required equipment for spray painting of such equipment at his own cost. Spray painting at the job site shall be permitted only at times and locations approved by the owner/ Engineer.
- **18.18** Painting two coats of bituminous paint on Insulation cladding sheet inner surface.

PAINTING SCHEME: Attached as File titled "Painting Schedule" (Annexure-3)

The scope of the work will comprise of but not limited to the following:

19 APPLICATION OF INSULATION AND REFRACTORY

- 19.1 Handling at site stores / storage yard, Transportation to site of work, Application of Insulation materials, using their own tools plants, tackles, all consumables, supervisor and men as enumerated in the scope of contract at ACC Erection & Commissioning etc.
- 19.2 Application of wool insulation, sheet metal cladding, welding of hooks / supports to hold insulation and refractory's as wherever necessary for all the equipment covered in this contract are to be carried out as per instruction of BHEL Engineer at site. The systems cover under this contract including but are not limited to the following.
- 19.3 The work shall conform to dimensions and tolerances given in various drawings and quality manuals provided by BHEL. If any portion of work is found to be defective in workmanship not conforming to drawings or other stipulations, the contractor shall dismantle and redo the work duly replacing the defective materials at his cost, failing which the job will be carried out by BHEL by engaging other agencies / departmentally and recoveries will be effected from contractor's bill towards expenditure incurred including BHEL's overhead charges.
- 19.4 All insulations materials including iron components and other sheets casing materials, etc., required as per drawing will be supplied by BHEL and the same have to be erected / applied as per the drawings and specifications of BHEL by the contractor.
- 19.5 Clean the Surface to be Insulated from Rust, Dust, Grease, Loose scale, Oil, Moisture, etc. Care shall be taken that flexible insulation is not unduly compressed. After insulating the equipment, the gaps / joints shall be filled with loose wool/ moulded insulation as applicable
- 19.6 Painting of inner side of sheet metal covering over the insulation walls with two coats of anti-corrosive paint (IS-158) to be applied to the entire satisfaction of BHEL Engineer and application of bituminous sealing compound on cladding/ sheet metal joints shall also be carried out by the contractor. Retainer type 'A' must be coated with Aluminium paint. For which the required amount of paint, thinner and other accessories for painting, cleaning the surfaces etc., shall be supplied by the contractor within the quoted rate.
- 19.7 It is the responsibility of the contractor to ensure that the insulation materials and sheet metal covering issued to him for application are well protected against loss or damage or weather conditions tending to affect its quality by the provision of close / semi closed sheds at his cost. All the insulation materials and sheet metal covering etc., issued to the contractor shall be properly stored and handled before application

due the same. If any damage occurs to the materials due to improper storage or due to any causes attributable to the contractor except for normal breakage or damaged material shall be to the cost of the contractor.

- 19.8 Contractor is liable for the exact accounting of the materials issued to him and any unaccountable losses shall be made good by him. The necessary accounting of the material issued will have to be furnished by the contractor periodically
- 19.9 The contractor shall provide the required quantity of wire, nails and other materials for centering works at their cost.
- 19.10 Removal type of insulation to be provided for valves fittings, expansion joints etc., as per the drawings or as directed by BHEL Engineer.
- 19.11 All piping insulations shall be carried out in such a manner as to facilitate removal of bolts nuts and washers from the flanges.
- 19.12 Fabrication of covering sheets may be necessary like preparing the sheets to the sizes and shapes specified in drawings, beading, swaging, beveling of sheets crowning of the sheets if necessary the same to supports over wool insulation with screws as specified in BHEL drawings or as instructed by BHEL engineer.
- 19.13 Fabrication, fixing or welding of hooks / supports to equipment of ACC, piping and other connected equipments to support wool insulation applying of primer paint to welded portion parts welding.
- 19.14 Cladding sheets shall be suitably pressed along with diagonals to form diamond shape so as to improve the strength of the sheets, to avoid humpiness and to give aesthetic look.
- 19.15 Plates, bars, rods and other materials that are to be cut, and re-welded from the fabricated places to suit erection requirements for which no extra payment will be made to the contractor.
- 19.16 A log book shall be maintained by the contractor for the clearance of the area for application of insulation. If the contractor does the work on his own accord without prior permission the area should be redone at his cost.
- 19.17 The contractor shall draw only one week's requirement of material for their work from BHEL stores and keep them in their semi-closed shed near to the work area. The materials required for a particular space of work only shall be taken to the work spot. At the end of the day's work the leftover or unused materials shall be taken back to their semi-closed shed for keeping the materials safe. Necessary records shall have to

be maintained by the contractor in respect of the above drawls / deposits, on daily basis as instructed by BHEL.

- 19.18 Wastages allowance for the materials issued are envisaged as follows:
 - c) Wool mattresses 2%
 - d) Cladding sheets 3 %
- 19.19 Upon completion of daily work, the contractor shall remove from the vicinity of work all scrap packing materials rubbish, unused and other materials and deposit them in places to be specified by BHEL Engineer. Also, the contractor will demolish all the hutments, sheds, offices, constructed by him and shall clean the debris after the contract is over. In the event of his failure to do so, the same will be arranged / removed by BHEL Engineer and the expenses incurred with overhead will be recovered from the contractors.
- 19.20 Welding of hooks as per pitch, applying red oxide paint to the welded portion as directed as per drawings before application of mineral wool mattresses will have to be done by the contractor.
- 19.21 Applying different layers of mineral wool as directed and as per drawings and specifications for ACC and its auxiliaries, pipelines valves and other vessels and after fixing require holdings materials, suitably if necessary, fabrication of rings etc., and fixing as directed and as per drawings and specifications shall also form part of this work.
- 19.22 If necessary the hooks may have to be made from the rods, raw materials supplied in running lengths. The contractor may have to carry out this work also and use the same hooks.
- 19.23 In case the contractor is required to dismantle and re-erect certain area as and when required for pre-commissioning / commissioning activities the rate as indicated in the rate schedule shall be paid by BHEL for erection. However, for dismantling no extra charge will be paid under any circumstances.
- 19.24 Wherever additional / clamps, frame works, etc., are required to be fabricated and installed even though not indicated in the drawings shall be fabricated and installed at their cost. Only steel materials shall be given by BHEL free of cost, consumables like electrodes, gases etc., are to arranged by the contractor at his cost.
- 19.25 Contractor has to arrange required fire retardant covering material at their cost to protect the insulation materials drawn from BHEL before and after erection.
- 19.26 The contractor shall provide any fixtures, concrete blocks / wooden sleepers, etc., which are required for temporary supporting of the insulation materials at site.

- 19.27 Delay in clearance of mechanical equipment and piping for insulations is unlikely to happen. However, if any delay occurs, the contractor shall not claim anything extra, like idle charges.
- 19.28 Welding of iron components directly on taks, Pipes, ducts is are to be carried out by certified high pressure welders.
- 19.29 Application of insulation and removal of the same for temporary piping under scope of erection of this contract is also included in the scope of the work. However, BHEL will supply the insulation materials free of cost.
- 19.30 Dressing of insulation to suit site conditions, sheet cladding over insulations, form the part of this work.
- 19.31 The temporary structures / items welded to permanent members / pipes are to be cut and removed without any damage. Any damage so to permanent members / pipes to be made good by the contractor at his cost.
- 19.32 The contractor will have to follow the instructions provided in the technical manuals, drawings, and specifications provided by BHEL, to the contractor from time to time. In case of ambiguity or deviation the decision / clarification of BHEL Engineer will have to be followed.
- 19.33 All rectification including painting of Employer's structure which are damaged by contractor during his work.
- 19.34 The Contractor shall provide all the necessary scaffolding materials, temporary structures and necessary safety devices etc, during all stages of work. Scaffolding materials (poles, gratings etc) shall be of light weight construction. Contractor shall arrange steel pipes & clamps with accessories like base plate attachment, fixing pins, struts etc for scaffolding required for this work. However, BHEL's decision in this regard shall be final and binding. Contractor shall arrange the scaffolding materials in sufficient quantity.

The Contractor shall provide the required quantity of wire, nails, and planks for formwork and other materials for shuttering and curing works.

19.35 All attachment welding, including welding of hooks / supports as per pitch both on equipment and piping shall be done as directed by Engineer. Attachment welding shall have to be done by certified welders. If necessary contractor may have to cut the hooks to correct length. Application of red oxide paint including supply of paint on welded portions as directed by BHEL is also included in scope of work.

- 19.36 The number of layers / thickness of mineral wool / LRB mattresses for auxiliaries, pipe lines, valves and other vessels shall be as per various drawings and as directed by Engineer. For applying the mineral wool mattress, the required holding materials, if necessary by fabrication of rings/ hooks shall be fixed as directed and as per drawings and spec.
- 19.37 The contractor should ensure, proper finishing of surface of the insulation, sheeting and cementing.
- 19.38 The contractor should ensure that the finished surface of the insulation works conforms to the dimensions and tolerances given in the drawings. Aesthetic finish and accuracy of work are most important.
- 19.39 It is the responsibility of the contractor to ensure that the insulation materials and sheet metal covering issued to him for application are well protected against loss or damage from weather conditions. Closed / semi closed sheds or any other arrangements required for this will by him at his cost. If any damage occurs to the material due to improper storage or due to any causes attributable to the contractor except for normal breakage or damages allowed in such cases, the cost of such damaged material shall be to the account of the contractor.
- 19.40 Aluminum sheet cladding will be fabricated to the sizes and shapes specified in drawings. Beading, swaging, beveling of sheets, crowning the sheets if necessary will be carried out by him. Two coats of anti-corrosive black bituminous paint are to be applied on inner surfaces of the cladding. Bitumen sealing compound on the joints if necessary is included in the scope of this work. Contractor may note that he will also supply anti-corrosive black bituminous paint & bituminous sealing compound required for above works at his cost. However, if supply by the BHEL MUs same will be issue free of charges to contractor.
- 19.41 Aluminum sheet metal cladding over insulation will consists of plain / ribbed / corrugated sheets. The sheets will be supplied in standard sizes. Cutting them to required size, grooving, fabricating bends, boxes etc., for proper covering is contractors responsibility. Any cutting / bending / welding of fabricated skin casing sheets if required will also covered within the scope of this contract.
- 19.42 A logbook shall be maintained by the contractor to obtain clearance for application of insulation. If the contractor does the work on his own accord without prior permission the area may have to be redone at his cost.
- 19.43 The work shall conform to dimension and tolerances specified in the various drawing and documents that will be provided during the execution. if any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the Contractor shall dismantle and re-do the work duly replacing

the defective materials at his cost, failing which the work will be got done by engaging other agencies or departmentally and recoveries will be deducted from Contractor's bills towards expenditure incurred including applicable departmental charges.

- 19.44 All insulation and refractory materials including iron components and outer sheet casing materials, cladding sheets etc required will be supplied by BHEL and the same have to be erected/ applied as per the drawings and specifications of BHEL by the Contractor.
- 19.45 Wool insulation is received at site as loose bonded mattresses in standard sizes. These are to be dressed/cut to suite the equipments. Multiple layers of wool have to be applied as directed and as per drawings and specifications for all equipments/ systems covered under the scope of work.
- 19.46 The cladding and outer casing are aluminium sheets. All relevant specifications and procedures with regards to beading, sealing etc for aluminium sheets have to be adhered to.
- 19.47 To take care of bimetal corrosion due to variety of metals in contact of each other viz retainer to support, support to outer casing/cladding, cladding-to-cladding etc, suitable paints specified by BHEL, to be applied and/or neoprene rubber packing/strips or any other insert may have to be fixed as required.
- 19.48 The Contractor shall leave certain gaps and openings while doing the work as per the instructions of BHEL Engineer to facilitate inspection during commissioning to fix gauges, fittings, instruments etc. these gaps will have to be finished as per drawings at later date by the Contractor at his cost.
- 19.49 Contractor shall cut open works in needed as per BHEL Engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over without any extra payment.
- 19.50 If during erection and commissioning any of the parts are to be insulated temporarily fixed and then replaced by permanent ones at a later date or if any of the parts are to be removed for modification, rectification, adjustment and then refitted or if some parts are to be opened for inspection and checking and for measurement of metal surface temperature the same may necessitate removal and re-application of insulation and sheet metal cladding, which shall be done by the contractor and the erection rate quoted shall be inclusive of such contingencies.
- 19.51 Removable type of insulation shall be provided for valves, fittings, expansion joints etc as per the drawings or as directed by BHEL Engineer.

19.52	All	temporary	pipelines	required	during	testing,	pre-commissioning	and
	com	missioning s	hould be in	ısulated as	directed	by BHEL	at no extra cost to B	HEL.
	Hov	vever, require	ed insulatio	n material s	shall be is	sued by E	BHEL free of cost.	

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XX: PRESERVATION & PROTECTION OF COMPONENTS

20 PRESERVATION & PROTECTION OF COMPONENTS

- 20.1 At all stages of work, equipments/materials in the custody of Contractor, including those erected, will have to be preserved as per the instructions of BHEL. Necessary preservation agents including the primer & paint, for the above work shall be provided by the Contractor.
- 20.2 The Contractor shall make suitable security arrangements including employment of security personnel and ensure protection of all materials/ equipment in their custody and installed equipments from theft/fire/pilferage and any other damages and losses.
- 20.3 Contractor shall collect all scrap materials periodically from various area of work site, deposit the same at one place earmarked at site or shift the same to a place earmarked in BHEL/ client's stores. In case of failure of Contractor in compliance of this requirement, BHEL will make suitable arrangement at Contractor's risk and cost.
- 20.4 The entire surplus, damaged, unused materials, packaging materials / containers, special transporting frames, gunny bags, etc shall be returned to BHEL stores by the Contractor.
- 20.5 The Contractor shall not waste any materials issued to him. In case it is observed at any stage that the wastage/excess utilisation of materials is not within the permissible limits, recovery for the excess quantity used or wasted will be effected with departmental charges from the Contractor. Decision of BHEL on this will be final and binding on the Contractor.
- 20.6 For any class of work for which no specifications have been laid down in these specifications, work shall be executed as per the instructions of BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XXI: Welding Schedule

Final Welding Schedule of Patratu Project shall be made available during Erection. Attached WPS (Annexure-7) is for reference purpose only.				

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XXII: Weightages / Factor

The scope of work under this contract covers Erection, Testing & Commissioning of Air Cooled Condenser (ACC) and associated auxiliaries, which includes material receipt from store, transportation to site, erection, testing, commissioning, trial run, handing over etc, as required, for total scope defined in this specifications along with other document of complete work of erection & commissioning of Air Cooled Condenser covering Structures, finned tube bundles, Steam Distribution manifold, Axial Fan system, Wind wall structures, Elevators, Air Removal system, Condensate System, Steam Ducting, Draining System, Cleaning System, Lifting devices, Insulation, Finish Painting etc. with required Structures, platforms, stairs, Hoist and Chain Pulley Blocks, EOT cranes, temporary passenger elevators etc. of Unit#2 at 3x800 MW PVUNL STPP, Patratu.

SECTION 1: Contract/ ACC U#2 Package

SN	Contract (ACC#2 Package)	Rate schedule Identifier	QTY	UOM	Weightage/ Factor "X"
1.1	Foundation & Structures etc. (GR-I)	GR-I	8,813	MT	0.648724658425
1.2	Rotating Machine & misc. eqp. (GR-II)	GR-II	1,075	MT	0.057335782570
1.3	Ducting &Piping all type (III)	GR-III	1,643	MT	0.281318829116
1.4	NIL (GR-IV)	GR-IV	0		
1.5	Insulation (Gr-V)	GR-V	104	MT	0.006985879819
1.6	Lifting Device (GR-VI)	GR-VI			
1.6.1	Chain Hoist	GR-VI	8	Set	0.002096686493
16.2	Electrical hoist (to be ins. Fan deck level)	GR-VI	1	Set	0.000524177960
1.6.3	EOT crane for Vacuum pump	GR-VI	1	Set	0.001572518821
1.6.4	EOT for drain pump	GR-VI	1	Set	0.001048340861
1.7	PROVIDING PG TEST ASSISTANCE	GR-VI	LUMPSUM	-	0.000393125935

Note: The quantity indicated in the BOQ is approximate only and is liable for variation. Payment will be as per actual quantity executed as certified by BHEL Engineer above Unit rate of individual items of BOQ.

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XXII: Weightages / Factor

Instructions to the bidders

- 1. <u>Bidders shall quote Total Lump-sum Price for the entire scope of work in</u> **Rupees in VOL II PRICE BID at BHEL E-procurement Portal.** Any other entry elsewhere in the offer of the bidder shall be treated as Null and Void.
- 2. This Total Lump-sum Price is bifurcated in Section 1 (E&C of ACC) based on the BHEL fixed percentage weightages w.r.t the total Total Lump-sum Price quoted by the bidder for the subject tender.
- 3. BHEL has pre-fixed the Weightage/Factor as detailed above in this chapter for deriving the Unit Rates. By multiplying BHEL pre-fixed the Weightages / Factor and the total prices derived in sl no. 2 above; unit rate of individual items shall be derived. Unit Rate/Item Rate thus arrived shall be rounded off to two decimal places.
- 4. Based on the quantities of individual item and the item rates arrived in Sl No 3 above, the total amount for individual items shall be derived. Total amount thus derived shall be rounded off to two decimal places.
- 5. Grand Total amount for the work shall be derived by BHEL by summing up respective total amounts. The Grand total amount thus derived shall be considered for award of the work.
- 6. Bidders to note that this is an item rate contract. Payment shall be made for the actual quantities of work executed at the unit rate arrived at as per Sl No.3 above.
- 7. For the convenience of bidders, BHEL shall issue an excel sheet with all the requisite formulae as described above. *However, the referred excel sheet shall not form part of contract document. Further, this sheet should not be uploaded at the e-Portal.*

TECHNICAL CONDITIONS OF CONTRACT (TCC) Chapter-XXIII: Technical Annexure

THIS TENDER SPECIFICATION CONSISTS OF FOLLWING ANNEXURE:

S.N.	DESCRIPTION
Annexure-1	T&P Hire Charges
Annexure-2	Approved Vendor List
Annexure-3	Painting Schedule
Annexure-4	FQP for Erection
Annexure-5	HSE Plan
Annexure-6	Technical Specification – NTPC
Annexure-7	WPS

NOTE- ALL THE ABOVE-MENTIONED ANNEXURE ARE UPLOADED ON PROCUREMENT PORTAL