

To

ALL BIDDERS

Sub: Corrigendum-03: Amendment to Appendix-I-VOL-IA-TCC-Detailed Technical Specification-Part A

IOB: Supply, Erection & Commissioning items for the illumination and minor electrical works for Safety Park at 3x800 MW Patratu TPP, Patratu, Jharkhand in line with the attached drawings on 'F.O.R.' Destination basis.

Ref:

1. Tender Enquiry Number: 2006032 dtd 24-08-2020
2. Corrigendum - 01 dated 03-09-2020 for Tender due date extension
3. Corrigendum - 02 dated 10-09-2020 for Tender due date extension

Bidders to kindly take note of the following:

AA) Amendment to TCC:

S. No.	Reference /clause No.	Existing Specification	Addition in Specification
1.	Part -A: Supply Items Item with Sr. No. 6,7,8 & 9 Receptacles	6. Receptacle - 5/15A DECORATIVE 7. Receptacle - 20A INDUSTRIAL 8. Receptacle - 20A INDUSTRIAL FOR AC Nos. 11 9. Receptacle - 63A, 3PHASE INDUSTRIAL	Female portion of receptacles with switch/MCB (as per rating) is required.
2.	Part -A: Supply Items Item with Sr. No. 12 &13	12. SWITCHBOARD WITH 03 NOS. 5A SWITCH & 01 NO. FAN REGULATOR 13. SWITCHBOARD WITH 04 NOS. 5A SWITCH & 06 NO. FAN REGULATOR	Switch board required for toilet and class room shall be modular for rest of building normal switch board shall be used.

3.	Part –A: Supply Items Item with Sr. No. 14	14. AC NORMAL LIGHTING PANEL WITH 18 OUTGOINGS (INDOOR TYPE)	Incomer: 3 phase, 4 pole (min – 125 A) rotary switch with fuse. A timer for timed operation, 18 no. RCCB (min – 20 A single phase) with 30 mA sensitivity.
4.	Part –A: Supply Items Item with Sr. No. 15	15. JUNCTION BOX	Junction box Size: 200 X 150 mm, 2 – way connector (4 no.) Material: Galvanized Iron with 4 side opening.

BB) Revised Price Bid:

Please refer Vol-II - PRICE BID Rev 01 for the Revised Price Bid.

CC) Extension of Last date:

The last date for submission of Tender has been rescheduled to 21-09-2020, 15:00 hrs. Technical Bid shall be opened on 21-09-2020, 15:15 hrs.

DD) General Clarification (Important):

Please note that old Vol-II, Price bid is non-functional & New 'Vol-II price bid Rev-01' has been uploaded on E-Procurement Portal. Offer of the bidder who had already submitted the bid will be deleted and thus those bidder has to resubmit the offer through E-Procurement Portal.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → www.bhel.abcpurchase.com

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,

Yours faithfully,

AGM (Purchase)