

Acceptable Makes and Models of the Testing Instruments

From: Prateekkumar [<mailto:pkp@bhel.in>]

Sent: 06 July 2017 10:12 **To:** 'VYOM'

Subject: FW: Make & model of different testing instruments

As discussed, make & model approved by POWERGRID enclosed.

Regards,

From: Mahesh [<mailto:maheshkumar@bhel.in>]

Sent: 26 August 2016 14:10

To: 'Prateek'

Subject: FW: Make & model of different testing instruments

From: Anurag Arora {अनुराग अरोड़ा} [<mailto:anurag.arora@powergridindia.com>]

Sent: 26 August 2016 12:53

To: maheshkumar@bhel.in; pkp@bhel.in

Cc: Mukesh Mathur {मुकेश माथुर}; Rakesh Kumar {राकेश कुमार}; Rajesh Wadhwa {आर. वाधवा}; Jivesh Khanna {जीवेश खन्ना}

Subject: Make & model of different testing instruments

Your ref : TBEM /UPPTCL/Agra /TA -222/1 dt 06.08.16

Project : 765 /400 kV Fatehabad

Dear Sir ,

This has reference to your above letter and request for make & model of different testing instruments to be supplied under LOA ref No CC-CS /494 –NR 1/ SS -2546/3/G3/NOA-1/5163 & 5164.

We have discussed the matter with our Asset Management Department and following make and model may be considered subject to meeting the POWERGRID Specification and approval of Model by Engineering department of POWERGRID :

Sr no	Name of the kit	Make	Model No
1.	Primary Injection kit 3000A	EURO –SMC	RAPTOR C-35
		Megger	ODEN AT /2H
2.	SF 6 Leak Detector	WIKA	GIR10
		DILO	3-033-R002
3	SF 6 Handling Plant	WIKA	GFU20
		DILO	PICCOLO B052R33
4.	Relay Test Kit	Megger	SMRT 410
		Doble	F6150
		Omicron	CMC 356

This is for your information and further necessary action please .

With Best Regards,

ANURAG ARORA

Manager (QA&I)

Power Grid Corporation of India Ltd

Mobile: +919423762548

-----XXX-----