

EPC PACKAGE FOR LARA SUPER THERMAL POWER PROJECT, STAGE-II (2x800 MW)
Amendment No. 04 to Technical Specifications Section-VI of Bidding Document No.: CS-9587-001R-2

S. No.	SPECIFICATION REFERENCE				Instead of			Read as		
	Section / Part	Sub-Section	Clause No.	Page No.						
TG3-01	VI/A	IA	3.1 Sl. No. (j) Condensate Extraction Pumps (CEP)	3 of 36	Name of equipment	Type of equipment	Equipment rating	Name of equipment	Type of equipment	Equipment rating
					Condensate Extraction Pumps (CEP)	Vertical, cannister with double suction first stage impeller for steam turbine generator sets	Capacity not less than 1025 Ton/ hr and total developed Head not less than 30 Kg/cm2 OR Capacity not less than 880 Ton/ hr (in case drip pumps are used) and total developed Head not less than 30 Kg/cm2	Condensate Extraction Pumps (CEP)	Vertical, cannister with double suction first stage impeller for steam turbine generator sets	Condensate Extraction Pump (CEP) rating not less than that supplied for minimum 660 MW size Steam Turbine Generator Unit

Doc. No.: CS-9587-001R-2-TECH AMDT- 04	LARA SUPER THERMAL POWER PROJECT STAGE-II (2X800 MW)	Amendment No. 04 to Technical Specifications Section-VI
--	--	---

EPC PACKAGE FOR LARA SUPER THERMAL POWER PROJECT, STAGE-II (2x800 MW)
Amendment No. 04 to Technical Specifications Section-VI of Bidding Document No.: CS-9587-001R-2

S. No.	SPECIFICATION REFERENCE				Instead of			Read as		
	Section / Part	Sub-Section	Clause No.	Page No.						
TG3-02	VI/A	IA	3.1 Sl. No. (o) Boiler Feed Pumps (BFP)	3 of 36	Name of equipment	Type of equipment	Equipment rating	Name of equipment	Type of equipment	Equipment rating
					Boiler Feed Pumps (BFP)	Horizontal, centrifugal, multistage, outer casing barrel type with end rotor removal for supercritical steam turbine generator sets	Capacity not less than 1250 Ton/ hr and total developed Head not less than 320Kg/cm2	Boiler Feed Pumps (BFP)	Horizontal, centrifugal, multistage, outer casing barrel type with end rotor removal for supercritical steam turbine generator sets	Boiler Feed Pump (BFP) rating not less than that supplied for minimum 660 MW size Super-critical Steam Turbine Generator Unit
TG3-03	VI/A	Attachment-3K for D. BOILER FEED PUMPS Page 185 of 401			-----			New clause added: 1.15.00 Steam parameters at Turbine inlet (Main Steam Pressure(kg/cm2 (abs.)) /Main Steam Temperature(Deg. C)/ Hot Reheat Steam Temperature(Deg. C)) : -----		

Doc. No.: CS-9587-001R-2-TECH AMDT- 04	LARA SUPER THERMAL POWER PROJECT STAGE-II (2X800 MW)	Amendment No. 04 to Technical Specifications Section-VI
--	--	---

EPC PACKAGE FOR LARA SUPER THERMAL POWER PROJECT, STAGE-II (2x800 MW)
Amendment No. 04 to Technical Specifications Section-VI of Bidding Document No.: CS-9587-001R-2

S. No.	SPECIFICATION REFERENCE				Instead of	Read as
	Section / Part	Sub-Section	Clause No.	Page No.		
QA-01	VI/B	E-12	1.00.00 (5)	3 of 4	Visual Cavitation Test on one first stage production impeller of Boiler Feed Pump shall be carried out to demonstrate absence of Cavitation at Design Speed in Cold Water. The test will establish the cavitation characteristic of one production first stage impeller to confirm that the cavity length under dynamically scaled site conditions corresponding to design point will not exceed an agreed size. This test shall be carried out at 25%, 50%,65%,80%,100% and 125% of Design Flow.	Deleted

Doc. No.: CS-9587-001R-2-TECH AMDT- 04	LARA SUPER THERMAL POWER PROJECT STAGE-II (2X800 MW)	Amendment No. 04 to Technical Specifications Section-VI
--	---	--