

Sl.No	Annexure-I : Provenness Criteria and/or Qualification Requirement	Bidder response
1	Slurry Pumps for the Wet Limestone based Flue Gas Desulphurization (FGD) system offered by the bidder shall be only from such manufacturer(s) who has previously designed (either by itself or under collaboration/licensing agreement) ,manufactured or got manufactured the respective equipments of the type ,application and minimum equipment rating as stipulated below such that the respective equipment(s) should have been in successful operation in at least one (1) plant for a period not less than one (1) year reckoned as on the date of consideration for approval but not later than 31.01.2019	
2	Name of Equipment : Slurry Pumps	
3	Type of Equipment : Centrifugal Type	
4	Application: Wet Limestone based FGD application or ash slurry application in coal fired power plant	
5	Equipment rating : 80% of the flow and 100% of the head of the offered slurry pumps.	
6	Bidder shall offer and supply only the type of above equipment (s) for which he himself or the manufacturer proposed by the bidder for the above equipment(s) is qualified.	
7	Necessary documentary evidences as per 3K for qualification shall be submitted along with this bid.	
8	Specific conformation to clause 4.00.00 of Annexure-I Qualification Requirement/Provenness Criteria	
9	Specific conformation to clause 4.01.01 of Annexure-I Qualification Requirement/Provenness Criteria	
10	Specific conformation to clause 4.01.02 of Annexure-I Qualification Requirement/Provenness Criteria	
11	Specific conformation to clause 4.01.04 of Annexure-I Qualification Requirement/Provenness Criteria	

12	Specific conformation to clause 4.01.08 of Annexure-I Qualification Requirement/Provenness Criteria	
13	Specific conformation to clause 4.01.09 of Annexure-I Qualification Requirement/Provenness Criteria	
14	Specific conformation to clause 4.01.10 of Annexure-I Qualification Requirement/Provenness Criteria	
15	Specific conformation to clause 4.01.11 of Annexure-I Qualification Requirement/Provenness Criteria	
16	Conformation to all the points of ATTACHMENT 3K documents, Filled in, Signed, Official Seal Affixed in all pages and shall be submitted the document ATTACHMENT 3K IN PART - I BID . This is mandatory to evaluate your offer for further processing.	