




COPY RIGHT AND CONFIDENTIAL
The information on this drawing is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of the company.

COMPUTER FILE NAME: ---

REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD
04	01.10.2020	DK	MKG/SB	SKB	01	13.12.19	MKG	JPSB	SKB	02	19.8.2020	DK	MKG/SB	SKB
Revised as per TCE comments received vide transmittal no. TCE.11005A-ME-VDT-440 dated 03/SEP/2020					Revised as per TCE comments received vide transmittal ref no. TCE.11005A-ME-VDT-348 dated 17/10/2019					Revised as per TCE comments received vide transmittal no. TCE.11005A-ME-VDT-383 dated 20/FEB/2020.				

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	











417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
417		CONTRACT	
417		CONTRACT	

417		CONTRACT	
-----	--	----------	--



REFERENCE DRGS:			
SL NO	TITLE	DRG. NUMBER	UNIT
1	PLAT PLAN	PE-DG-417-100-M001	PEM
2	P & ID CONDENSATE TRANSFER SYSTEM	PE-DG-417-100-M108	PEM
3	P & ID DM MAKE UP WATER SYSTEM	PE-DG-417-100-M110	PEM
4	GA OF DM TRANSFER PUMP	PE-V7-417-100-300X	PEM / VENDOR
5	GA OF STRAINER	PE-V7-417-100-300X	PEM / VENDOR
6	PIPE SCHEDULE	PE-DG-417-100-M121	PEM
7	DM STORAGE TANK	PE-DG-417-100-M001	PEM / VENDOR

NOTES:

- ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE NOTED.
- ALL ELEVATIONS ARE MARKED W.R.T. T.O. HALL FINISHED FLOOR LEVEL AS +0.0M WHICH CORRESPONDS TO RL +81.8M.
- DESIGN PARAMETERS:
 - DESIGN PRESSURE FOR DM TRANSFER PUMP DISCHARGE PIPING SHALL BE CORRESPONDING PUMP SHUT OFF HEAD OF THE PUMP.
 - DESIGN MCH. TEMPERATURE = 80° C.
 - STAINLESS STEEL FITTINGS SHALL BE TO ASTM A-403 OF CORRESPONDING PIPE THICKNESS (AS A MIN.) WITH DIMENSIONS TO ANSI B 16.4.
 - COUNTER FLANGES FOR PUMPS, TANKS SHALL BE SUPPLIED ALONG WITH EQUIPMENT. BALANCE COUNTER FLANGES AS APPLICABLE SHALL BE SUPPLIED BY PIPING CENTER.
 - FOR NORMAL MEASUREMENT INSTRUMENT STUDS ARE TO BE AS PER DRG. NO. PE-DG-417-145-M01.
 - UNLESS NOTED OTHERWISE ALL DRAINS & VENTS SHALL BE OF 25NB.
 - DRAINS & VENTS ALONG WITH DRAIN & VENT VALVES SHALL BE PROVIDED AT ALL LOW POINTS AND HIGH POINTS RESPECTIVELY.
 - LOCATION OF VARIOUS STUDS SHALL BE AS PER PIPING CENTER DETAILED DRG.
 - ALL PIPE DETAILS SHALL BE MATCHED WITH FINAL APPROVED DRG. OF P&ID VENDORS FOR ALL BOI LIKE PUMPS, VALVES.
 - STRAINERS ALONG WITH COUNTER FLANGE ARE IN PEM (MSE) SCOPE OF SUPPLY.
 - RACK PIPING IS SHOWN FOR REFERENCE ONLY FOR DETAILING PLEASE REFER RESPECTIVE PIPING AND CABLE RACK DRAWINGS.
 - COMMISSIONING STRAINER INDICATED AT ALL THE PUMP SUCTION AS PER RESPECTIVE P&ID.
 - CONCRETE PEDESTALS, EP & CHANNEL TO BE PROVIDED BY CIVIL.

DM WATER STORAGE TANK NOZZLE SCHEDULE					
SL NO	NOZZLE	SIZE (NB)	ELEVATION	SERVICE	PROJECTION
1	H1	100	5.314	CONDENSATE OUTLET	-
2	N2	150	5.314	SPARE	-
3	N3	100	5.308	DRAIN	-
4	N4	150	18.882	OVERFLOW	-
5	N5	100	18.878	DM WATER INLET	-
6	N6	100	5.314	PUMP RECIRCULATI ON	-
7	N7	100	18.878	SPARE	-

HOLD

- GA OF DM TRANSFER PUMPS
- GA OF STRAINER


REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD

JOB NO. 417
STATUS CONTRACT
DISTRIBUTION

CUSTOMER:		TELANGANA STATE POWER GENERATION CORPORATION LTD TELANGANA INDIA YADADRI TPS (5X800 MW)			
CONSULTANT:		TATA CONSULTING ENGINEERS LIMITED BANGALORE INDIA			
CLIENT:		BHARAT HEAVY ELECTRICALS LTD POWER SECTOR PROJECT ENGINEERING MANAGEMENT NOIDA			
DRAWING NO.		PE-DG-417-100-M041			
SHEET		1 OF 1			

COPYRIGHT AND CONFIDENTIAL					
The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED & must not be used directly or indirectly in any way without the written consent of the company.					
DEPT.	CODE	NAME	SIGN	DATE	
DESIGN				31.10.2018	
CHK				31.10.2018	
APPD				31.10.2018	

TITLE					
LAYOUT OF PIPING IN & AROUND DM TANK & P/H					
DEPT.	SCALE	DRAWING NO.	PE-DG-417-100-M041	REV.	01





\$ COLUMN FROM 0.0 TO ~13.5(BOTTOM OF OIL CANAL)
 # COLUMN UPTO EL:2.5M
 @ COLUMN UPTO BOTTOM OF BFP DECK
 MAX BEAM DEPTH FOR PLATFORM BELOW TG DECK AT
 EL:2.5M TO BE RESTRICTED TO 400MM.

277 of 665 PAGE 11

REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD
04	04.01.2020	DK	MK	BKA	03	18.07.2019	DK	Sd/- DK/BKA	Sd/- SPV	02	18.08.2018	DK	Sd/- DK/BKA	Sd/- JW
1.	DRAWING REVISED INLINE WITH CUSTOMER COMMENTS.				1.	DRAWING REVISED INLINE WITH CUSTOMER COMMENTS.				1.	DRAWING REVISED INLINE WITH CUSTOMER COMMENTS.			
2.	OTHER CHANGES AS MARKED.				2.	OTHER CHANGES AS MARKED.				2.	OTHER CHANGES AS MARKED.			

182327/2021/PS-PEM-MAY :

	SPECIFICATION NO. PE-TS-417-155A-A001	
	SECTION : I	
	SUB-SECTION: IB	
	REV. NO. 00	DATE :

SECTION – I
SPECIFIC TECHNICAL REQUIREMENTS
SUB-SECTION IB - Specific Technical Requirements (Electrical)

	TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT 5X800 MW YADADRI TPS (ELECTRICAL PORTION)	SPECIFICATION NO. VOLUME NO. : II-B SECTION : I REV NO. : 00 DATE: 09/01/2020 SHEET : 4 OF 33
<u>SPECIFIC TECHNICAL REQUIREMENTS: ELECTRICAL</u> 1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER: a) Services and equipment as per “Electrical Scope between BHEL and Vendor”. b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge. c) Supply of mandatory spares as specified in the specifications of mechanical equipment’s. d) Electrical load requirement for CONDENSATE PLOSHING UNIT. e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information. f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer/BHEL approval without any commercial and delivery implications to BHEL. g) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc. shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL. h) Motor shall meet minimum requirement of motor specification. i) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL. j) Cable BOQ worked out based on routing of cable listing provided by the vendor for “both end equipment in vendor’s scope” shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages. 2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS: Refer “Electrical Scope between BHEL and Vendor” Annexure - I. 3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID 3.1 The electrical specification without any deviation from the technical/quality assurance requirements stipulated shall be deemed to be complied by the bidder in case bidder furnishes the overall compliance of package technical specification in the form of compliance certificate/No deviation certificate. 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc., is required during tender stage. Any such submission even if made, shall not be considered as part of offer.		

	TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT 5X800 MW YADADRI TPS (ELECTRICAL PORTION)	SPECIFICATION NO.	
		VOLUME NO. :	II-B
		SECTION :	I
		REV NO. :	00 DATE: 09/01/2020
		SHEET :	5 OF 33

4.0 List of enclosures :

- a) Electrical scope between BHEL & vendor (Annexure –I)
- b) Technical specification for motors.
- c) Datasheets for motors.
- d) Electrical Load data format (Annexure –II)
- e) BHEL cable listing format (Annexure –III)
- f) Quality plan for motors.

282 of 665

182327/2021/PS-PEM-MAX

TITLE

LV MOTORS

DATA SHEET-A

SPECIFICATION NO.

VOLUME II B

SECTION I

REV NO. 00 DATE 09/01/2020

SHEET 18 OF 33

- | | | | |
|------|--|--|---|
| 1.0 | Design ambient temperature | : | 50 °C |
| 2.0 | Maximum acceptable kW rating of LV motor | : | ≤175KW |
| 3.0 | Installation (Indoors/ Outdoors) | : | As required |
| 4.0 | Degree Of Protection (Indoor/Outdoor) | : | IP55 |
| 5.0 | Type of Cooling | : | TEFC/CACA/TETV |
| 6.0 | Details of supply system | | |
| | a) | Rated voltage (with variation) | : 415V ± 10% |
| | b) | Rated frequency (with variation) | : 50 Hz (Variation: +3% TO –5%) |
| | c) | Combined voltage & freq. variation | : 10% |
| | d) | System fault level at rated voltage | : 50 kA for 1 sec |
| | e) | Short time rating for terminal boxes | |
| | | o 110kW & Above
(Breaker controlled) | : 50 kA for 0.25 sec |
| | | o Below 110kW (SFU+
Contactor controlled) | : 50 KA for 0.25 sec. |
| | f) | LV System grounding | : Solidly |
| 7.0 | Class of insulation | : | Class 'F', with temp rise limited to class B. |
| 8.0 | Minimum voltage for starting
(As percentage of rated voltage) | : | 80% of rated voltage |
| 9.0 | Power cables data | : | Shall be given during Detailed engg. |
| 10.0 | Earth Conductor Size & Material | : | Shall be given during Detailed engg. |
| 11.0 | Space heater supply | : | 240 V, 1Φ , 50 Hz |
| 12.0 | Rating up to which Single phase motor | : | Acceptable below 0.20 kW |
| 13.0 | Tests | : | As per Customer motor spec. (enclosed) |
| 14.0 | Energy efficient/ Flame proof motor | : | As per Customer spec. requirement |

- Also detail Customer spec. for Motors to be referred as enclosed with spec.