



ANNEXURE-A (to BHEL Specification BA35039)

Doc No.: PBTP-KPS-GR-35039

1.0.0. Intent of the Specification

The intent of the specification is to procure “Wear parts” (Grinding Rolls and Bull ring segments) for XRP-1003 type coal pulverisers of BHEL make operating at **NTPC-KORBA**.

It is not the intent to specify completely herein, all aspects of material selection and manufacturing process, nevertheless, the wear parts shall conform in all aspects to high standards of material quality, manufacturing process and workmanship and shall be capable of performing in continuous commercial operation, in a manner acceptable to the owner, who will interpret the meaning of specification, drawings and shall have right to reject or accept any work or material which in his assessment is not complete to meet the requirement of this specification.

Bidder is request to carefully examine and understand the specification and seek clarifications, if required, to ensure that they have understood the specification. The Bidder's offer should not carry any section like clarifications, Interpretations and /or assumptions. Also, the offer should not be conditional with respect to the Operation and Maintenance practices at the station.

2.0.0 Not Applicable

3.0.0. Applicable Drawings

The drawing listed below and forming part of the specification is for Bidder's information. All these drawings and indicative of Owner's requirement to enable the Bidder to make a suitable offer. It shall however, be responsibility of the Contractor to ensure fitment of the supplied material.

i.	Drawing No. KS/TC/SG/02/50/104	Grinding Rolls
ii.	Drawing No. KS/TC/SG/02/50/110	Bull Ring Segments

Any variation/alteration from the listed drawings shall be clearly brought out in the technical deviation schedule with implications if any, such variations may be acceptable, after assessment of its implication and shall be subject to Owner's approval.

4.0.0 Scope of the Proposal

The scope of the proposal shall include manufacturing, testing, packaging, transportation, delivery on F.O.R (BHEL-Hyderabad) basis of wear parts of XRP-1003 type coal Pulverisers comprising of the following:

- i. Grinding Rolls

ii. Bull Ring Segment

The scope of proposal shall also include supervision of installation (supervision of installation of 1st Set of wear parts in each mill) if required.

4.1.0 The scope of supply of Contractor shall include supply of mill wear parts, that is set of grinding rolls and set of bull ring segments and additional mill components (refer Note 1 below) for **28 number of coal pulverisers** such that these wear parts are compatible with each other.

Note 1: One set of wear part include one set of grinding rolls and one set of bull ring segment. Together three nos. grinding rolls required for one pulveriser shall form “One set of Grinding rolls” and bull ring segments quantity required for each pulveriser shall form “One set of Bull Ring Segments” for entire period of guaranteed wear life of each set of grinding rolls and bull ring segments shall deemed to be included in scope of each set of grinding roll/each set of bull ring segments shall deemed to be included in the price of respective sets of grinding rolls and/or bull ring segments.

4.2.0 The quantity of wear parts shall be such that $28 \times 10000 = 2,80,000$ hrs. (Two lakhs eighty thousand hours of operation of pulveriser (cumulative hours) can be achieved for the entire range of coals. The Bidder shall guarantee the same life for each type of wear part (i.e. grinding roll and bull ring segments) and this guaranteed life shall be the basis of calculating the quantity of wear parts. The guarantee for wear parts life shall be in accordance with the guarantee requirement specified in subsequent sections.

Note 2: The rated fineness not be less than 70% through 200 mesh.

4.3.0 In the bid proposal the Bidder is required to offer the wear parts such quantities that the cumulative wear life (based on guarantee provided by the bidder for wear life of the wear parts) for each set of the wear part (i.e. grinding rolls and bull ring segments) is not less than the number of hours resulting from multiplications of “number of coal pulverisers for which wear part are being procured” X “10000 operating Hrs”. The required Quantity/sets of wear parts shall be arrived at by rounding off the fractional part of the set to next higher whole number.

4.4.0 The wear life guarantee for each set and type of wear parts shall be from within the range of 4000 Hrs. – 10000 Hrs. and the quantity of wear parts shall be calculated based on guaranteed wear life from within the above range only. An example of arriving at number of sets of wear parts for the purpose of Bidder's quotation is given below at table-1:

Example: Table – 1

S. No.	Description	Bidder A	Bidder B
1.	Number of coal pulveriser as per specification	28	28
2.	Guarantee wear life of each set of grinding roll	4000	6000
3.	Guarantee wear life of each set of bull ring segments	5000	7000
4	Number of grinding rolls required to be quoted per mill	$10000 \times 28 / 4000 = 70$ sets	$10000 \times 28 / 6000 = 46.67$ i.e. 47 sets
5	Total number of sets of bull ring segments required to be quoted.	$10000 \times 28 / 4000 = 70$ sets	$10000 \times 28 / 6000 = 46.67$ i.e. 47 sets

5.0.0 Evaluation Criteria

The bids guaranteeing wear life less than 4000 Hrs. will not be considered for evaluation and shall be rejected. Further, no evaluation credit will be given for guaranteed wear life in excess of 10000 Hrs.

The evaluation of the bids shall be based on the total price of (a) sets of bull ring segments and (b) sets of grinding rolls and quoted by the Bidder in accordance with the clause 4.0.0 "Scope of the Proposal".

6.0.0 Material of Construction

The material of construction of wear parts shall be selected taking into account highly abrasive nature of coal resulting from coal contamination with silica sand and Alpha-quartz. The coal and ash data is specified elsewhere in the document and same shall be considered for selection of wear part material and offering guarantee for wear life.

S. No.	Name of Wear Part	Material
1.	Bull Ring Segments	Ni Hard, High Chrome, Sinter Cast
2.	Grinding Rolls	Ni Hard, High Chrome Carbide Insert, Sinter Cast

Note: - The Ni-hard Rolls shall be manufactured using centrifugal casting method.

The above list of the materials is only indicative and also not exhaustive, the materials selected by the contractor for the mill wear parts must have been used satisfactorily in at least six (06) numbers of coal pulverisers having similar or higher rated capacity.

7.0.0 Coal Characteristics

The range of coal and ash characteristics, which is likely to be supplied to the mills, is enclosed at Annexure - 1. Bidder is requested to familiarize themselves with the detailed coal and ash characteristics, if required. No allowance will be given on wear part life on account of change in coal and ash characteristics except for YGP index. (See clause 8.1.2 & 8.3.4)

The material of construction of wear parts shall be selected taking into account highly abrasive nature of coal resulting from coal contamination with silica sand and Alpha-quartz. Bidders shall consider the effect of these shale, sand stone and alpha quartz content for offering guaranteed wear life of Mill wear parts.

8.0.0 Guarantees

The quantity of wear parts shall be such that total cumulative hours of $28 \times 10000 = 2,80,000$ hours of operation is achieved with the supplied sets.

The Bidder shall guarantee the wear parts for wear life and fitment of wear parts in the existing mills and furnish these guarantees in Schedule - I.

8.1.0 Guaranteed Wear Life

The "each set of wear parts", i.e. each set of 3 grinding rolls and each set of bull ring segments) shall be guaranteed for wear life in number of hours of mill operation with consistent mill loading capacity not less than 80% of its maximum capacity at rated fineness (70% to 80% of 200 mesh) for the specified range of coals during guaranteed period.

8.1.1 The guarantee on wear life shall be provided for each type of wear part separately (i.e. Grinding Rolls and Bull Ring Segments) shall be same. The guaranteed wear life for each set of grinding

rolls and each set of bull ring segments and additional component (if any) shall be from within the range of 4000 - 10000 "Operating Hours of mill". Bidders offering wear life guarantee less than 4000 Operating Hours shall not be considered for evaluation. Further, Bidder's offering wear life guarantee higher than 10000 Operating Hours shall not be given any evaluation credit beyond 10000 Hrs. The material and design of Bull Ring Segments shall be so selected by the Contractor that their replacement coincides with the replacement of set of grinding rolls.

8.1.2 The mill wear part guarantee shall be valid for complete range of coal and ash characteristics specified in this specification. No correction in guaranteed wear life shall be allowed within the above range of coal and ash characteristics except for YGP index. For variation in YGP Index of coal beyond the specified range the Bidder may submit the correction curve, indicating change in wear life w.r.t. YGP Index, along with Bid. The correction curve shall be subject to Owner's approval.

8.1.3 The guarantee for Rolls and Bull ring segments shall be specified against the wear depth.

8.1.4 The guarantee for Bull ring segments shall be same as the guarantee offered for the Rolls.

8.2.0 Wear Part Warrantee:- The Bidder shall guarantee the wear life of wear parts in number of mill operating hours (Refer note below). The guarantee/warrantee on wear life shall be demonstrated on all the pulverisers.

Note: The wear life in Operating Hours of mill for the purpose of wear part is the total hours of operation of mill up to removal of said wear parts from the pulveriser. Removal criteria of wear parts shall be as per clause no. 8.3.2 & 8.3.3.

8.3.0 Demonstration of Pulverisers Wear Part Guarantee:-

8.3.1 The Guarantee/warrantee for the life of mill wear parts shall be demonstrated by the Contractor during the Guarantee Trial Period (GTP). The GTP shall commence after successful operation of the Pulverisers established continuously for a period of not less than 12 hrs or at near 55 tonnes/hr capacity and fineness not less than 70% thru 200 mesh with the newly installed wear parts. The GTP shall end as soon as first set of grinding rolls and first set of bull ring segments have completed their actual wear life or the guaranteed wear life (whichever is earlier) in all the Pulverisers. However, in case the wear parts are supplied in more than one lot, the Pulverisers Wear Part Guarantee demonstration as per the above shall be repeated for each lot of wear parts.

8.3.2 The performance of the Pulveriser shall be monitored on regular basis w.r.t. Loading, Fineness, Wear depth of wear parts as per the practice in vogue at the station.

The mill loading will be monitored on daily basis, the fineness on weekly basis and roller wear depth during every preventive maintenance of the mill. Each type of wear part (i.e. grinding rolls, bull ring segments and additional components, if any) shall be considered to have completed their guaranteed/warranted wear life when any of the following conditions occur:

- a) The actual wear depth reaches the guarantee wear depth for Rolls (average wear of 3 rolls in the set)
- b) Mill Loading capacity shall not fall below 55 Tonnes/Hr or 90% of the base capacity till guaranteed period
- c) Pulverised coal fineness of 70% (to 80%) through 200 meshes. Shall be sustainable till guarantee period.

Note: No allowance shall be given for Operation and Maintenance practices while applying these criteria.

8.3.3 Further, in case any of the wear parts has worn out to such an extent that either the normal or safe operation of the Pulverisers is jeopardized if this part is not replaced/ repaired or

continuous use with this part may lead to exposure or wear of other parts which are not meant for the purpose of checking the shortfall in wear life, even if there is no reduction in Pulveriser rated capacity or fineness, then the part shall be deemed to have outlived its wear life.

- 8.3.4 Average Wear life for pulveriser wear part warrantee shall be arrived at from the station record for each pulveriser and as corrected for variation in YGP index of coal being fired during that time. The correction for variation in YGP index is applicable only when the average YGP index falls beyond the range as indicated in Annexure-1 for Coal Characteristics. For this purpose, the coal YGP shall be the average tested value tested as per the station record during the period the wear parts are in use.

8.4.0 Liquidated Damage for Shortfall in Guaranteed/Warranted Wear Life:

- 8.4.1 Liquidated damages shall be levied for shortfall in wear life of wear parts for each set of wear part. For the purpose of ascertaining the wear life achieved following method shall be adopted:

- 8.4.2 The wear life of set of wear parts shall be recorded for all pulverisers. The average wear life of first sets of wear parts in four pulverisers in which the wear parts have completed their wear life earlier than other pulverisers shall be considered as wear life achieved for that lot.

Following method is an example where wear parts required for 6 no.s of pulverisers as per clause 4.1.0 were procured, first sets of wear parts of the supply lot were installed and all the first sets have completed their life. Table - II below explains how the average wear life is to be calculated for the purpose of establishing compliance to guaranteed wear life and levying liquidated damages in case of shortfall.

Table - II

S. No.	Description	Guaranteed Wear life	Life achieved for first set of wear parts					
			Mill 1	Mill 2	Mill 3	Mill 4	Mill 5	Mill 6
1.	1 st Set of wear parts, Hrs	3500	4500	3600	3650	3550	3625	3450

Table-II show the life of first set of wear parts achieved in six pulverisers/mill. As per records, in Mill Nos. 6,4,2 and 5, the first set of wear parts have completed their wear life earlier than others (in terms of time from installation of wear parts). Therefore, for the purpose of establishing the wear life achieved by the set of wear parts, average of life achieved in mills # 6,4,2 and 5 shall be considered i.e. $(3450+3550+3600+2625)/4 = 3556$ Hrs.

- 8.4.3 In case the wear parts do not fulfill the guaranteed wear life the credit shall be provided after the end of GTP to the Employer at the rate of one and a half times the shortfall worked out for each set of wear part. For example should a wear part set have a price of Rs 10000 (Rupees Ten Thousand) and the wear life guaranteed for the wear part is 6000 Hrs. When the set of wear parts which fail to meet the warrantee test lasts only 4000 Hrs. out of guaranteed 6000 Hrs. a credit of Rs. $(10,000 \times 1.5 \times 2000)/4000 = \text{Rs. } 7500$ would apply towards the Employer for each set of wear parts. This credit shall apply to all wear parts by multiplying the credit per set of wear part with total number of wear part sets in that lot and shall be considered as Liquidated Damaged for shortfall in wear life for that lot.

- 8.4.4** At the end of GTP, if it is found that any of the wear part set have achieved life of 50% or less

than the guaranteed wear life the Contractor shall replace the wear parts set free of cost and commence the GTP again till such time the wear parts are able to achieve wear parts life higher than 50% of wear life. For wear life between 50% and 100% the liquidated damages as described above shall apply.

If any wear part fails to achieve 50% of guaranteed life even after GTP, the Contractor shall replace the wear part set free of cost.

8.4.5 The bidder shall supply the material in lot size which will be decided while placing the Purchase Order. In case the wear parts are supplied in more than one lot the liquidated damages as per the above shall be levied for each lot of wear parts.

8.5.0 Fitment Guarantee

8.5.1 Fitment of the supplied material in the identified Pulverisers is the responsibility of contractor and same shall be guaranteed by the Bidder. In case it is found that the supplied material (wear parts) do not fit into the pulveriser and/or the normal and safe operation of the pulveriser cannot be sustained with the supplied wear parts during the normal running of the mill, the Contractor shall within one week supply fresh lot of modified wear parts (not less than 25% of the quantity) to replace the wear parts which have failed in fitment and/or have restricted normal/ safe operation of pulverisers. The balance set of such wear parts shall be supplied within one month. In case the normal/safe operation is jeopardized due to wear of grinding rolls and bull ring segment the same shall be considered under the guarantee for wear life and not under fitment guarantee.

9.0.0 Quality Assurance & Inspection

9.1.0 Bidder shall provide the necessary information on Quality Assurance Program containing the overall Quality management and Procedures, which the Bidder proposes to follow during various stages of manufacturing of the specified wear parts. The contractor shall also submit a detailed manufacturing quality plan in the formats **(to be informed separately)** detailing out the tests/checks carried out by the manufacturer, during various stages of manufacturing, for BHEL's customer approval. The quality Plan shall be accompanied with all the entire plan standards, reference documents, acceptance norms, procedures and specifications. The indicative tests/checks, which shall necessarily form part of the Quality plan, are as follow:

- i. Chemical Composition and heat treatment.
- ii. Mechanical properties and measurement of hardness.
- iii. Wear – resistant parts shall be UT/RT tested to check soundness after suitable heat treatment. In case of bi-metallic castings, UT shall be carried out for ensuring the proper bonding.
- iv. Metallurgical test: Micro-structure examination will be carried out on samples selected at random.
- v. Surface defects of the wear resistant parts shall be examined by DPT.
- vi. To ensure proper fitment at site each grinding roll shall be subjected to blue-matching check for proper bore surface contact. In case of bull ring segment trial assembly shall be carried out for each set on the test bowl.
- vii. Weldments on any other mill component shall be checked with suitable NDT.

9.2.0 The approved Quality Plan shall indicate BHEL's customer witness points (customer hold points) for which the contractor shall give 15 days' inspection advance notice for undertaking inspection.

10.0.0 Any requirement, as specified by BHEL's customer shall be confirmed/adhered to by the bidder.

Note: The technical specification includes following forms which need to be duly filled by the Bidder and submitted along with the bid:

Schedule – I: Guarantee Declaration, Schedule – II: Technical Data Sheets, Schedule – III: Information Regarding Quality Assurance Plan, Schedule – V: Delivery Schedule.

COAL & ASH CHARACTERISTICS

PROXIMATE ANALYSIS OF COAL	UNIT OF MEASUREMENT	RANGE	
		FROM	TO
MOISTURE	%	10	13
ASH	%	38	45
HGI	Index	50	70
YGP INDEX	mg/Kg of Coal	45	55
ASH ANALYSIS			
SILICA	%	55	66
ALUMINA	%	30	35

Schedule- I

TECHNICAL SPECIFICATION FOR PROCUREMENT OF WEAR
PARTS FOR XRP 1003 COAL PULVERISERS

Tender Document No.:

(GUARANTEE DECLARATION)

Bidder's Name & Address

BHEL-HYDERABAD

Dear Sir,

We declare that the wear life of wear parts, their fitment and material specification for wear parts offered in this bid are guaranteed by us. We further declare that in the event of any deficiencies in meeting the guarantees indicated below as established in accordance the bidding documents, you may at your discretion accept the wear parts after assessing the liquidated damages as specified in clause 8.4.0 of bidding documents or reject the wear parts and recover the payment already made.

S. No.	Guaranteed Parameter	Guaranteed Figures
1.0	Wear Life of Wear parts	
1.1	Wear life of each set of grinding Rolls in Operating Hours at -----mm wear depth as per Clause 8.0.0	
1.2	Wear life of each set of bull ring Segments in Operating Hours at ---- mm wear depth as Per clause 8.0.0	
2.0	Guarantee for fitment	as per bidding document Clause 8.5.0

Date:	(Signature)
Place:	(Printed Name)
	(Designation)
	(Common Seal)

Note: A) Wear life guarantee for Set of Grinding rolls & Set of bull ring segments shall be same.
B) Any Variation to the stipulated conditions under which Guarantees are to be met will not be permitted and Bids with such variation are liable to be rejected.

**TECHNICAL SPECIFICATION FOR PROCUREMENT OF WEAR
PARTS FOR XRP 1003 COAL PULVERISERS**

Tender Document No.

(Technical Data Sheets)

S. No.	Description	Grinding Rolls	Bull Ring Segments
1	Name of manufacturer		
2	Location of Manufacturing Unit		
3	Model of Coal Pulveriser		
4	Number of Pulverisers		
5	Number of sets		
6	Number of items in each set		
7	Wear life of each set		
8	Weight of each item (Bidder to Provide item wise list)		
9	Weight of each set		
10	Compliance to specified dimensions	Yes	Yes
11	Name of material		
12	Surface hardness		
13	Physical properties of material		
14	Chemical composition of material		

Date:

Place:

(Signature)

(Printed Name)

(Designation)

(Common Seal)

Schedule- III

TECHNICAL SPECIFICATION FOR PROCUREMENT OF WEAR
PARTS FOR XRP 1003 COAL PULVERISERS

Tender Document No.

(Information regarding Quality Assurance program)

Bidder's Name & Address
Dear Sirs,

BHEL-HYDERABAD

We hereby provide the necessary information on Quality Assurance program containing the overall Quality management and Procedures, which we propose to follow during various stages of manufacturing the specified wear parts.

Date:
Place:

(Signature)
(Printed Name)
(Designation)
(Common Seal)

Note: Continuation sheets of like size and format may be used as per Bidder's requirement and shall be annexed to this Attachment.

TECHNICAL SPECIFICATION FOR PROCUREMENT OF WEAR
PARTS FOR XRP 1003COAL PULVERISERS

Tender Document No.

(Delivery Schedule)

Bidder's Name & Address

BHEL-HYDERABAD

-
- 1 Grinding Rolls
 2. Bull Ring Segments

Note: Bidder to provide list of additional pulverizer components.

Date:
Place:

(Signature)
(Printed Name)
(Designation)
(Common Seal)