

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Government of India Undertaking)
 SEAMLESS STEEL TUBE PLANT
 THIRUCHIRAPALLI - 620014
 TAMILNADU (INDIA)

Page
1/3

PHONE : 91-44-28158821
 GRAMS : BHARATELEC
 FAX NO:
 E-mail :
 Web : FAX NO:

Enquiry No	Enquiry Date	Due Date for Quotation
9641800098	25.06.2018	16.07.2018
Please quote Enquiry No, Date and due date in all correspondences. This is only a request for quotation and not an order. Bid should be submitted in two parts. 1.Techno-commercial bid (Part-I) and 2.Price bid(Part-II) in a separate sealed cover and both covers must be placed in a third cover and sealed. Our Enquiry No., Enq. date & Enq. Due date must be written on all three covers.		

Item	Description	Unit	Quantity	Delivery Quantity	Schedule Date
10	SP2002004137 Flame proof panel-1 LPG Yard Flame proof panel-1 LPG Yard. 1) Incomer1: 400A SFU (EB Main power supply). 2) Outgoing1: 200A SFU (1000Kg Vaporiser). 3) Outgoing2: 200A SFU (500Kg Vaporiser). 4) Outgoing3: 200A SFU (spare). 5) Outgoing4: 200A SFU (spare). 6) Outgoing5: 32A SFU (Unloading compressor1). 7) Outgoing6: 32A SFU (Unloading compressor2). 8) Outgoing6: 32A SFU (Unloading compressor3). Each outgoing should have analog ammeter fixed with viewing glass. Incoming should have energy meter fixed. Energy meter shall be of model PAC3200 from M/s Siemens with viewing glass for viewing from outside. All feeders should have individual RYB Indicators. Panel shall be titled with metal tag "LPG YARD MCC PANEL 1". The panel should be flame proof for installation in LPG Yard area. Necessary certificates should be produced along with materials. Minimum detailed bill of materials are attached for compliance. Any additional data should be produced during the technical bid of tender.	NO	1.000	1.00	13.08.18
20	SP2002004138 Flame proof panel-2 LPG Yard Flame proof panel-2 LPG Yard. 1) Incomer1: 400A SFU with suitable rated fuse (EB Main power supply). 2) Outgoing1: DOL starter with Auto/Manual switch for 55KW 94A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 3) Outgoing2: DOL starter with Auto/Manual switch for 9.3KW 17.3A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 4) Outgoing3: DOL starter with Auto/Manual switch for 5)	NO	1.000	1.00	13.08.18

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening.Late and delayed offers are liable to be rejected.	Yours faithfully, For BHARAT HEAVY ELECTRICALS LIMITED MANAGER / PURCHASE (SSTP)
--	--



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)
SEAMLESS STEEL TUBE PLANT
THIRUCHIRAPALLI - 620014
TAMILNADU (INDIA)

9641800098 / 25.06.2018

23505

Outgoing4: DOL starter with Auto/Manual switch for 55KW 94A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 6) Outgoing5: 63A SFU for lighting. 7) Outgoing6: 63A SFU spare. 8) Outgoing7: 32A SFU for local compressor.

Each outgoing should have analog ammeter fixed with viewing glass.

Incoming should have energy meter fixed.

Energy meter shall be of model

PAC3200 from M/s Siemens with viewing glass for viewing from outside.

All feeders should have individual RYB

Indicators. Panel shall be

titled with metal tag "LPG YARD MCC PANEL

2". The panel should be flame

proof for installation in LPG Yard area.

Necessary certificates should

be produced along with materials.The panel

should be flame proof for

installation in LPG Yard area. Necessary

certificates should be produced

along with materials.

Minimum detailed bill of materials are attached

for compliance. Any

additional data should be produced during the

technical bid of tender.

Note to supplier:

1.,,Guarantee certificate required

2.,,Test certificate required

3. The order will be placed on overall L1 basis

TENDER NOTES:

1. This Tender is floated on TWO-BID basis.

2. Following details are enclosed.

a.,,Annexure-A - Important Note to

Tenderers & Annexure-D Note to

MSE Vendors enclosed. Send your MSE

Certificate accordingly.

Tenderers are requested to submit their

Offers in TWO-BID basis,

viz.,

I.,,Part I,.,,.,,Technical and Un-Priced Commercial Bid

II.,,Part II,.,,.,,Price Bid

b.,,Annexure-B - Technical Conditions

c.,,Annexure-C - Commercial Conditions

3. Tenderers are required to fill in above

Annexure-B and C and

enclose them along with their UN-PRICED BID.

4.a. Delivery date furnished in the Enquiry is only indicative.

4.b. For Delivery Schedule - Pl. refer Clause

No. C.4 of Annexure- C.

5. Price Bid of Vendors, who accept the

Clause No. B.1 to B.6 of

Annexure-B & C.1 to C.4 of Annexure- C. shall

only be considered

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening.Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)
SEAMLESS STEEL TUBE PLANT
THIRUCHIRAPALLI - 620014
TAMILNADU (INDIA)

9641800098 / 25.06.2018

23505

for further processing. Fill the Annexure-B & C and enclose it with Technical and Un-Priced commercial Bid. For Payment term - Refer Annexure - C Point No. C- 2. Any deviation in the above payment term will attract loading as mentioned below. For payment term deviation - "Base rate of SBI (as applicable on the date of bid opening. Techno-commercial bid opening in case of two part bids) + 6% shall be considered for loading for the period of relaxation sought by bidders. Payment through Bank is not preferred. In case of Payment through Bank is opted by Supplier, BHEL prefers documents submission through bank with copy of LR and door delivery of Goods to Stores with Consignee copy attached. In this case Loading will be 3% on the offered value. Offers of indigenous Suppliers with payment terms as LC/Advance Payment are liable for rejection.

General Note:

The bidder along with its associate/ collaborators/ sub-contractors/ sub-vendors/ consultants/ service providers shall strictly adhere to BHEL fraud prevention policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL management about any fraud or suspected fraud as soon as it comes to their notice.

The supplier shall submit EI/EI forms to BHEL time to time as indicated by the BHEL and in case of inordinate delay in issuing EI/EI forms, then BHEL reserves the right to deduct 5% of the value of the supplied items against which EI/EI forms pending to be issued

Enclosures:

"LD clause has to be confirmed without fail."

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)