

# *NTPC Limited*

(A Government of India Enterprise)



## **LOT-IB PROJECTS**

**PART - D**

## **ERCTION CONDITIONS OF CONTRACT**

**SECTION – VI**

## **TECHNICAL SPECIFICATION**

**FOR**

**FLUE GAS DESULPHURISATION (FGD)**

**SYSTEM PACKAGE**

**BIDDING DOCUMENT NO.: CS-0011-109(1B)-9**

# *NTPC Limited*

(A Government of India Enterprise)



## **LOT-IB PROJECTS**

### **PART - D**

### **ERCTION CONDITIONS OF CONTRACT**

### **SECTION – VI**

### **TECHNICAL SPECIFICATION**

### **FOR**

### **FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE**

**BIDDING DOCUMENT NO.: CS-0011-109(1B)-9**

(This document is meant for the exclusive purpose of bidding against this Package and shall not be transferred, reproduced or otherwise used for purposes other than that for which it is specifically issued).

## PART - D

# ERCTION CONDITIONS OF CONTRACT

LOT-IB PROJECTS  
FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE

TECHNICAL SPECIFICATION  
SECTION-VI, PART-D  
BID DOC NO: CS-0011-109(1B)-9

## ERCTION CONDITIONS OF CONTRACT

### PART - D

#### CONTENTS

| Clause No. | Description  | Page No. |
|------------|--|----------|
| 1.00.00    | General  | 1        |
| 2.00.00    | Regulation of Local Authorities and Statutes       | 1        |
| 3.00.00    | Welding of Pressure Parts and High Pressure Piping | 1        |
| 4.00.00    | Heat Treatment                                     | 2        |
| 5.00.00    | Weld Edge Preparation                              | 3        |
| 6.00.00    | Cleaning and Servicing                             | 3        |
| 7.00.00    | Field Welding Schedule                             | 3        |
| 8.00.00    | Site Run Miscellaneous Piping                      | 4        |
| 9.00.00    | Thermal Expansions                                 | 4        |
| 10.00.00   | Piping Supports                                    | 4        |
| 11.00.00   | Pressure Testing                                   | 5        |
| 12.00.00   | Thermowells and Flow Nozzles                       | 5        |
| 13.00.00   | Insulation, Lagging and Cladding                   | 5        |
| 14.00.00   | Code Requirements                                  | 7        |
| 15.00.00   | Electrical safety regulations                      | 7        |
| 16.00.00   | Removal of Material                                | 8        |
| 17.00.00   | Inspection, Testing and Inspection Certificates    | 8        |
| 18.00.00   | Access to site and Works on Site                   | 8        |
| 19.00.00   | Contractor's Site Office Establishment             | 8        |
| 20.00.00   | Co-operation with other contractors                | 9        |

| <b>Clause No.</b> | <b>Description</b>                                | <b>Page No.</b> |
|-------------------|---|-----------------|
| 21.00.00          | Discipline of Workmen                             | 9               |
| 22.00.00          | Contractor's Field Operation                      | 9               |
| 23.00.00          | Photographs and Progress Report                   | 10              |
| 24.00.00          | Man-Power Report                                  | 10              |
| 25.00.00          | Protection of Work                                | 10              |
| 26.00.00          | Employment of Labour                              | 10              |
| 27.00.00          | Facilities to be provided by the Employer         | 11              |
| 28.00.00          | Facilities to be provided by the Contractor       | 12              |
| 29.00.00          | Lines and Grades                                  | 13              |
| 30.00.00          | Fire Protection                                   | 13              |
| 31.00.00          | Security  | 13              |
| 32.00.00          | Contractor's Area Limits                          | 14              |
| 33.00.00          | Contractor's Co-operation with the Employer       | 14              |
| 34.00.00          | Pre-commissioning and Commissioning Activities    | 14              |
| 35.00.00          | Materials Handling and Storage                    | 17              |
| 36.00.00          | Construction Management                           | 18              |
| 37.00.00          | Field Office Records                              | 21              |
| 38.00.00          | Contractor's Materials Brought on to Site         | 21              |
| 39.00.00          | Protection of Property and Contractor's Liability | 22              |
| 40.00.00          | Painting  | 22              |
| 41.00.00          | Insurance   | 23              |
| 42.00.00          | Unfavourable Working Conditions                   | 24              |
| 43.00.00          | Protection of Monuments and Reference Points      | 24              |
| 44.00.00          | Work & Safety Regulations                         | 24              |

| <b>Clause No.</b> | <b>Description</b>  | <b>Page No.</b> |
|-------------------|---|-----------------|
| 45.00.00          | Foreign Personnel   | 33              |
| 46.00.00          | Foundation Dressing & Grouting for Equipment/Equipment Bases              | 34              |
| 47.00.00          | Shaft Alignments  | 36              |
| 48.00.00          | Dowelling   | 36              |
| 49.00.00          | Check Out of Control Systems  | 36              |
| 50.00.00          | Commissioning Spares  | 37              |
| 51.00.00          | Cabling   | 37              |
| 52.00.00          | Equipment Delivery and Erection   | 38              |
| 53.00.00          | Welding-Special Requirements  | 44              |
| 54.00.00          | Deviations Dispositioning   | 44              |
| 55.00.00          | Non-Destructive Testing (NDT)   | 44              |
| 56.00.00          | Testing Equipment & Facilities  | 44              |
| Annexure-I        | Standard Check List   | 45              |
| Annexure-II       | Brief Write-up on the contents of testing schedule/commissioning schedule | 52              |
| Annexure-III      | Safety Plan   | 53              |

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | NTPC                                 |
|--|--|--------------------------------------|
| <b>1.00.00</b>   | <b>GENERAL</b>   |                                      |
| 1.01.00  | <p>The following provisions shall supplement the conditions already contained in the other parts of these specifications and documents and shall govern that portion of the work of this contract which is to be performed at site. The erection requirements and procedures not specified in these documents shall be in accordance with the recommendations of the equipment manufacturer, or as mutually agreed to between the Employer and the Contractor prior to commencement of erection work.</p>  |                                      |
| 1.02.00  | <p>The Contractor upon signing of the Contract shall, in addition to a Project Co-ordinator, nominate another responsible officer as his representative at Site suitably designated for the purpose of overall responsibility and co-ordination of the Works to be performed at Site. Such a person shall function from the Site office of the Contractor during the pendency of Contract.</p>   |                                      |
| <b>2.00.00</b>   | <b>REGULATION OF LOCAL AUTHORITIES AND STATUTES</b>  |                                      |
| 2.01.00  | <p>In addition to the local laws and regulations, the Contractor shall also comply with the Minimum Wages Act and the Payment of Wages Act (both of the Government of India) and the rules made there under in respect of its labour and the labour of its sub-contractors currently employed on or connected with the contract.</p>   |                                      |
| 2.02.00  | <p>All registration and statutory inspection fees, if any, in respect of his work pursuant to this Contract shall be to the account of the Contractor. However, any registration, statutory inspection fees lawfully pay-able under the provisions of the Indian Boiler Regulations and any other statutory laws and its amendments from time to time during erection in respect of the plant equipment ultimately to be owned by the Employer, shall be to the account of the Employer. Should any such inspection or registration need to be re-arranged due to the fault of the Contractor or his Sub-Contractor, the additional fees for such inspection and/or registration shall be borne by the Contractor.</p> |                                      |
| <b>3.00.00</b>   | <b>WELDING OF PRESSURE PARTS AND HIGH PRESSURE PIPING</b>  |                                      |
| 3.01.00  | <p>The welding of all pressure parts and high pressure piping shall be in accordance with the following requirements:</p> <p><b>Qualification of Weld Procedures</b></p> <p>Only qualified welding procedures as per ASME Section IX shall be used by contractor at site. Procedure qualification records along with WPS shall be submitted to NTPC for review. Welding procedure shall indicate all essential and non-essential parameters as per ASME Section IX. Makes of welding consumables shall be subject to employer's approval.</p>  |                                      |
| 3.02.00  | <p><b>Welder's Qualification</b></p> <p>Only welders who are qualified in accordance with the latest applicable requirements of the Indian Boiler Regulations, shall be permitted to perform any welding work on the pressure parts and its attachment welding. In addition to such statutory qualification requirements, the welders shall also undergo a satisfactory</p>  |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9  | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |  | PAGE<br>1 OF 53                      |

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC |
|------------|--|------------------|
|            | <p>pre-production qualification test to be conducted by the Contractor at site as per ASME Sec IX in presence of employer's representative(s), prior to performing work under these specifications. The services of an independent testing laboratory shall be retained by the Contractor to perform welder qualification tests for welders.</p> <p>All the welders carrying out welding at site shall carry an identification badge, which shall indicate the category and the grade of welding for which they have been tested and authorised to carry out welding.</p>  |                  |
| 3.03.00    | <p><b>Records</b></p> <p>Welders performance shall be monitored regularly and record of their performance shall be maintained by contractor in a manner acceptable to the employer. Contractor shall maintain such records including record of procedure qualification &amp; welder qualification and hand-over to the employer at the end of work.</p>  |                  |
| 3.04.00    | <p><b>MARKING</b></p> <p>On completion of each welded joint, the welder shall mark his regularly assigned identification mark near the joint. The welder's identification numbers, inspection stamps or code symbol stamps and any other information shall not be directly stamped on any alloy steel piping. In alloy steel piping, all such information shall be stamped on separate marking plate which shall be tack welded on pipe near the weld.</p>   |                  |
| 4.00.00    | <p><b>HEAT TREATMENT</b></p>   |                  |
| 4.01.00    | <p>Pre-heating, post-heating and post-weld stress relief operations of all welds, shall be performed in accordance with the requirements of applicable code. Local post weld stress relieving heat treatments shall be adopted only in cases where it is normally impracticable to subject the entire assembly as such for stress relieving operations. Heating may be by means of electric induction coils or electric resistance coils. Oxy-acetylene flame heating or exothermic chemical heating methods will not be permitted. Complete recording of the temperatures through out the stress relieving cycle of the material and the weld subjected to heat treatment shall be made by means of a potentiometric recorder. Recorders other than those of potentiometric type shall not be used for such temperature recording during stress relieving operations.</p> <p>The contractor &amp; employer's representative, at start and at the end of HT Cycle shall sign the time and temperature charts for heat-treatment.</p> |                  |
| 4.02.00    | Not Used.  |                  |
| 4.03.00    | After setting up the weld joint for heat treatment operation, the Employer's signature shall be obtained on the strips chart of the recorder prior to starting of heat treatment cycle. The right hand corner of the strip chart at the starting point of the heat treatment cycle shall contain details like the weld number, material, diameter and thickness, method of heating adopted, prescribed ranges of heat treatment temperatures, date of heat treatment, reference to item number of the Field welding Schedule (as specified at clause no 7.00.00- of this chapter) etc.   |                  |

|  |   |                                      |                 |
|--|---|--------------------------------------|-----------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>2 OF 53 |
|--|---|--------------------------------------|-----------------|

| CLAUSE NO.     | ERCTION CONDITIONS OF CONTRACT  |
|----------------|---|
| <b>5.00.00</b> | <p><b>WELD EDGE PREPARATION</b></p> <p>Preparation at site of weld joint shall be in accordance with details acceptable to the Employer. Wherever possible, machining or automatic flame cutting shall be used for edge preparation. Hand flame cutting will be permitted only where edge preparation otherwise is impractical. All slag shall be removed from cuts and all the hand cuts shall be ground smooth to the satisfaction of the Employer. Flame cutting of alloy steel pipe shall be avoided. Wherever such cutting is done, a 200mm length at the cut face shall be removed by machining. Pneumatic hand tools such as edge preparation, tube cutting machine can be used.</p>   |
| <b>6.00.00</b> | <p><b>CLEANING AND SERVICING</b></p>  |
| 6.01.00        | <p>The inside of all tubes, pipes, valves and fittings shall be free from dirt, and loose scales before being erected. All the pipelines shall be thoroughly blown and/or flushed. Each steam and water tubes shall be blown with compressed air and shall be subjected to 'ball test' before erection to ensure that no obstructions exist. A system for recording of all such operations shall be developed and maintained in a manner to ensure that no obstructions are left inside the tubes and no tubes are left uncleansed and untested.</p>  |
| 6.02.00        | <p>All valves and valve actuators, and dampers and damper actuators, if any, shall be thoroughly cleaned and serviced prior to pre-commissioning tests and/or Initial Operations of the plant. A system for recording of such servicing operation shall be developed and maintained in a manner acceptable to the Employer and to ensure that no valves or dampers including their actuators are left unserviced.</p>   |
| 6.03.00        | <p>All interior surfaces of the turbine shall be thoroughly cleaned prior to boxing - up to remove all traces of oil preservations.</p>   |
| <b>7.00.00</b> | <p><b>FIELD WELDING SCHEDULE</b></p> <p>The Contractor shall submit to the Employer, a certified and complete field welding schedule for all the field welding activities to be carried out in respect of the pressure parts involved in the equipment furnished and erected by him, at least 90 days prior to the scheduled start of erection work at site. Such schedule will be strictly followed by the Contractor during the process of erection. The above field-welding schedule to be issued by the Contractor shall contain the following:</p> <p>(a.) Drawing No (s)</p> <p>(b.) Location of the weld</p> <p>(c.) Size of the weld (outside diameter and thickness)</p> <p>(d.) Type of joints</p> <p>(e.) Material specifications</p> <p>(f.) Size of fillet on backing ring, when the type of joint is with backing ring</p> <p>(g.) Electrode/ filler metal specifications</p> |

|  |   |                                      |                 |
|--|---|--------------------------------------|-----------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>3 OF 53 |
|--|---|--------------------------------------|-----------------|

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC  |
|--|---|---|
|  | <p>(h.) Number of welds per unit</p> <p>(i.) Quantity of filler metal per weld</p> <p>(j.) Indication of required Non-destructive Examination (NDE) for each weld</p> <p>(k.) Pre-heat temperatures for welding</p> <p>(l.) Process of welding</p> <p>(m.) Post-welding heat treatment temperature ranges, duration, under as specified at clause no 4.00.00 of this chapter entitled "Heat Treatment".</p> <p>(n.) Qualification details of weld procedures to be adopted as specified at clause no 3.01.00 of this chapter entitled 'Qualification of Weld Procedures'.</p>   |   |
| 8.00.00  | <p><b>SITE RUN MISCELLANEOUS PIPING</b></p> <p>Sketches or diagrams of the proposed routings of all piping, not already indicated and routed on the shop drawings which were reviewed by the Employer, shall be submitted to the Employer for review, Employer's acceptance of such site routings shall be obtained before the piping is erected. All these site run piping shall be installed in such a manner as to present an orderly and neat installation. They shall be located as to avoid obstruction of access and passages. Valves, instruments or any other special items shall be located convenient for operation by the operating personnel. Pipe runs shall be plumb or level except where pitch for drainage is required. Pipe runs that are not parallel to the building structure, walls or column rows shall be avoided so that deflection of pipes between hangers does not exceed 6 mm. No miscellaneous pipe shall be routed and installed above or adjacent to electrical equipment.</p> |   |
| 9.00.00  | <p><b>THERMAL EXPANSIONS</b></p> <p>All piping installation shall be such that no excessive or destructive expansion forces exist either in the cold condition or under condition of maximum temperature. All bends, expansion joints and any other special fittings, necessary to provide proper expansion, shall be incorporated. During installation of expansion joints and anchors, care must be taken to make sure that full design movement is available at all times for maximum to minimum temperature and vice-versa.</p>   |   |
| 10.00.00   | <p><b>PIPING SUPPORTS</b></p>   |   |
| 10.01.00   | Hangers, supports and anchors shall be installed as required to obtain a safe, reliable and complete pipe installation. All supports shall be properly levelled and anchored when installed. The anchors shall be so placed that thermal expansion will be absorbed by bends without subjecting the valves or equipment to excessive strains.   |   |
| 10.02.00   | The hanger assemblies shall not be used for the attachment of rigging to hoist the pipe into place. Other means shall be used to securely hold the pipe in place till the pipe support is completely assembled and attached to the pipe and building  |   |
| LOT-IB PROJECTS<br><b>FLUE GAS DESULPHURISATION (FGD)<br/>SYSTEM PACKAGE</b> |   | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 |
| ERECTION CONDITIONS<br>OF<br>CONTRACT  |   | PAGE<br>4 OF 53   |

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC                     |
|--|--|--------------------------------------|
|  | <p>structures and spring support is set to accommodate the pipe way. All temporary rigging shall be removed in such a way that the pipe support is not subjected to any sudden load. All piping, having variable spring type supports, shall be held securely in place by temporary means during the hydraulic test of pipe system. Constant support type spring hangers used during hydraulic test shall be pinned or blocked solid during the test. After complete installation and insulation of the piping and filling of the piping with its normal operating medium, the pipe support springs shall be adjusted to the cold positions. If necessary, the spring support shall be re-adjusted to the hot positions after the line has been placed for service at its normal maximum operating temperature conditions. Electric arc welding only shall be used to weld all pipe supports to structural steel members that form part of the building supporting structure. The structural beams shall not be heated more than necessary during welding of supports and such welds shall run parallel to the axis of the span. All lugs or any other attachments welded to the piping shall be of the same material as the pipe.</p> |                                      |
| <b>11.00.00</b>  | <b>PRESSURE TESTING</b>  |                                      |
| 11.01.00   | On completion of erection of pressure parts, a hydraulic test in accordance with the requirements of the Indian Boiler Regulations shall be performed by the Contractor.   |                                      |
| 11.02.00   | All the valves, high pressure pipes and inter-connected pipes connecting the pressure parts shall be tested along with pressure parts. All blank flanges or any removable plugs required for openings not closed by the valves, and piping provided, shall be furnished by the Contractor. The pressurization equipment including water piping from the supply, needed for the above test shall also be furnished by the Contractor. Any defects noticed during the testing are to be rectified and the unit re-tested. If any welding is done on the pressure parts after the Hydraulic test, the Hydraulic test for that portion of pressure parts shall be repeated. Water as required for such pressure testing shall be provided by the employer.   |                                      |
| 11.03.00   | Thy hydraulic test shall be considered successful only on certification to that effect by the concerned inspecting Authority as per the provisions of the Indian Boiler Regulations and the Employer.  |                                      |
| <b>12.00.00</b>  | <b>THERMOWELLS AND FLOW NOZZLES</b>  |                                      |
| 12.01.00   | All the thermowells and flow nozzles in the equipment furnished under the technical specifications shall be installed as a part of this work.  |                                      |
| 12.02.00   | All thermowell connections incorporated in the steam service shall be plugged during the pressure testing and the blow out of steam piping systems. Upon completion of the blow out operation, all thermowells shall be installed and seam welded. Similarly, all flow nozzles in the steam lines shall also be installed only on completion of steam blowing operations unless otherwise agreed to by the Employer, depending upon the sequence of cleaning and purging operations to be adopted by the Contractor at the field.  |                                      |
| <b>13.00.00</b>  | <b>INSULATION, LAGGING AND CLADDING</b><br>The provision of insulation, lagging and cladding of the various equipments and portion of the equipment covered under the Contract, shall be furnished by the  |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9  | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |  | PAGE<br>5 OF 53                      |

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC                     |
|--|--|--------------------------------------|
|  | Contractor as specified elsewhere or agree to separately in writing. Welds required for holding insulation on pressure parts shall be carried out by IBR qualified welder.   |                                      |
| 13.01.00   | <p><b>Piping, Pipe Fittings &amp; Valves</b></p> <p>All piping insulation and metal cladding furnished with the equipment to be erected shall be applied as specified herein.</p>  |                                      |
| 13.01.01   | <p><b>Piping</b></p> <p>The insulation on piping shall be applied using wire loops on 150mm centres. These wire loops shall be thoroughly embedded into the outer insulation surface and all cracks, voids and depressions shall be filled with insulating cement suitable for the piping temperature so as to form a smooth base for application of cladding. The wires used for piping insulation shall be of 16 SWG. The surface shall be smooth and uniform before applying the outer covering. All piping insulation ends shall be terminated at a sufficient distance from flanges to facilitate removal of bolts.</p>   |                                      |
| 13.01.02   | <p><b>Flanges</b></p> <p>Insulation on flanges shall be by means of blocks of insulating material securely bound to the flange by wire loops. Such blocks of insulation shall be long enough to overlap the adjacent pipe insulation by an amount equal to the thickness of adjacent pipe insulation. Smooth finish shall be obtained by the application of insulating cement. Alternatively, sectional pipe insulation of proper diameter may be used. Insulation on flanges shall not be done until the pipe and equipment have been in service during the initial operation and till all the flange bolts have been retightened.</p>  |                                      |
| 13.01.03   | <p><b>Bends and Elbows</b></p> <p>Insulation on bends and elbows shall be cut into sections sufficiently short to form a reasonable smooth external surface. After the application of insulation material in place, it shall be smoothly coated with insulating cement. Elbows may be insulated as above or alternatively by means of specially moulded insulation enclosures.</p>   |                                      |
| 13.01.04   | <p><b>Cladding</b></p> <p>Cladding shall be of aluminium sheet of thickness as per details given in detail Technical Specification or will be provided during detail engineering shall be machine rolled and formed to accurately fit insulation curvatures. Cladding shall be secured using self-tapping screws. Screws shall be adequate number and so located as to produce tight joints. The spacing of screws shall be as far as possible uniform and on centres not exceeding 150 mm. For outside diameters less than 230 mm, spacing of screws shall be on centres not exceeding 100 mm. adequate number of screws shall be provided for fixing the cladding and be so placed in such locations, as to produce a smooth cladding finish without bellying'. Insulated elbows having insulated diameters less than 330 mm shall be provided with preformed smooth aluminium elbow jackets. Wherever possible, all joints should be lapped a minimum of 50 mm with joints facing downwards and so placed that they are obscured from normal points of vision. All the joints in the cladding shall be made with suitable provisions for expansions. All butt joints such as those at piping tees</p> |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9  | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |  | PAGE<br>6 OF 53                      |

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|-----------------|---|------------------|
| 13.01.05        | <p>shall be made using rolled seams. In addition, to prevent galvanic corrosion, suitable action, as specified at clause no 13.02.00 of this chapter, shall be taken.</p> <p><b>Valves and Fittings</b></p> <p>All valves and fittings (above valve size of 2 inches) installed in the steam pipelines shall also be applied with insulation and furnished with suitably shaped boxes so as to facilitate easy dismantling of the fittings. The insulation thickness for valves, valve fittings etc., shall be same as that used on the line on which they are installed. All voids shall be properly filled up with insulating material and as per the directions of the Employer.</p>   |                  |
| 13.02.00        | <p><b>Protection of Equipment during Insulation Applications</b></p> <p>All equipment and structures shall be suitably protected from damage while applying insulation after completion of insulation. All equipment and structures shall be thoroughly cleaned and remove insulating materials which might have fallen on them.</p>  |                  |
| <b>14.00.00</b> | <p><b>CODE REQUIREMENTS</b></p> <p>The erection requirements and procedures to be followed during the installation of the equipment shall be in accordance with the relevant Indian Electricity Rules &amp; Codes, Indian Boiler Regulations, ASME codes and accepted good practices, the Employer's Drawings and other applicable Indian recognised codes and laws and regulations of the Government of India.</p>   |                  |
| <b>15.00.00</b> | <p><b>ELECTRICAL SAFETY REGULATIONS</b></p> <p>15.01.00 In no circumstances will the Contractor interfere with fuses and electrical equipment belonging to the other Contractor or Employer.</p> <p>15.02.00 Before the Contractor connects any electrical appliances to any plug or socket belonging to the other Contractor or Employer, he shall:</p> <ul style="list-style-type: none"> <li>(a) Satisfy the Employer that the appliance is in good working condition.</li> <li>(b) Inform the Employer of the maximum current rating, voltage and phase of the appliances.</li> <li>(c) Obtain permission of the Employer detailing the socket to which the appliances may be connected.</li> </ul> <p>The Employer will not grant permission to connect until he is satisfied that</p> <ul style="list-style-type: none"> <li>(d) The appliance is in good condition and is fitted with suitable plug.</li> <li>(e) The appliance is fitted with a suitable cable having two earth conductors, one of which shall be an earthened metal sheath surrounding the cores.</li> </ul> |                  |

|  |   |                                      |                 |
|--|---|--------------------------------------|-----------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>7 OF 53 |
|--|---|--------------------------------------|-----------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   |
|------------|--|
| 15.03.00   | No electric cable in use by the other Contractor/Employer will be disturbed without permission. No weight of any description will be imposed on any such cable and ladder or similar equipment will rest against or to be attached with it.  |
| 15.04.00   | No repair work shall be carried out on any live equipment. The equipment must be declared safe by the Employer and a permit to work issued before any work is carried out.   |
| 15.05.00   | The Contractor shall employ the necessary number of qualified, full time electricians to maintain his temporary electrical installation.   |
| 16.00.00   | <b>REMOVAL OF MATERIAL</b><br>No material brought to the Site shall be removed from the Site by the Contractor and/or his Sub-Contractors without the prior written approval of the Employer.  |
| 17.00.00   | <b>INSPECTION, TESTING AND INSPECTION CERTIFICATES</b><br>The provisions of the clause entitled Inspection, Testing and Inspection Certificates given in Part - C of the Technical Specification, shall also be applicable to the erection portion of the Works. The Employer shall have the right to re-inspect any equipment though previously inspected and approved by him at the Contractor's works, before and after the same are erected at Site. If by the above inspection, the Employer rejects any equipment, the Contractor shall make good for such rejections either by replacement or modification/ repairs as may be necessary to the satisfaction of the Employer. Such replacements will also include the replacements or re-execution of such of those works of other Contractors and/or agencies, which might have got damaged or affected by the replacements or re-work done to the Contractor's work. |
| 18.00.00   | <b>ACCESS TO SITE AND WORKS ON SITE</b>  |
| 18.01.00   | Suitable access to site and permission to work at the Site shall be accorded to the Contractor by the Employer in reasonable time.   |
| 18.02.00   | In the execution of the Works, no person other than the Contractor or his duly appointed representative, Sub-Contractor and workmen, shall be allowed to do work on the Site, except by the special permission, in writing by the Employer or his representative.  |
| 19.00.00   | <b>CONTRACTOR'S SITE OFFICE ESTABLISHMENT</b><br>The Contractor shall establish a Office at the Site and keep posted an authorised representative for the purpose of the Contract. Any written order or instruction of the Employer or his duly authorised representative, shall be communicated to the said authorised resident representative of the Contractor and the same shall be deemed to have been communicated to the Contractor at his legal address.   |

|  |   |                                      |                 |
|--|---|--------------------------------------|-----------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>8 OF 53 |
|--|---|--------------------------------------|-----------------|

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT  | NTPC |
|-----------------|---|------|
| <b>20.00.00</b> | <b>CO-OPERATION WITH OTHER CONTRACTORS</b>  |      |
| 20.01.00        | <p>Employer, who may be performing other works on behalf of the Employer and the workmen who may be employed by the Employer and doing work in the vicinity of the works under the Contract. The Contractor shall also arrange to perform his work as to minimise, to the maximum extent possible, interference with the work of other Contractors and their workmen. Any injury or damage that may be sustained by the employees of the other Contractors and the Employer, due to the Contractor's work shall promptly be made good at his own expense. The Employer shall determine the resolution of any difference or conflict that may arise between the Contractor and other Contractors or between the Contractor and the workmen of the Employer in regard to their work. If the work of the Contractor is delayed because of the any acts of omission of another Contractor, the Contractor shall have no claim against the Employer on that account other than an extension of time for completing his works. Employer shall have full access to visit the contractor's site at any time for inspection and surveillance checks.</p> |      |
| 20.02.00        | <p>The Employer shall be notified promptly by the Contractor of any defects in the other Contractor's works that could affect the Contractor's Works. The Employer shall determine the corrective measures if any, required to rectify this situation after inspection of the works and such decisions by the Employer shall be binding on the Contractor.</p>  |      |
| <b>21.00.00</b> | <b>DISCIPLINE OF WORKMEN</b>  |      |
|                 | <p>The Contractor shall adhere to the disciplinary procedure set by the Employer in respect of his employees and workmen at Site. The Employer shall be at liberty to object to the presence of any representative or employee of the Contractor at the Site, if in the opinion of the Employer such employee has misconducted himself or is incompetent, negligent or otherwise undesirable then the Contractor shall remove such a person objected to and provide in his place a competent replacement.</p>   |      |
| <b>22.00.00</b> | <b>CONTRACTOR'S FIELD OPERATION</b>   |      |
| 22.01.00        | <p>The Contractor shall keep the Employer informed in advance regarding his field activity plans and schedules for carrying out each part of the works. Any review of such plan or schedule or method of work by the Employer shall not relieve the Contractor of any of his responsibilities towards the field activities. Such reviews shall also not be considered as an assumption of any risk or liability by the Employer or any of his representatives and no claim of the Contractor will be entertained because of the failure or inefficiency of any such plan or schedule or method of work reviewed. The Contractor shall be solely responsible for the safety, adequacy and efficiency of plant and equipment and his erection methods.</p>  |      |
| 22.02.00        | <p>The Contractor shall have the complete responsibility for the conditions of the Work-Site including the safety of all persons employed by him or his Sub-Contractor and all the properties under his custody during the performance of the work. This requirement shall apply continuously till the completion of the Contract and shall not be limited to normal working hours. The construction review by the Employer is not intended to include review of Contractor's safety measures in, on or near the Work-Site, and their adequacy or otherwise.</p>  |      |

|  |   |                                      |                 |
|--|---|--------------------------------------|-----------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>9 OF 53 |
|--|---|--------------------------------------|-----------------|

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT  |                                      |                  |
|--|---|--------------------------------------|------------------|
| <b>23.00.00</b>  | <b>PHOTOGRAPHS AND PROGRESS REPORT</b>  |                                      |                  |
| 23.01.00   | The Contractor shall furnish three (3) prints each to the Employer of progress photographs of the work done at Site. Photographs shall be taken as and when indicated by the Employer or his representative. Photographs shall be adequate in size and number to indicate various stages of erection. Each photograph shall contain the date, the name of the Contractor and the title of the photograph.   |                                      |                  |
| 23.02.00   | The above photographs shall accompany the monthly progress report detailing out the progress achieved on all erection activities as compared to the schedules. The report shall also indicate the reasons for the variance between the scheduled and actual progress and the action proposed for corrective measures, wherever necessary.   |                                      |                  |
| 23.03.00   | The Contractor shall submit the progress of work in soft and hard form (as decided by employer) quarterly highlighting the progress and constraints at site.  |                                      |                  |
| <b>24.00.00</b>  | <b>MAN-POWER REPORT</b>   |                                      |                  |
| 24.01.00   | The Contractor shall submit to the Employer, on the first day of every month, a man hour schedule for the month, detailing the man hours scheduled for the month, skill-wise and area-wise.   |                                      |                  |
| 24.02.00   | The Contractor shall also submit to the Employer on the first day of every month, a man power report of the previous month detailing the number of persons scheduled to have been employed and actually employed, skill- wise and the areas of employment of such labour.   |                                      |                  |
| <b>25.00.00</b>  | <b>PROTECTION OF WORK</b>   |                                      |                  |
|  | The Contractor shall have total responsibility for protecting his works till it is finally taken over by the Employer. No claim will be entertained by the Employer or the representative of the Employer for any damage or loss to the Contractor's works and the Contractor shall be responsible for complete restoration of the damaged works to original conditions to comply with the specification and drawings. Should any such damage to the Contractor's Works occur because of other party not being under his supervision or control, the Contractor shall make his claim directly with the party concerned. If disagreement or conflict or dispute develops between the Contractor and the other party or parties concerned regarding the responsibility for damage to the Contractor's Works the same shall be resolved as per the provisions of the as specified at clause no 21.00.00 of this chapter entitled "Co-operation with other Contractors." The Contractor shall not cause any delay in the repair of such damaged Works because of any delay in the resolution of such disputes. The Contractor shall proceed to repair the Work immediately and no cause thereof will be assigned pending resolution of such disputes. |                                      |                  |
| <b>26.00.00</b>  | <b>EMPLOYMENT OF LABOUR</b>   |                                      |                  |
| 26.01.00   | In addition to all local laws and regulations pertaining to the employment of labour to be complied with by the Contractor pursuant to GCC, the Contractor will be expected to employ on the work only his regular skilled employees with experience of the   |                                      |                  |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9   | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>10 OF 53 |

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT  | NTPC                                 |
|--|---|--------------------------------------|
|  | particular work. No female labour shall be employed after darkness. No person below the age of eighteen years shall be employed.  |                                      |
| 26.02.00   | All travelling expenses including provisions of all necessary transport to and from Site, lodging allowances and other payments to the Contractor's employees shall be the sole responsibility of the Contractor.   |                                      |
| 26.03.00   | The hours of work on the Site shall be decided by the Employer and the Contractor shall adhere to it. Working hours will normally be eight (8) hours per day - Monday through Saturday.   |                                      |
| 26.04.00   | Contractor's employees shall wear identification badges while on work at Site.  |                                      |
| 26.05.00   | In case the Employer becomes liable to pay any wages or dues to the labour or any Government agency under any of the provisions of the Minimum Wages Act, Workmen Compensation Act, Contact Labour Regulation Abolition Act or any other law due to act of omission of the Contractor, the Employer may make such payments and shall recover the same from the Contractor's Bills.                                      |                                      |
| <b>27.00.00</b>  | <b>FACILITIES TO BE PROVIDED BY THE EMPLOYER</b>  |                                      |
| 27.01.00   | <b>Electricity</b><br><br>Refer clause 1.12.00 (Construction Power) Sub-Section III-B, Part-A, Section VI of Technical Specification.   |                                      |
| 27.02.00   | <b>Water</b><br><br>Contractor shall make all arrangements himself for the supply of construction water as well as potable water for labour and other personnel at the worksite/colony. However, drawl of construction/potable water from bore-well shall be permitted if found suitable. Any statutory clearance required shall be obtained by the contractor. Assistance, if required shall be provided by the owner. |                                      |
| 27.03.00   | <b>Communication</b><br><br>The Employer will extend the telephone facilities, if available at Site, for purposes of Contract. The Contractor shall be charged at actuals for such facilities.  |                                      |
| 27.04.00   | <b>Railway Siding</b><br>Railway siding shall be provided by owner (up to plant entry point) for coal transportation to site. However the same may not be available to the bidder for material/supplies transport etc. Bidder has to plan its own arrangement for movement of ODC consignment to plant site.  |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9   | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |   | PAGE<br>11 OF 53                     |

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT   |
|-----------------|--|
| <b>28.00.00</b> | <b>FACILITIES TO BE PROVIDED BY THE CONTRACTOR</b>   |
| 28.01.00        | <p><b>Contractor's site office Establishment</b></p> <p>The Contractor shall establish a site office at the site and keep posted an authorized representative for the purpose of the contract, pursuant to GCC. The site office will include one conference meeting room for site meetings between the Contractor and the Employer.</p>  |
| 28.02.00        | <p><b>Tools, tackles and scaffoldings</b></p> <p>The Contractor shall provide all the construction equipments, tools, tackles and scaffoldings required for pre-assembly, installation, testing, commissioning and conducting Guarantee tests of the equipments covered under the Contract. He shall submit a list of all such materials to the Employer before the commencement of pre-assembly at Site. These tools and tackles shall not be removed from the Site without the written permission of the Employer. The Contractor shall arrange Dozer, Hydra, Cranes, Trailer, etc. for the purpose of fabrication, erection and commissioning.</p>  |
| 28.03.00        | <p><b>Testing Equipment and Facilities:</b></p> <p>The contractor shall provide the necessary testing, equipment and facilities.</p>   |
| 28.04.00        | <p><b>Site laboratory for civil works:</b></p> <p>Contractor shall provide and maintain a site laboratory for the testing of construction material under the direction and general supervision of employer.</p>  |
| 28.05.00        | <p><b>First-aid</b></p>  |
| 28.05.01        | <p>The Contractor shall provide necessary first-aid facilities for all his employees, representatives and workmen working at the Site. Enough number of Contractor's personnel shall be trained in administering first-aid.</p>  |
| 28.05.02        | <p>The Employer will provide the Contractor, in case of any emergency, the services of an ambulance for transportation to the nearest hospital.</p>  |
| 28.06.00        | <p><b>Cleanliness</b></p>  |
| 28.06.01        | <p>The Contractor shall be responsible for keeping the entire area allotted to him clean and free from rubbish, debris etc. during the period of Contract. The Contractor shall employ enough number of special personnel to thoroughly clean his work-area at least once in a day. All such rubbish and scrap material shall be stacked or disposed in a place to be identified by the Employer. Materials and stores shall be so arranged to permit easy cleaning of the area. In areas where equipment might drip oil and cause damage to the floor surface, a suitable protective cover of a flame resistant, oil proof sheet shall be provided to protect the floor from such damage.</p> |
| 28.06.02        | <p>Similarly the offices shall be kept clean and neat to the entire satisfaction of the Employer. Proper sanitary arrangements shall be provided by the Contractor, in the work-areas and office areas of the Contractor.</p>  |
| <b>29.00.00</b> | <b>LINES AND GRADES</b>  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>12 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|-----------------|---|------------------|
|                 | <p>All the Works shall be performed to the lines, grades and elevations indicated on the drawings. The Contractor shall be responsible to locate and layout the Works. Basic horizontal and vertical control points will be established and marked by the Employer at Site at suitable points. These points shall be used as datum for the works under the Contract. The Contractor shall inform the Employer well in advance of the times and places at which he wishes to do work in the area allotted to him so that suitable datum points may be established and checked by the Employer to enable the Contractor to proceed with his works. Any work done without being properly located may be removed and/or dismantled by the Employer at Contractor's expense.</p>   |                  |
| <b>30.00.00</b> | <b>FIRE PROTECTION</b>  |                  |
| 30.01.00        | <p>The work procedures that are to be used during the erection shall be those which minimise fire hazards to the extent practicable. Combustible materials, combustible waste and rubbish shall be collected and removed from the Site at least once each day. Fuels, oils and volatile or flammable materials shall be stored away from the construction and equipment and materials storage areas in safe containers. Untreated canvas, paper, plastic or other flammable flexible materials shall not at all be used at Site for any other purpose unless otherwise specified. If any such materials are received with the equipment at the Site, the same shall be removed and replaced with acceptable material before moving into the construction or storage area.</p> |                  |
| 30.02.00        | <p>Similarly corrugated paper fabricated cartons etc. will not be permitted in the construction area either for storage or for handling of materials. All such materials used shall be of water proof and flame resistant type. All the other materials such as working drawings, plans etc. which are combustible but are essential for the works to be executed shall be protected against combustion resulting from welding sparks, cutting flames and other similar fire sources.</p>   |                  |
| 30.03.00        | <p>All the Contractor's supervisory personnel and sufficient number of workers shall be trained for fire-fighting and shall be assigned specific fire protection duties. Enough of such trained personnel must be available at the Site during the entire period of the Contract.</p>   |                  |
| 30.04.00        | <p>The Contractor shall provide enough fire protection equipment of the types and number for the warehouses, office, temporary structures, labour colony area etc. Access to such fire protection equipment, shall be easy and kept open at all time.</p>   |                  |
| <b>31.00.00</b> | <b>SECURITY</b>   |                  |
|                 | <p>The Contractor shall have total responsibility for all equipment and materials in his custody stores, loose, semi-assembled and/or erected by him at Site. The Contractor shall make suitable security arrangements including employment of security personnel to ensure the protection of all materials, equipment and works from theft, fire, pilferage and any other damages and loss. All materials of the Contractor shall enter and leave the Employer Site only with the written permission of the Employer in the prescribed manner.</p>   |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>13 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
| 32.00.00   | <b>CONTRACTOR'S AREA LIMITS</b> <p>The Employer will mark-out the boundary limits of access roads, parking spaces, storage and construction areas for the Contractor and the Contractor shall not trespass the areas not so marked out for him. The Contractor shall be responsible to ensure that none of his personnel move out of the areas marked out for his operations. In case of such a need for the Contractor's personnel to work out of the areas marked out for him the same shall be done only with the written permission of the Employer.</p>  |                  |
| 33.00.00   | <b>CONTRACTOR'S CO-OPERATION WITH THE EMPLOYER</b> <p>In case where the performance of the erection work by the Contractor affects the operation of the system facilities of the Employer, such erection work of the Contractor shall be scheduled to be performed only in the manner stipulated by the Employer and the same shall be acceptable at all times to the Contractor. The Employer may impose such restrictions on the facilities provided to the Contractor such as electricity, etc. as he may think fit in the interest of the Employer and the Contractor shall strictly adhere to such restrictions and co-operate with the Employer. It will be the responsibility of the Contractor to provide all necessary temporary instrumentation and other measuring devices required during start-up and operation of the equipment systems which are erected by him. The Contractor shall also be responsible for flushing and initial filling of all the oil and lubricants required for the equipment furnished and installed by him, so as to make such equipment ready for operation. The Contractor shall be responsible for supplying such flushing oil and other lubricants unless otherwise specified elsewhere in documents and specifications.</p> |                  |
| 34.00.00   | <b>PRE-COMMISSIONING AND COMMISSIONING ACTIVITIES</b>   |                  |
| 34.01.00   | <b>GENERAL</b>  |                  |
| 34.01.01   | <p>The Contractor upon completion of installation of equipments and systems, shall conduct pre-commissioning and commissioning activities, to make the equipment/systems ready for safe, reliable and efficient operation on sustained basis. All pre-commissioning/commissioning activities considered essential for such readiness of the equipment/systems including those mutually agreed and included in the Contractor's quality assurance programme as well as those indicated in clauses elsewhere in the technical specifications shall be performed by the contractor.</p>  |                  |
| 34.01.02   | <p>The pre-commissioning and commissioning activities including Guarantee/ demonstration/ acceptability tests, checks and trial operations of the equipment/systems furnished and installed by the contractor shall be the responsibility of the Contractor as detailed in relevant clauses in Technical Specification. The Contractor shall provide, in addition, test instruments, calibrating devices etc. and labour required for successful performance of these operations. If it is anticipated that the above test may prolong for a long time, the Contractor's workmen required for the above test shall always be present at site during such operations.</p>  |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>14 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
| 34.01.03   | <p>The following activities shall be carried out by the contractor, 18 month prior to schedule date of commissioning of the equipment/systems installed by him.</p> <p>(a.) The contractor shall furnish the organization chart of his operation and commissioning engineers for the acceptance of employer. Adequate number of operation and commissioning engineers shall be deployed by the contractor to effectively meet the requirement of round the clock operation in shifts also, till the plant is taken over by the employer.</p> <p>(b.) The contractor shall submit the bio-data containing the details of experience of his operation and commissioning engineers for the acceptance of employer.</p> <p>(c.) The contractor shall furnish the deployment schedule of his operation and commissioning engineers for the acceptance of the employer.</p> <p>(d.) Apart from above, contractor shall ensure deployment of sufficient skilled/semi-skilled/unskilled manpower during pre-commissioning and commissioning activities.</p> |                  |
| 34.01.04   | <p>It shall be the responsibility of the Contractor to provide all necessary temporary instrumentation and other measuring devices required during start-up and initial operation of the equipment/systems which are installed by him.</p>  |                  |
| 34.01.05   | <p>The Contractor shall also be responsible for flushing and initial filling of all oils and lubricants required for the equipment furnished and installed by him so as to make such equipment ready for operation. The Contractor shall be responsible for supplying such flushing oil and other lubricants unless otherwise specified elsewhere in these specifications and documents.</p>  |                  |
| 34.02.00   | <b>COMMISSIONING DOCUMENTATION</b>  |                  |
| 34.02.01   | <p>The contractor shall submit the commissioning documentation, comprising of Standard checklists, pre-commissioning procedures, testing schedules, commissioning schedules and commissioning networks for various equipment/systems covered under the contract, for the approval of employer.</p>  |                  |
| 34.02.02   | <p>Standard checklist, as the name suggests, shall be a fairly general documents, containing the list of all checks required to be carried out for similar and repetitive type of equipment to ensure consistent and thorough checking. An indicative list of such equipment is enclosed as Annexure I.</p>   |                  |
| 34.02.03   | <p>The testing schedule is a document, designed for safe and systematic commissioning of individual equipment/sub-system (for example compressor etc.) Commissioning schedule is a document envisaged for commissioning of a system (for example Compressed Air system, Unit commissioning etc.). The testing/Commissioning schedule shall have a standard format in order to maintain consistency of presentation, content and reporting. A brief write up on the contents of the Testing Schedule/Commissioning Schedule is enclosed as Annexure-II.</p>  |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>15 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  |
|------------|---|
| 34.02.04   | The contractor shall submit the list of commissioning documentation to be submitted by him, along with their submission schedule for various equipment/systems covered under the contract, with in 6(six) month from the date of award of contract, for the acceptance of employer.   |
| 34.02.05   | The Contractor shall submit the commissioning documentation, for various equipment/covered under the contract, for the approval of employer, at least 18 months before the scheduled date of commissioning of the equipment/systems.  |
| 34.03.00   | <b>COMMISSIONING ACTIVITIES</b>   |
| 34.03.01   | Upon completion of pre-commissioning activities/tests, the contractor shall initiate commissioning of facilities. During commissioning the Contractor shall carry out system checking and reliability trials on various parts of the facilities.  |
| 34.03.02   | Contractor shall carry out the checks/tests at site to prove to the Employer that each equipment of the supply complies with requirements stipulated and is installed in accordance with requirements specified.  |
| 34.03.03   | Before the plant is put into initial operation the Contractor shall be required to conduct test to demonstrate to the Employer that each item of the plant is capable of correctly performing the functions for which it was specified and its performance, parameters etc. are as per the specified/approved values. These tests may be conducted concurrently with those required under commissioning sequence.                 |
| 34.03.04   | The Contractor shall also demonstrate the performance of all C&I equipment, the tests on main equipment of prior to that as the case may be.  |
| 34.03.05   | Other tests shall be conducted, if required by the Employer, to establish that the plant equipment are in accordance with requirements of the specifications.   |
| 34.03.06   | The Contractor shall conduct all the commissioning tests and undertake commissioning activities pertaining to all other auxiliaries and equipments including all electrical and C&I equipment/systems not specifically brought out above but are within the scope of work and facilities being supplied and installed by the Contractor and follow the guidelines indicated above or elsewhere in these technical specifications. |
| 34.05.00   | <b>Initial Operation</b><br><br>Upon completion of system checking/Tests as above and as a part of commissioning of facilities, complete plant/facilities shall be put on initial operation as stipulated in General Technical Requirements.  |
| 35.00.00   | <b>MATERIALS HANDLING AND STORAGE</b>   |
| 35.01.00   | All the equipments furnished under the Contract and arriving at Site shall be promptly received, unloaded and transported and stored in the storage spaces by the Contractor.   |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>16 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  |
|------------|---|
| 35.02.00   | Contractor shall be responsible for examining all the shipment and notify the Employer immediately of any damage, shortage, discrepancy etc. for the purpose of Employer's information only. The Contractor shall submit to the Employer every week a report detailing all the receipts during the week. However, the Contractor shall be solely responsible for any shortages or damage in transit, handling and / or in storage and erection of the equipment at Site. Any demurrage, wharfage and other such charges claimed by the transporters, railways etc. shall be to the account of the Contractor. |
| 35.03.00   | The Contractor shall maintain an accurate and exhaustive record detailing out the list of all equipment received by him for the purpose of erection and keep such record open for the inspection of the Employer.   |
| 35.04.00   | All equipment shall be handled very carefully to prevent any damage or loss. No bare wire ropes, slings, etc. shall be used for unloading and/or handling of the equipment without the specific written permission of the Employer. The equipment stored shall be properly protected to prevent damage either to the equipment or to the floor where they are stored. The equipment from the store shall be moved to the actual location at the appropriate time so as to avoid damage of such equipment at Site.   |
| 35.05.00   | All electrical panels, controls gear, motors and such other devices shall be properly dried by heating before they are installed and energised. Motor bearings, slip rings, commutators and other exposed parts shall be protected against moisture ingress and corrosion during storage and periodically inspected. Heavy rotating parts in assembled conditions shall be periodically rotated to prevent corrosion due to prolonged storage.  |
| 35.06.00   | All the electrical equipment such as motors, etc. shall be tested for insulation resistance at least once in three months from the date of receipt till the date of commissioning and a record of such measured insulation values maintained by the Contractor. Such records shall be open for inspection by the Employer.  |
| 35.07.00   | The Contractor shall ensure that all the packing materials and protection devices used for the various equipments during transit and storage are removed before the equipment are installed.  |
| 35.08.00   | The consumables and other supplies likely to deteriorate due to storage must be thoroughly protected and stored in a suitable manner to prevent damage or deterioration in quality by storage.  |
| 35.09.00   | All the materials stored in the open or dusty location must be covered with suitable weatherproof and flame-proof covering material wherever applicable.  |
| 35.10.00   | If the materials belonging to the Contractor are stored in areas other than those earmarked for him, the Employer will have the right to get it moved to the area earmarked for the Contractor at the Contractor's cost.  |
| 35.11.00   | The Contractor shall be responsible for making suitable indoor storage facilities to store all equipment which require indoor storage. Normally, all the electrical equipments such as motors, control gear, generators, exciters and consumables like  |

| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>17 OF 53 |
|--|---|--------------------------------------|------------------|
|--|---|--------------------------------------|------------------|

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|-----------------|---|------------------|
|                 | electrodes, lubricants etc. shall be stored in the closed storage space. The Employer, in addition, may direct the Contractor to move certain other materials, which in his opinion will require indoor storage, to indoor storage areas which the Contractor shall strictly comply with.   |                  |
| <b>36.00.00</b> | <b>CONSTRUCTION MANAGEMENT</b>  |                  |
| 36.01.00        | The field activities of the Contractors working at Site, will be coordinated by the Employer and the Employer decision shall be final in resolving any disputes or conflicts between the Contractor and other Contractors and tradesmen of the Employer regarding scheduling and co-ordination of work. Such decision by the Employer shall not be a cause for extra compensation or extension of time for the Contractor.  |                  |
| 36.02.00        | The Employer shall hold weekly meetings of all the Contractors working at Site, at a time and place to be designated by the Employer. The Contractor shall attend such meetings and take notes of discussions during the meeting and the decisions of the Employer and shall strictly adhere to those decisions in performing his Works. In addition to the above weekly meeting, the Employer may call for other meeting either with individual Contractors or with selected number of Contractors and in such a case the Contractor if called, will also attend such meetings.  |                  |
| 36.03.00        | Time is the essence of the Contract and the Contractor shall be responsible for performance of his works in accordance with the specified construction schedule. If at any time, the Contractor is falling behind the schedule, he shall take necessary action to make good for such delays by increasing his work force or by working overtime or otherwise accelerate the progress of the work to comply with the schedule and shall communicate such actions in writing to the Employer, satisfying that his action will compensate for the delay. The Contractor shall not be allowed any extra compensation for such action. |                  |
| 36.04.00        | The Employer shall however not be responsible for provision of additional labour and/or materials or supply or any other services to the Contractor except for the co-ordination work between various Contractors as set out earlier.   |                  |
| 36.05.00        | <b>Site management during construction phase till handing over of plant</b><br><br>Bidder shall ensure that the plant site within the plant boundary is managed in a coordinated and professional way all through the construction phase till handing over of plant, ensuring safe, easy & unhindered working conditions and a healthy & hygienic working environment at site. He shall ensure the following measures at site while executing the project.  |                  |
| a)              | Proper housekeeping by systematic and proper disposal of earth from excavations (separately for usable & surplus earth), muck (from pile bores or otherwise), wastes (from dismantling of pile tops, concrete works etc), packing & insulation wastes, steel scrap, cable wastes etc generated during construction / erection works. Suitable disposal sites for each of above shall be identified in the layout and at site in the beginning of the project itself. It shall be ensured that all agencies engaged by the bidder follow the discipline to dispose off of earth spoils and wastes at the                           |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>18 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC |
|------------|--|------------------|
|            | <p>designated places. Preferably once in a week suitable time slot will be identified for housekeeping by all agencies and suitable instructions shall be issued in this regard. Bidder may engage a separate agency or identify a gang for collection of wastes and disposal to designated places. Suitable arrangement / tieup will also be made for periodic disposal of wastes/ scrap from the designated places.</p> <p><b>b)</b> All fabrication areas shall be suitably hard crusted to provide a water free and proper working platforms. Suitable sheds preferably pre engineered structures to be provided for paint shops, fabrication workshops etc for ensuring all weather work conditions for onsite structural works. For the main plant and auxiliary buildings, bidder should preferably plan the works in such a way that structural fabrication is done in suppliers' offsite works / workshops and onsite fabrication works are avoided / kept minimum.</p> <p><b>c)</b> Suitable onsite maintenance workshop for day to day breakdown maintenance heavy plant and equipment like batching plants, cranes, earth moving equipment, poclaims, welding equipment etc. The workshop shall have stock of frequently needed spares and suitable repair facilities with experienced technicians/mechanics. A central test laboratory equipped with test equipment for routine tests like tests on soil, concrete, bricks, aggregates, welds etc with experienced staff shall be established at the start of the project itself.</p> <p><b>d)</b> All office and covered store buildings of the bidder and its agencies shall be of prefab/ pre-engineered / porta cabin construction. Shabby semi finished constructions in brickwork/ GI / asbestos roof etc shall not be permitted.</p> <p><b>e)</b> First aid facilities and amenities like rest rooms, suitable pre engineered toilets (separate for men and women), drinking water fountains/tanks, canteen, crèche for women workers shall be planned and established at the beginning of the project itself. These facilities shall be located distributed over the plant area to enable easy access by the construction workers and staff and shall be marked on the plant layout. Suitable treatment for toilet discharge, like bio digesters etc shall be planned and conventional septic tanks / soak pits etc shall be avoided.</p> <p><b>f)</b> Proper lighting of all construction / erection areas. Bidder shall erect adequate number of high lighting masts in main plant, offsite, office and store areas for lighting during night. DG sets of adequate capacity shall be provided for emergency backup. The street lighting along the roads shall also be prioritised along with road construction. The construction power ring main shall be planned and erected immediately after the award.</p> <p><b>g)</b> Well planned and coordinated storage and movement of plant, equipment and construction materials. System wise / agency wise storage / laydown areas shall be planned and marked on the plant layout at the beginning itself. Bidder shall ensure that all its agencies comply to the areas allocated to them and follow the designated storage and movement plans. Adequate covered storage shall be constructed for storage of critical equipments like switchgears, MCCs, insulation etc.</p> <p><b>h)</b> Proper access control for construction workers, staff and visitors. Bidder shall ensure that suitable electronic based gate pass system is in place from start of project itself</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>19 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|------------|--|------|
|            | <p>to keep record and track of all workers, staff and visitors entering/exiting the plant premises shift wise on daily basis.</p> <p>i) Compliance to all safety requirements as specified elsewhere in the tender documents. Bidders shall establish a safety centre at the start of the project itself. It shall have a 24X7 manned safety control room in addition to a permanent safety equipment display room, separate training / lecture hall with AV facilities for safety training, store room with adequate stock of specified safety equipment, a first aid room and other amenities. Bidder shall install CCTV cameras at all strategic locations in the plant area which shall be linked to the safety control room.</p> <p>j) Compliance to all environment and other conditions stipulated by the concerned statutory authorities while according clearance / NOC to the project. Bidder shall ensure adequate sprinkling of water by deploying water tankers to prevent the fugitive dust nuisance during construction.</p> <p>k) Development of suitable landscape &amp; green belt areas and rainwater harvesting within the plant premises. Bidder shall plan to develop the landscape &amp; green belt areas and rainwater harvesting from the start of the project itself. The landscape and rainwater harvesting plan shall be finalized immediately after award of work and suitable work plan with priority and schedule shall also be finalized thereafter. Top soil before excavation shall be suitably preserved and stacked for landscape and green belt development.</p> <p>l) Provision of adequate shelters, water supply, sanitation and lighting in construction workers and staff camps. No camps for workers and staff shall be permitted within the plant premises and Bidder shall make separate arrangement outside the plant premises for locating and development of camps for construction workers and staff. The designated areas shall be suitably developed with infrastructure like roads, drains, water supply and sewerage and shall be free from water logging. Suitable low cost shelters will be provided for the workers. Complete area shall be secured by fencing and shall be provided adequate area lighting. Suitable waste disposal, shopping and recreation facilities will be developed in these camps.</p> <p>Contractor shall ensure that due importance is given to site management as discussed above and a detailed work plan considering the above aspects is finalized immediately after the award. A senior level executive shall be identified who shall be responsible for implementation of the work plan. Suitable format for progress reporting on site management plan shall be developed and made part of the project progress report. The progress on implementation of above work plan shall be reviewed along with project progress in the monthly project review meetings with owner. In case the progress on site management plan is unsatisfactory, Engineer-in Charge may withhold upto 1% of the monthly running bill (for civil and site erection works) till such time the required progress is demonstrated. Incase in the opinion of Engineer-in-charge, bidder's actions on site management aspects is not adequate, Engineer-in- charge may get the relevant work executed through a separate agency and deduct the expenses incurred from Bidder's bill along with overheads @10 %.</p> |      |
| 37.00.00   | <b>FIELD OFFICE RECORDS</b>  |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>20 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC                     |
|--|--|--------------------------------------|
|  | <p>The Contractor shall maintain at his Site Office up-to- date copies of all drawings, specifications and other Contract Documents and any other supplementary data complete with all the latest revisions thereto. The Contractor shall also maintain in addition the continuous record of all changes to the above Contract Documents, drawings, specifications, supplementary data, etc. effected at the field and on completion of his total assignment under the Contract shall incorporate all such changes on the drawings and other Engineering data to indicate as installed conditions of the equipment furnished and erected under the Contract. Such drawings and Engineering data shall be submitted to the Employer in required number of copies.</p> |                                      |
| <b>38.00.00</b>  | <b>CONTRACTOR'S MATERIALS BROUGHT ON TO SITE</b>   |                                      |
| 38.01.00   | <p>The Contractor shall bring to Site all equipment, components, parts, materials, including construction equipment, tools and tackles for the purpose of the Works under intimation to the Employer. All such goods shall, from the time of their being brought vest in the Employer, but may be used for the purpose of the Works only and shall not on any account be removed or taken away by the Contractor without the written permission of the Employer. The Contractor shall nevertheless be solely liable and responsible for any loss or destruction thereof and damage thereto.</p>  |                                      |
| 38.02.00   | <p>The Employer shall have a lien on such goods for any sum or sums which may at any time be due or owing to him by the Contractor, under, in respect of or by reasons of the Contract. After giving a fifteen (15) days notice in writing of his intention to do so, the Employer shall be at liberty to sell and dispose off any such goods, in such manner as he shall think fit including public auction or private treaty and to apply the proceeds in or towards the satisfaction of such sum or sums due as aforesaid.</p>  |                                      |
| 38.03.00   | <p>After the completion of the Works, the Contractor shall remove from the Site under the direction of the Employer the materials such as construction equipment, erection tools and tackles, scaffolding etc. with the written permission of the Employer. If the Contractor fails to remove such materials, within fifteen (15) days of issue of a notice by the Employer to do so then the Employer shall have the liberty to dispose off such materials as detailed under as specified at clause no 39.02.00 of this chapter and credit the proceeds thereto to the account of the Contractor.</p>   |                                      |
| <b>39.00.00</b>  | <b>PROTECTION OF PROPERTY AND CONTRACTOR'S LIABILITY</b>   |                                      |
| 39.01.00   | <p>The Contractor shall be responsible for any damage resulting from his operations. He shall also be responsible for protection of all persons including members of public and employees of the Employer and the employees of other Contractors and Sub- Contractors and all public and private property including structures, building, other plants and equipments and utilities either above or below the ground.</p>  |                                      |
| 39.02.00   | <p>The Contractor will ensure provision of necessary safety equipment such as barriers, sign - boards, warning lights and alarms, etc. to provide adequate protection to persons and property. The Contractor shall be responsible to give reasonable notice to the Employer and the Employers of public or private property and utilities when such property and utilities are likely to get damaged or injured during the performance of his Works and shall make all necessary arrangements with such</p>   |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9  | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |  | PAGE<br>21 OF 53                     |

| CLAUSE NO.  | ERCTION CONDITIONS OF CONTRACT   |  |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
|---|--|---|---------------------------------------|------------------------|---|-----------------------------|----------------------|---|-----------------------------|-----------------|---|----------------------------|
| 40.00.00  | <p>Employers, related to removal and/or replacement or protection of such property and utilities.</p> <p><b>PAINTING</b></p> <p>For painting refer Part-A, sub section-III, Section VI of Technical specification.</p> <p>Painting for structures shall conform to the painting specification specified in Part-B under Civil.</p> <p>Painting for Electrical equipments/systems shall conform to the painting specification given in Electrical portion of Part-A and Part-B of technical specifications.</p>   |   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.00.00  | <p><b>INSURANCE</b></p>  |   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.01.00  | <p>In addition to the conditions covered under the Clause entitled "Insurance" in Section General Conditions of Contract (GCC), the following provisions will also apply to the portion of works to be done beyond the Contractor's own or his Sub-Contractor's manufacturing Works.</p>   |   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.02.00  | <p><b>Workmen's Compensation Insurance</b></p> <p>This insurance shall protect the Contractor against all claims applicable under the Workmen's Compensation Act, 1948 (Government of India). This policy shall also cover the Contractor against claims for injury, disability disease or death of his or his Sub-Contractor's employees, which for any reason are not covered under the Workmen's Compensation Act, 1948. The liabilities shall not be less than the following:</p> <table> <tr> <td>Workmen's Compensation</td><td>-</td><td>As per Statutory Provisions</td></tr> <tr> <td>Employee's Liability</td><td>-</td><td>As per Statutory Provisions</td></tr> </table>                       |   |                                       | Workmen's Compensation | - | As per Statutory Provisions | Employee's Liability | - | As per Statutory Provisions |                 |   |                            |
| Workmen's Compensation  | -  | As per Statutory Provisions   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| Employee's Liability  | -  | As per Statutory Provisions   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.03.00  | <p><b>Comprehensive Automobile Insurance</b></p> <p>This insurance shall be in such a form to protect the Contractor against all claims for injuries, disability, disease and death to members of public including the Employer's men and damage to the property of other arising from the use of motor vehicles during on or off the Site operations, irrespective of the Ownership of such vehicles. The liability covered shall be as herein indicated :</p> <table> <tr> <td>Fatal Injury</td><td>:</td><td>Rs.100,000 each person</td></tr> <tr> <td></td><td>:</td><td>Rs.200,000 each occurrence</td></tr> <tr> <td>Property Damage</td><td>:</td><td>Rs.100,000 each occurrence</td></tr> </table> |   |                                       | Fatal Injury           | : | Rs.100,000 each person      |                      | : | Rs.200,000 each occurrence  | Property Damage | : | Rs.100,000 each occurrence |
| Fatal Injury  | :  | Rs.100,000 each person  |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
|   | :  | Rs.200,000 each occurrence  |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| Property Damage   | :  | Rs.100,000 each occurrence  |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.04.00  | <p><b>Comprehensive General Liability Insurance</b></p>  |   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| 41.04.01  | <p>The insurance shall protect the Contractor against all claims arising from injuries, disabilities, disease or death of members of public or damage to property of others,</p>   |   |                                       |                        |   |                             |                      |   |                             |                 |   |                            |
| LOT-IB PROJECTS<br><b>FLUE GAS DESULPHURISATION (FGD)<br/>           SYSTEM PACKAGE</b> |  | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9   | ERECTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>22 OF 53       |   |                             |                      |   |                             |                 |   |                            |

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC |
|-----------------|--|------------------|
| 41.04.02        | <p>due to any act or omission on the part of the Contractor, his agents, his employees, his representatives and Sub-Contractors or from riots, strikes and civil commotion. This insurance shall also cover all the liabilities of the Contractor arising out of the Clause entitled "Defence of Suits" in Section General Conditions of Contract (GCC).</p> <p>The hazards to be covered will pertain to all the Works and areas where the Contractor, his Sub-Contractors, his agents and his employees have to perform work pursuant to the Contract.</p>   |                  |
| 41.05.00        | <p>The above are only illustrative list of insurance covers normally required and it will be the responsibility of the Contractor to maintain all necessary insurance coverage to the extent both in time and amount to take care of all his liabilities either direct or indirect, in pursuance of the Contract.</p>  |                  |
| <b>42.00.00</b> | <b>UNFAVOURABLE WORKING CONDITIONS</b>   |                  |
|                 | <p>The Contractor shall confine all his field operations to those works which can be performed without subjecting the equipment and materials to adverse effects during inclement weather conditions, like monsoon, storms, etc. and during other unfavourable construction conditions. No field activities shall be performed by the Contractor under conditions which might adversely affect the quality and efficiency thereof, unless special precautions or measures are taken by the Contractor in a proper and satisfactory manner in the performance of such Works and with the concurrence of the Employer. Such unfavourable construction conditions will in no way relieve the Contractor of his responsibility to perform the Works as per the schedule.</p>                                       |                  |
| <b>43.00.00</b> | <b>PROTECTION OF MONUMENTS AND REFERENCE POINTS</b>  |                  |
|                 | <p>The Contractor shall ensure that any finds such as relic, antiquity, coins, fossils, etc. which he may come across during the course of performance of his Works either during excavation or elsewhere, are properly protected and handed over to the Employer. Similarly the Contractor shall ensure that the bench marks, reference points, etc., which are marked either with the help of Employer or by the Employer shall not be disturbed in any way during the performance of his Works. If, any work is to be performed which disturb such reference, the same shall be done only after these are transferred to other suitable locations under the direction of the Employer. The Contractor shall provide all necessary materials and assistance for such relocation of reference points etc.</p> |                  |
| <b>44.00.00</b> | <b>WORK &amp; SAFETY REGULATIONS</b>   |                  |
| 44.01.00        | <p><b>General</b></p> <p>i) The contractor shall comply with all the requirements of "The Building and Other Construction Workers (Regulation of Employment &amp; Conditions of Service) Act," 1996 and its Central Rule 1998 / State Rules and any other statutory requirements as applicable.</p>  |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>23 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC |
|------------|--|------------------|
|            | <p>ii) The Contractor shall follow NTPC Safety Rules as issued from time to time with respect to safety in construction &amp; erection.</p> <p>iii) The contractor shall have the approved Safety, Health and Environment (SHE) Policy in respect of Safety and health of Building Workers and it shall be circulated widely and displayed at conspicuous place in Hindi and local language understood by the majority of the workers. A copy of the safety policy should be submitted to Engineer in charge.</p> <p>iv) The contractor shall submit the safety plan comprising of methods to implement the Safety Policy/ Rules, Risk assessment and ensuring Safety at work areas, Safety audits, inspections and its compliance, Supervision and responsibility to ensure Safety at various levels, Safety training to employees, review of Safety and accident analysis, ensure Health and Safety Procedures to prevent accidents to Engineer I/c for approval as per the format of Safety plan as annexed at Annexure - III.</p> <p>v) The Contractors shall ensure proper safety of all the workmen, materials, plant and equipment belonging to him or to the Employer or to others, working at the Site.</p> <p>vi) All equipments used in construction and erection by the contractor shall meet BIS / International Standards and where such standards do not exist, the Contractor shall ensure these to be absolutely safe. All equipments shall be strictly operated and maintained by the contractor in accordance with manufacturer's operation manual. The contractor should also follow Guidelines / Rules of the Employer in this regard.</p> <p>vii) The Contractors shall provide suitable latest Personal Protective Equipments of prescribed standard to all their employees and workmen according to the need. The Engineer I/c shall have the right to examine these safety equipments to determine their suitability, reliability, acceptability and adaptability. The contractor should also ensure these before their use at worksite.</p> <p>viii) The Contractor shall provide safe working conditions to all workmen and employees at his workplace including safe means of access, railings, stairs, and ladders, scaffolding, work platforms, toe boards etc. The scaffoldings shall be erected under the control and supervision of an experienced and competent person. For erection of scaffolds, access, work platforms etc. shall be good and the contractor shall use standard quality of material.</p> <p>ix) The Contractor shall follow and comply with all the Safety Rules, standards, code of practices of NTPC and relevant provisions of applicable laws pertaining to the safety of workmen, employees, plant and equipment as may be prescribed from time to time without any protest or contest or reservation. In case of any nonconformity between statutory requirement and the Safety Rules of the Employer referred above, the latter shall be binding on the Contractor unless the statutory provisions are more stringent. As and when required he can refer / obtain copy of NTPC safety documents as stated above.</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>24 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|------------|--|------|
|            | <p>x) The contractor shall have his own arrangements with nearby hospitals for shifting and treatment of sick and injured.</p> <p>The medical examination of the workers employed in hazardous areas shall be conducted as per Rule 223 Of The Building and Other Construction Worker (Regulation of Employment and Condition of Service) Central Rule 1998 Their health records shall be maintained accordingly and to be submitted to Engineer I/c when asked for. If any worker found suffering from occupational health hazard, the worker should be shifted to suitable place of working and properly treated under intimation to Engineer I/c. The medical fitness certificate to be submitted to Engineer (I/c).</p> <p>xi) First Aid boxes equipped with requisite articles as specified in the Rule 231 of The Building and Other Construction Worker (Regulation of Employment and Condition of Service) Central Rule 1998 shall be provided at construction sites for the use of workers. Training has to be provided on first aid to workmen &amp; office bearers working at site.</p> |      |
| 44.01.01   | <p><b>Emergency Action Plan</b></p> <p>The contractor shall prepare an emergency action plan approved by his competent authority to handle any emergency occurred during construction work. Regular mock drills shall be organized to practice this emergency plan. The Emergency Action Plan should be widely circulated to all the employees and suitable infrastructure shall be provided to handle the emergencies.</p>  |      |
| 44.01.02   | <p><b>Scaffolding</b></p> <p>The contractor shall take all precautions to prevent any accidental collapse of scaffolding or fall of persons from scaffolding. The contractor should ensure that scaffolding are designed by a competent person and it erection and repairs should be done under the expert supervision. The scaffolding shall meet the required strength and other requirements for the purpose for which the scaffold is erected. The material used for scaffold should conform to the BIS / International standards.</p>   |      |
| 44.01.03   | <p><b>Opening</b></p> <p>The contractor shall ensure that there is no opening in any working platform/any floor of the building, which may cause fall of workers or material. When ever an opening on a platform/any floor of the building is unavoidable, the opening should be suitably fenced and necessary measures for protection against falling objects or building workers from such platform are taken by providing suitable safety nets, safety belts or other similar means.</p>  |      |
| 44.01.04   | <p><b>Explosives</b></p> <p>The contractor shall take all precautions while handling, using, storing or transporting of all explosives. Before usage of any explosive necessary warning / danger signals be erected at conspicuous places to warn the workers and general public. The contractor should strictly ensure that all measures and precautions</p>  |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>25 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|------------|--|------|
| 44.02.00   | <p>required to be complied for use, handling, storing or transportation of explosives under the rules framed under the Explosives Act, 1884.</p> <p><b>Fencing of Machinery</b></p> <p>The contractor shall provide suitable fencing or guard to all dangerous and moving parts of machinery.</p> <p>The contractor shall not allow any of the employees to clean, lubricate, repair, adjust or examine during machinery in motion, which may cause injury to the person.</p>  |      |
| 44.03.00   | <p><b>Carrying of Excessive Weight by a Worker</b></p> <p>The worker shall not be allowed to lift by hand or carry over his head, back or shoulder more than the maximum limit set by the prescribed rules for the construction Workers.</p>   |      |
| 44.04.00   | <p><b>Dangerous and Harmful Gases / Equipment</b></p> <p>The contractor shall ensure that the workers are not exposed to any harmful gases during any construction activity including excavation, tunneling, confined spaces etc.</p> <p>The contractor should not allow any worker to go into the confined space unless it is certified by Engineer (I/c) to be safe and fit for the entry to such work place. Proper record and work permits should be followed to carry out such works.</p>   |      |
| 44.05.00   | <p><b>Overhead Protection</b></p> <p>The contractor shall ensure that any area exposed to risk of falling materials, articles or objects is roped off or cordoned off or otherwise suitably guarded from inadvertent entry of any person.</p> <p>Wherever there is a possibility of falling of any material, equipment or construction workers while working at heights, a suitable and adequate safety net should be provided. The safety net should be in accordance with BIS Standards.</p>   |      |
| 44.06.00   | <p><b>Working at Heights</b></p> <p>All working platforms, ways and other places of construction work shall be free from accumulations of debris or any other material causing obstructions and tripping.</p> <p>Wherever workers are exposed to the hazard of falling into water, the contractor shall provide adequate equipment for saving the employees from drowning and rescuing from such hazards. The contractor shall provide boat or launch equipped with sufficient number of life buoys, life jackets etc. manned with trained personnel at the site of such work.</p> <p>Every opening at elevation from ground level through which a building worker, vehicle, material equipment etc. may fall at a construction work shall be covered and/or guarded suitably by the contractor to prevent such falls.</p> |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>26 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | <br><b>नियमिती</b><br><b>NTPC</b> |
|------------|--|--|
| 44.07.00   | <p>Wherever the workers are exposed to the hazards of falling from height, the contractor shall provide full harness safety belts fitted with fall arresting systems to all the employees working at higher elevations and life line of 8 mm diameter wire rope with turn buckles for anchoring the safety belts while working or moving at higher elevations. Safety nets shall also be provided for saving them from fall from heights and such equipment should be in accordance with BIS standards.</p> <p>Wherever there is a possibility of falling of any material, equipment or construction workers while working at heights, a suitable and adequate safety net should be provided. The safety net should be in accordance with BIS Standards.</p> <p>The contractor shall provide standard prefabricated ladders on the columns where the workers are required to use them as an access for higher elevations till permanent staircase is provided. The workers shall be provided with safety belts fitted with suitable fall arresting system (Fall arrestors) for climbing/getting down through ladders to prevent fall from height.</p> <p><b>Handling of Hazardous Chemicals</b></p> <p>The Contractor will notify well in advance to the Engineer I/c of his intention to bring to the Site any container filled with liquid or gaseous fuel or explosive or petroleum substance or such chemicals which may involve hazards. NTPC shall have the right to prescribe the conditions, under which such container is to be stored, handled and used during the performance of the works and the Contract shall strictly adhere to and comply with such instructions. The Engineer I/c shall have the right at his sole discretion to inspect any such container or such construction plant / equipment for which material in the container is required to be used and if in his opinion, its use is not safe, he may forbid its use. No claim due to such prohibition shall be entertained by NTPC and NTPC shall not entertain any claim of the Contractor towards additional safety provisions / conditions to be provided for / constructed.</p> <p>Further, any such decision of the Engineer I/c shall not, in any way, absolve the Contractor of his responsibilities and in case, use of such a container or entry thereof into the Site area is forbidden by NTPC, the Contractor shall use alternative methods with the approval of the NTPC without any cost implication to the NTPC or extension of work schedule.</p> <p>Where it is necessary to provide and / or store petroleum products or petroleum mixtures and explosives, the Contractor shall be responsible for carrying-out such provision and / or storage in accordance with the rules and regulations laid down in Petroleum Act 1934, Explosives Act 1948, and Petroleum and Carbide of Calcium Manual published by the Chief Inspector of Explosives of India. All such storage shall have prior approval of the Engineer I/c. In case any approvals are necessary from the Chief Inspector (Explosives) or any statutory authorities, the Contractor shall be responsible for obtaining the same.</p> <p>The Contractor shall be fully responsible for the safe storage of his and his Sub-contractor's radio-active sources in accordance with BARC/DAE (Bhabha Atomic Research Centre/ Department of Atomic Energy, Govt. of India) Rules and other applicable provisions. All precautionary measures stipulated by BARC/DAE in</p> |  |

|   |  |   |                                |
|---|--|---|--------------------------------|
| <b>LOT-IB PROJECTS</b><br><b>FLUE GAS DESULPHURISATION (FGD)</b><br><b>SYSTEM PACKAGE</b> | <b>TECHNICAL SPECIFICATION</b><br><b>SECTION – VI, PART-D</b><br><b>BID DOC. NO. CS-0011-109(1B)-9</b> | <b>ERCTION CONDITIONS<br/>OF<br/>CONTRACT</b> | <b>PAGE</b><br><b>27 OF 53</b> |
|---|--|---|--------------------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|------------|--|------|
|            | <p>connection with use, the contractor would take storage and handling of such material.</p> <p>The contractor shall provide suitable personal protective equipments to the workers who are handling the hazardous and corrosive substances including alkalis and acids.</p> <p>As a precautionary measure the contractor should keep the bottles filled with distilled water in cupboard / Boxes near work place for emergency eye wash by worker exposed to such hazardous chemicals.</p>  |      |
| 44.08.00   | <p><b>Eye Protection</b></p> <p>The contractor shall provide suitable personal protective equipment to his workmen depending upon the nature of hazards and ensure their usage by the workers engaged in operations like welding, cutting, chipping, grinding or similar operations which may cause injuries to his eyes.</p>  |      |
| 44.09.00   | <p><b>Excavation</b></p> <p>The contractor shall take all necessary measures during excavation to prevent the hazards of falling or sliding material or article from any bank or side of such excavation which is more than one and a half meter above his footing by providing adequate piling, shoring, bracing etc. against such bank or sides.</p> <p>Adequate and suitable warning signs shall be put up at conspicuous places at the excavation work to prevent any persons or vehicles falling into the excavation trench. No worker should be allowed to work where he may be stuck or endangered by excavation machinery or collapse of excavations or trenches.</p>  |      |
| 44.10.00   | <p><b>Electrical Hazards</b></p> <p>The contractor should ensure that all electrical installations at the construction work comply with the requirements of latest electricity acts / rules.</p> <p>The contractor shall take all adequate measures to prevent any worker from coming into physical contact with any electrical equipment or apparatus, machines or live electrical circuits which may cause electrical hazards during the construction work. The contractor shall provide the sufficient ELCBs / RCCBs for all the portable equipments, electrical switchboards, distribution panels etc. to prevent electrical shocks.</p> <p>The contractor should ensure use of single / double insulated hand tools or low voltage i.e., 110 volts hand tools.</p> <p>The contractor should also ensure that all temporary electrical installations at the construction works are provided with earth leakage circuit breakers.</p> |      |
| 44.11.00   | <p><b>Vehicular Traffic</b></p> <p>The contractor should employ vehicle drivers who hold a valid driving license under the Motor Vehicles Act, 1988.</p>   |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>28 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
| 44.12.00   | <p><b>Lifting Appliances, Tools &amp; Tackles, Lifting Gear And Pressure Plant &amp; Equipment etc.</b></p> <p>The contractor shall ensure all the lifting appliances, tools &amp; tackles including cranes etc., lifting gear including fixed or movable and any plant or gear, hoists, Pressure Plant and equipment etc. are in good condition and shall be examined by competent person and only certified shall be used at sites. Periodical Examination and the tests for all lifting / hoisting equipment &amp; tackles shall be carried out. A register of such examinations and tests shall be properly maintained by the Contractor and will be promptly produced as and when desired by the Engineer I/c or by the person authorized by him.</p>  |                  |
| 44.13.00   | <p><b>Excessive Noise, Vibration</b></p> <p>The contractor shall take adequate measures to protect the workers against the harmful effect of excessive noise or vibration. The noise should not exceed the limits prescribed under the concerned rules, Noise Pollution (Regulation and Control) Rules, 2000.</p>   |                  |
| 44.14.00   | <p><b>Electrical Installations</b></p>  |                  |
| 44.14.01   | <p>The Contractor shall not interfere or disturb electric fuses, wiring and other electrical equipment belonging to the Employer or other contractors under any circumstances, whatsoever, unless expressly permitted in writing by the Engineer I/c to handle such fuses, wiring or electrical equipment.</p> <p>Before the Contractor connects any electrical appliances to any plug or socket belonging to the other contractor or the NTPC, he shall</p> <ul style="list-style-type: none"> <li>i) Satisfy the Engineer I/C that the appliance is in good working condition;</li> <li>ii) Inform the Engineer I/C of the maximum current rating, voltage and phases of the appliances;</li> <li>iii) Obtain permission of the Engineer I/C detailing the sockets to which the appliances may be connected.</li> </ul> <p>The Engineer I/C will not grant permission to connect until he is satisfied that:</p> <p>The appliance is in good condition and is fitted with suitable plug; having earth connection with the body.</p> <p>Wherever armored / metallic sheathed multi core cable is used, the same armored / sheathed should be connected to earth.</p> <ul style="list-style-type: none"> <li>iv) No repair work shall be carried out on any live equipment. The Engineer I/c must declare the equipment safe and a permit to work shall be issued by the NTPC / contractor as the case may be to carry out any repair / maintenance work. While working on electric lines / equipments whether live or dead, suitable type and sufficient quantity of tools will have to be provided by the contractor to electricians / workmen / Officers.</li> </ul> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>29 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|------------|--|------|
|            | <p>v) The contractor shall employ necessary number of qualified, full time Electricians / Electrical Supervisors to maintain his temporary electrical installation.</p> <p>The installations are provided with suitable ELCBs and RCCBs wherever required.</p>   |      |
| 44.15.00   | <b>Safety Organisation</b>   |      |
| 44.15.01   | <p>The contractor employing more than 250 workmen whether temporary, casual, probationary, regular or permanent shall employ at least one full time safety officer exclusively to supervise safety aspects of the equipments and workmen, who will coordinate with the NTPC Safety Officer. Further requirement of safety officers, if any, shall be guided by Rule 209 of The Building and Other Construction Worker (Regulation of Employment and Conditions of Service) Central Rule 1998. In case the work is being carried out through subcontractor, the employees / workmen of the sub contractor shall also be considered as the contractor's employees/workmen for the above purpose.</p> <p>In case of contractor deploying less than 250 workmen he should designate one of his Engr / supervisor or the contractor himself (if he is directly supervising the work) as safety officer in addition to his existing responsibilities. The Engr./ supervisor should get atleast 2days safety training from any reputed organization or from NTPC before resuming the work. If already trained in past the declaration along with trg. certificate to be furnished to NTPC safety officer.</p> |      |
| 44.15.02   | <p>The name and address of such Safety Officer of the Contractor will be promptly informed in writing to the EIC with a copy to the Project Safety Officer before he starts work or immediately after any change of the incumbent is made during currency of the Contract.</p>   |      |
| 44.16.00   | <b>Reporting of Accident and Investigation</b>   |      |
|            | <p>In case any accident occurs during the construction / erection or other associated activities undertaken by the Contractor thereby causing any near miss, minor or major or fatal injury to his employees due to any reason, whatsoever, it shall be the responsibility of the Contractor to promptly inform the same to the Engineer I/C, NTPC Safety Officer with a copy to NTPC Head of Project in the prescribed form and also to all the authorities envisaged under the applicable laws.</p>  |      |
| 44.17.00   | <b>Right to stop Work</b>  |      |
| 44.17.01   | <p>The Engineer I/C shall have the right at his sole discretion to stop the work, if in his opinion the work is being carried out in such a way that it may cause accidents and endanger the safety of the persons and / or property, and / or equipments. In such cases, the contractor shall be informed in writing about the nature of hazards and possible injury / accident and he shall comply to remove shortcomings promptly. The Contractor after stopping the specific work can, if felt necessary appeal against the order of stoppage of work to the Project Manager within 3 days of such stoppage</p>  |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>30 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
| 44.17.02   | of work and decision of the Project Manager in this respect shall be conclusive and binding on the Contractor.<br><br>The Contractor shall not be entitled for any damages / compensation for stoppage of work, {Sub-Clause XVIII (I)} due to safety reasons and the period of such stoppage of work shall not be taken as an extension of time for Completion of the Facilities and will not be the ground for waiver of levy of liquidated damages.   |                  |
| 44.18.00   | <b>Fire Protection</b><br><br>The contractor shall provide sufficient fire extinguishers at place /s of work. The fire extinguishers shall be properly maintained as per relevant BIS Standards. The employees shall be trained to operate the fire extinguishers / equipment.  |                  |
| 44.19.00   | <b>Penalties</b> <ul style="list-style-type: none"> <li>I If the Contractor fails in providing safe working environment as per the Safety Rules of NTPC or continues the work even after being instructed to stop the work by the Engineer I/C as provided in Clause XVIII (1) above, the Contractor shall be penalized at the rate of Rs. 25,000/- per day or part thereof till the instructions are complied with and so certified by the Engineer I/C. However, in case of accident, the provisions contained in Sub-Clause XX (II) below shall also apply in addition to the penalties mentioned in this sub-clause.</li> <li>II If the Contractor does not take all safety precautions and / or fails to comply with the Safety Rules as prescribed by the Employer or under the applicable law for the safety of the plant and equipment and for the safety of personnel and the contractor does not prevent hazardous conditions which cause injury to this own employees or employees of other contractors, or NTPC's employees or any other person who are at the Site or adjacent thereto, the Contractor shall be responsible for payment of penalty to NTPC as per the following schedule:- <ul style="list-style-type: none"> <li>a) Fatal injury or accident causing death:<br/>Penalty @10% of contract value or Rs. 5,00,000/- per person, which ever is less.</li> <li>b) Major injuries or accident causing 25% or more permanent disablement to workmen or employees:<br/>Penalty @2.5% of contract value or Rs. 1,00,000/- per person which ever is less</li> </ul> </li> </ul> <p>Permanent disablement shall have the same meaning as indicated in The Workmen's Compensation Act' 1923. The penalty mentioned above shall be in addition to the compensation payable to the workmen / employees under the relevant provisions of the Workmen's Compensation Act' 1923 and rules framed there under or any other applicable laws as applicable from time to time.</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>31 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC  |
|--|--|---|
|  | <p>III If any contractor worker found working without using the safety equipment like safety helmet, safety shoes, safety belts, etc. or without anchoring the safety belts while working at height the Engineer I/c / Safety Officer of NTPC shall have the right to penalize the contractor for Rs. 200/- per person per day and such worker shall be sent out of the workplace immediately and shall not be allowed to work on that day. Engineer I/c / Safety Officer of NTPC will also issue a notice in this regard to the contractor.</p> <p>IV If two or more fatal accidents occur at same NTPC site under the control of contractor during the period of contract and he has</p> <ul style="list-style-type: none"> <li>(1) not complied with keeping adequate PPEs in stock or</li> <li>(2) defaulted in providing PPEs to his workmen</li> <li>(3) not followed statutory requirements / NTPC safety rules</li> <li>(4) been issued warning notice/s by NTPC head of the project on non observance of safety norms</li> <li>(5) not provided safety training to all his workmen, the contractor can be debarred from getting tender documents in NTPC for two years from the date of last accident.</li> </ul> <p>The safety performance will also be one of the overriding criteria for evaluation of overall performance of the contractors by NTPC. The contractor shall submit the accident data including fatal / non-fatal accidents for the last 3 years where he has undertaken the construction activities Projects-wise along with the tender documents. This will also be considered for evolution of tender documents. If the information given by the contractor found incorrect, his contract will be liable to be terminated.</p> |   |
| 44.20.00   | The Contractor will make available minimum quantity of all safety equipments and safety personal protection equipments (PPEs) of required specifications as per suggestive list included bidding documents as a part of "List of minimum T & P". Further Contractor will ensure availability of additional requirement for individual worker and safety equipment as per site requirement during execution of the contract till its completion.  |   |
| 44.21.00   | <p><b>Award</b></p> <p>If the Contractor's performance on safety front is found satisfactory i.e. without any fatal/reportable accident in the year of consideration; he may be considered for suitable award "ACCIDENT FREE SAFETY MERITORIOUS AWARD" as per scheme of the employer.</p>  |   |
| 44.22.00   | <p><b>The Contractor shall abide by the following during Construction and Erection activities:</b></p> <p>I. Chain pulley block shall not be used for loads more than 2 (Two) tonne.</p>   |   |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE |  | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 |
| ERCTION CONDITIONS<br>OF<br>CONTRACT                                 |  | PAGE<br>32 OF 53  |

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT |  |
|------------|--------------------------------|---|
|------------|--------------------------------|---|

|                 |  |  |
|-----------------|--|--|
|                 | <p>II. Hydra shall not be used for material transport.</p> <p>III. Cage shall necessarily be provided to Monkey ladders of height more than 4 m.</p> <p>IV. Fencing shall be provided to all Electrical Distribution boards and transformers etc.</p>  |  |
| <b>45.00.00</b> | <b>FOREIGN PERSONNEL</b>   |  |
| 45.01.00        | The Contractor shall submit to the Employer data on all personnel he proposes to bring into India from abroad for the performance of the Works under the Contract, at least sixty (60) days prior to their departure to India. Such data will include for each person the name, his present address, his assignment and responsibility in connection with the works, and a short resume of his qualification, experience etc. in relation to the work to be performed by him.  |  |
| 45.02.00        | Any person unsuitable and unacceptable to the Employer shall not be brought to India. Any person brought to India, if found unsuitable or unacceptable by the Employer, the Contractor shall within a reasonable time make alternate arrangements for providing a suitable replacement and repatriation of such unsuitable personnel.  |  |
| 45.03.00        | No person brought to India for the purposes of the works shall be repatriated without the consent of the Employer in writing, based on a written request from the Contractor for such repatriation giving reasons for such an action to the Employer. The Employer may give permission for such repatriation provided he is satisfied that the progress of work will not suffer due to such repatriation.  |  |
| 45.04.00        | The cost of passports, visas and all other travel expenses to and from India, incurred by the Contractor shall be to his account. The Employer will not provide any residential accommodation and/or furniture for any of the Contractor's personnel including foreign personnel and Contractor shall make his own arrangements for such facilities in the area allotted at Site, to him by the Employer for that purpose.   |  |
| 45.05.00        | The Contractor and his expatriate personnel shall respect all Indian Acts, Laws, rules and regulations and shall not in any way interfere with Indian political and religious affairs and shall conform to any other rules and regulations which the Government of India and the Employer may establish from time to time, on them. The Contractor's expatriate personnel shall work and live in close co-operation and coordination with their co-workers and the community and shall not engage themselves in any other employment neither part-time nor full-time nor shall they take part in any local politics. |  |
| 45.06.00        | The Employer shall assist the Contractor, to the extent possible, in obtaining necessary permits to travel to India and back, by issue of necessary certificates and other information needed by the Government agencies.  |  |
| <b>46.00.00</b> | <b>FOUNDATION DRESSING &amp; GROUTING FOR EQUIPMENT/ EQUIPMENT BASES</b>   |  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>33 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC                     |
|--|---|--------------------------------------|
| 46.01.00   | The surfaces of foundations shall be dressed to bring the top surface of the foundations to the required level, prior to placement of equipment/equipment bases on the foundations.   |                                      |
| 46.02.00   | All the equipment/ equipment bases, shall be grouted and finished by bidder as per these specifications unless otherwise recommended by the equipment manufacturer.   |                                      |
| 46.03.00   | The concrete foundation surfaces shall be properly prepared by bidder by chipping, grinding as required to bring the top of such foundation to the required level, to provide the necessary roughness for bondage and to assure enough bearing strength.  |                                      |
| 46.04.00   | <p><b>Grout</b></p> <p>The grout for equipment foundation shall be high strength grout having a minimum characteristic compressive strength of 60 N/mm<sup>2</sup> at 28 days. The grout shall be ready mix non-shrink, chloride - free, cement based, free flowing, non-metallic grout as recommended by equipment manufacturer. The ready mix grout shall be of reputed make as approved by the Employer.</p> <p>The Grout shall have good flowability even at very low water/ grout powder ratio.</p> <p>The Grout shall have characteristics of controlled expansion to be able to occupy its original volume to fill the voids and to compensate for shrinkage. Grout shall be of pre-mix variety so that only water needs to be added before use.</p> <p>The mixing of the Grout shall conform to the recommendations of the manufacturer of the Grout.</p> |                                      |
| 46.05.00   | <b>Placing of Grout</b>   |                                      |
| 46.05.01   | After the base has been prepared, its alignment and level has been checked and approved and before actually placing the grout, a low dam shall be set around the base at a distance that will permit pouring and manipulation of the grout. The height of such dam shall be at least 25mm above the bottom of the base. Suitable size and number of chains shall be introduced under the base before placing the grout, so that such chains can be moved back & forth to push the grout into every part of the space under the base.  |                                      |
| 46.05.02   | The grout shall be poured either through grout holes if provided or shall be poured at one side or at two adjacent sides to make the grout move in a solid mass under the base and out in the opposite side. Pouring shall be continued until the entire space below the base is thoroughly filled and the grout stands at least 25 mm higher all around than the bottom of the base. Enough care should be taken to avoid any air or water pockets beneath the bases.  |                                      |
| 46.05.03   | In addition to the above, recommendations of Grout manufacturer shall also be followed.   |                                      |
| 46.06.00   | <b>Finishing of the Edges of the Grout</b>  |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9   | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |   | PAGE<br>34 OF 53                     |

| CLAUSE NO.   | ERCTION CONDITIONS OF CONTRACT   | NTPC                                 |
|--|--|--------------------------------------|
|  | <p>The poured grout should be allowed to stand undisturbed until it is well set. Immediately thereafter, the dam shall be removed and grout which extends beyond the edges of the structural or equipment base plates shall be cut off, flushed and removed. The edges of the grout shall then be pointed and finished with 1:2 cement mortar pressed firmly to bond with the body of the grout and smoothed with a tool to present a smooth vertical surface. The work shall be done in a clean and scientific manner and the adjacent floor spaces, exposed edges of the foundations, and structural steel and equipment base plates shall be thoroughly cleaned of any spillage of the grout.</p> |                                      |
| 46.07.00   | <p><b>Checking of Equipment After Grouting</b></p> <p>After the grout is set and cured, the Contractor shall check and verify the alignment of equipments, alignment of shafts of rotating machinery, the slopes of all bearing pedestals, centering of rotors with respect to their sealing bores, couplings, etc. as applicable and the like items to ensure that no displacement had taken place during grouting. The values recorded prior to grouting shall be used during such post grouting check- up and verifications. Such pre and post grout records of alignment details shall be maintained by the Contractor in a manner acceptable to the Employer.</p>                               |                                      |
| 47.00.00   | <p><b>SHAFT ALIGNMENTS</b></p> <p>All the shafts of rotating equipment shall be properly aligned to those of the matching equipments to as perfect an accuracy as practicable. The equipment shall be free from excessive vibration so as to avoid overheating of bearings or other conditions which may tend to shorten the life of the equipment. The vibration level of rotating equipments measured at bearing housing shall conform to Zone A of ISO 10816. All bearings, shafts and other rotating parts shall be thoroughly cleaned and suitably lubricated before starting.</p>  |                                      |
| 48.00.00   | <p><b>DOWELLING</b></p> <p>All the motors and other equipment shall be suitably doweled after alignment of shafts with tapered machined dowels as per the direction of the Employer.</p>   |                                      |
| 49.00.00   | <p><b>CHECK OUT OF CONTROL SYSTEMS</b></p> <p>After completion of wiring, cabling furnished under separate specification and laid and terminated by the Employer, the Contractor shall check out the operation of all control systems for the equipment furnished and installed under these specifications and documents.</p>  |                                      |
| 50.00.00   | <p><b>COMMISSIONING SPARES</b></p>   |                                      |
| 50.01.00   | <p>It will be the responsibility of the Contractor to provide all commissioning spares including consumable spares required for initial operation till the Completion of Facilities. The Contractor shall furnish a list of all commissioning spares within 60 days from the date of Notification of Award and such list shall be reviewed by the Employer and mutually agreed to. However, such review and agreement will not</p>   |                                      |
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9  | ERCTION CONDITIONS<br>OF<br>CONTRACT |
|  |  | PAGE<br>35 OF 53                     |

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT   | नियमितीया<br>NTPC |
|-----------------|--|-------------------|
|                 | absolve the Contractor of his responsibilities to supply all commissioning spares so that initial operation do not suffer for want of commissioning spares. All commissioning spares shall be deemed to be included in the scope of the Contract at no extra cost to the Employer.   |                   |
| 50.02.00        | These spare will be received and stored by the Contractor atleast 3 months prior to the schedule date of commencement of initial operation of the respective equipment and utilised as and when required. The unutilised spares and replaced parts, if any, at the end of successful completion of guarantee tests shall be the property of the Contractor and he will be allowed to take these parts back at his own cost with the permission of Employer.  |                   |
| <b>51.00.00</b> | <b>CABLING</b>   |                   |
| 51.01.00        | All cables shall be supported by conduits or cable tray run in air or in cable channels. These shall be installed in exposed runs parallel or perpendicular to dominant surfaces with right angle turn made of symmetrical bends or fittings. When cables are run on cable trays, they shall be clamped at a minimum intervals of 2000mm or otherwise as directed by the Employer.   |                   |
| 51.02.00        | Each cable, whether power or control, shall be provided with a metallic or plastic tag of an approved type, bearing a cable reference number indicated in the cable and conduit list (prepared by the Contractor), at every 5 meter run or part thereof and at both ends of the cable adjacent to the terminations. Cable routing is to be done in such a way that cables are accessible for any maintenance and for easy identification.  |                   |
| 51.03.00        | Sharp bending and kinking of cables shall be avoided. The minimum radii for PVC insulted cables 1100 V grade shall be 15 D where D is the overall diameter of the cable. Installation of other cables like high voltage, coaxial, screened, compensating, mineral insulated shall be in accordance with the cable manufacturer's recommendations. Wherever cables cross roads and water, oil, sewage or gaslines, special care should be taken for the protection of the cables in designing the cable channels.   |                   |
| 51.04.00        | In each cable run some extra length shall be kept at a suitable point to enable one or two straight through joints to be made, should the cable develop fault at a later date.   |                   |
| 51.05.00        | Control cable terminations shall be made in accordance with wiring diagrams, using identifying codes subject to the Employer's approval. Multicore control cable jackets shall be removed as required to train and terminate the conductors. The cable jacket shall be left on the cable, as far as possible, to the point of the first conductor branch. The insulated conductors from which the jacket is removed shall be neatly twined in bundles and terminated. The bundles shall be firmly but not tightly tied utilising plastic or nylon ties or specifically treated fungus protected cord made for this purpose. Control cable conductor insulation shall be securely and evenly cut. |                   |
| 51.06.00        | The connectors for control cables shall be covered with a transparent insulating sleeve so as to prevent accidental contact with ground or adjacent terminals and shall preferably terminate in Elmex terminals and washers. The insulating sleeve shall be fire resistant and shall be long enough to over pass the conductor insulation.   |                   |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>36 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
|            | All control cables shall be fanned out and connection made to terminal blocks and test equipment for proper operation before cables are corded together.  |                  |
| 52.00.00   | <b>EQUIPMENT DELIVERY AND ERECTION</b>  |                  |
| 52.01.00   | <b>General Requirements</b> <p>(a.) This part covers Contractor's responsibilities for packing, shipping, warehousing and the installation of all equipment and materials furnished and installed under this specification.</p> <p>(b.) The Contractor shall submit for Employer's approval draft manual for Equipment Delivery and Erection (EDE Manual) covering detailed instructions, write up, technical data, drawings, check-lists, documentation formats for all activities after equipment manufacture upto installation of equipment. This manual shall cover general instructions for all equipment and specific instructions for individual equipment wherever required and shall include at least the following :</p> <p>(1.) Instructions for packing, shipping, receiving handling, warehousing and storage.</p> <p>(2.) Instructions for location and installation of equipment furnished by this specification.</p> <p>(3.) Installation drawings for field mounted equipment, panels, cubicles and other equipment covered under this specification.</p> <p>(4.) Instruction relating installation of piping/ tubing, support and routing drawings of impulse pipes/signal tubes and tube/cable trays.</p> <p>(5.) Check lists and quality assurance hold points.</p> <p>(6.) Format for all related documentation.</p> |                  |
| 52.02.00   | <p>(c.) The EDE Manual shall conform to the requirements of this specification, all applicable codes and standards, recommendations of equipment manufacturers and accepted good engineering practices and shall be subject to Employer approval during detailed engineering.</p> <p>(d.) The Contractor shall ensure that all work under this part shall be performed as per the requirements of this specification, Employer approved EDE Manual and drawing/documents approved by the Employer during detailed engg.</p> <p><b>Crating</b></p> <p>(a.) All equipment and materials shall be suitably coated, wrapped, or covered and boxed or crated for moist humid tropical shipment and to prevent damage or deterioration during handling and storage at the site.</p>   |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>37 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | NTPC |
|------------|---|------|
|            | <p>(b.) Equipment shall be packed with suitable desiccants, sealed in water proof vapour-proof wrapping and packed in lumber of plywood enclosures, suitably braced, tied and skidded. Lumber enclosures shall be solid, not slatted.</p> <p>(c.) Desiccants shall be either silica gel or calcium sulphate, sufficiently ground to provide the required surface area and activated prior to placing in the packaging. Calcium sulphate desiccants shall be of a chemical nature to absorb moisture. In any case, the desiccant shall not be of a type that will absorb enough moisture to go into solution. Desiccants shall be packed in porous containers, strong enough to withstand handling encountered during normal shipment. Enough desiccant shall be used for the volumes enclosed in wrapping.</p> <p>(d.) Review by the Employer of the Contractor's proposed packaging methods shall not relieve the Contractor of responsibility for damage or deterioration to the equipment and materials specified.</p> <p>(e.) All accessory items shall be shipped with the equipment. ; Boxes and crates containing accessory items shall be marked so that they are identified with the main equipment. The contents of each box and crates shall be indicated by markings on the exterior.</p> <p>(f.) All boxes, crates, cases bundles, loose pieces, etc. shall be marked consecutively from No.1 upward throughout all shipments from a given port to completion of the order without repeating the same number.</p> <p>(g.) An itemized list of contents shall be enclosed inside each case and one other copy securely fastened to the outside of the case in a tin or light weight sheet metal envelope or pocket. The lists shall be plainly marked and placed in accessible locations to facilitate receipt and inspection. The packing list shall indicate whether shipment is partial or complete and shall incorporate the following information on each container, etc., according to its individual shipping number:</p> <ul style="list-style-type: none"> <li>a) Export case markings</li> <li>b) Case number</li> <li>c) Gross weight and net weight in Kilograms</li> <li>d) Dimensions in centimeters</li> <li>e) Complete description of material</li> </ul> <p>(h.) Packaging or shipping units shall be designed within the limitations of unloading facilities and the equipment which will be used for transport. Complications involved with ocean shipment and the limitations of ports, railways and roads shall be considered. It shall be the Contractor's responsibility to investigate these limitations and to provide suitable packaging to permit safe handling during transit and at the job site.</p> |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>38 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | नियमितीया<br>NTPC |
|------------|---|-------------------|
|            | <p>(i.) Electrical equipment, control and instrumentation shall be protected against moisture and water damage. All external gasket surfaces and flange faces, couplings, motor pump shafts, bearing and like items shall be thoroughly cleaned and coated with rust preventive compound as specified above and protected with suitable wood, metal or other substantial type covering to ensure their full protection.</p> <p>(j.) Equipment having antifriction or sleeve bearings shall be protected by weather tight enclosures.</p> <p>(k.) Coated surfaces shall be protected against impact, abrasion, discolouration and other damage. Surfaces which are damaged shall be repaired.</p> <p>(l.) All exposed threaded parts shall be greased and protected with metallic or other substantial type protectors. All female threaded openings shall be closed with forged steel plugs. All pipings, tubing, and conduit equipment and other equipment openings shall be sealed with metallic or other rough usage covers and tapped to seal the interior of the equipment piping, tubing, or conduit.</p> <p>(m.) Provisions shall be made to ensure that water does not enter any equipment during shipment or in storage at the plant site.</p> <p>(n.) Returnable containers and special shipping devices shall be returned by the manufacturer's field representative at the Contractor's expense.</p> <p>(o.) While packaging the material, care shall be taken for the limitation from the point of view of availability of railway wagon sizes in India.</p> |                   |
| 52.03.00   | <p><b>Factory Assembly</b></p> <p>(a.) Instrument enclosures shall be supplied and erected completely in the factory with instrument, air supply and blow down piping with necessary valves, fittings, etc. and also all electrical wiring between the instruments and the enclosure terminal blocks. Control panel and cubicles shall also be fully wired in the factory. Control panel mounted equipments are to be dismounted from the panels before shipment and individually packed for shipment. Electronic control modules of the plug-in type are to be removed from equipment racks after factory checkout are individually packed for shipment. Other equipment shall be fully assembled at the factory, except for necessary shipping splits in panels.</p> <p>(b.) All separately packaged accessories items and parts shall be shipped with the equipment. Containers for separately packaged items shall be marked so that they are identified with the main equipment. An itemized packing slip, indicating what is in that carton only, shall be attached to the outside and inside of each container used for packing.</p> <p>A master packing slip covering all accessories items for a given piece of equipment which are shipped in separate containers, shall be attached to one container.</p>  |                   |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>39 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | નાનીયિકી<br>NTPC |
|------------|--|------------------|
| 52.04.00   | <p><b>Equipment Installation</b></p> <p>(a.) <b>General Requirements</b></p> <p>(1.) The Contractor shall furnish all construction materials, tools and equipment and shall perform all work required for complete installation of all control and instrument equipment furnished under this specification.</p> <p>(2.) Contractor shall prepare detailed installation drawings for each equipment furnished under this specification for Employer's approval. Installation of all equipment/systems furnished by this specification shall be as per Employer's approval.</p> <p>(3.) Erection procedures not specified herein shall be in accordance with the recommendations of the equipment manufacturers. The procedures shall be acceptable to the Employer.</p> <p>(4.) The Contractor shall coordinate his work with other suppliers where their instruments and devices are to be installed under specifications.</p> <p>(b.) <b>Installation Materials</b></p> <p>All materials required for installation, testing and commissioning of the equipment shall be furnished by the Contractor.</p> <p>(c.) <b>Regulatory Requirements</b></p> <p>All installation procedures shall confirm with the accepted good engineering practice and with all applicable governmental laws, regulations and codes.</p> <p>(d.) <b>Cleaning</b></p> <p>All equipment shall be cleaned of all sand, dirt and other foreign materials immediately after removal from storage and before the equipment is brought inside the power plant building or to other installation sites. All piping and tubes shall be air blown.</p> <p>(e.) <b>Equipment Assembly</b></p> <p>Equipment installed under these specifications shall be assembled if shipped unassembled. The equipment shall be dismantled and reassembled as required to perform the installation and commissioning work described in these specifications.</p> <p>(f.) <b>Equipment Setting</b></p> <p>Field mounted instruments and accessories shall be bracket or sub panel mounted on the nearest suitable firm steel work or masonry. The brackets,</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>40 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  |  |
|------------|---|--|
|            | <p>stands, supports and other miscellaneous hardware required for mounting instruments and accessories such as receiver gauge, air set, valve manifold, purge-meter etc. shall be furnished and installed. No field mounted instruments shall be installed such that it depends for support or rigidity on the impulse piping or on electrical connection to it.</p> <p>Indicating type field mounted instruments shall be installed in such a way that centre of indicating dial shall be about 1600-1800mm from operating floor level. Non-indicating type field instruments shall be installed such that operating handle of manifold block / isolating cock comes within 1600 mm from operating floor level.</p> <p>(g.) <b>Free-Standing Equipment</b></p> <p>Free-standing Cabinets shall be attached to the floor, concrete equipment bases or supporting steel as indicated on the manufacturer's drawings and the Employer's Plant Arrangement Drawings. The cabinets shall be shimmed for proper alignment before bolting them to the floor. Adjacent enclosures shall be shimmed to maintain mutually level appearance before they are attached to floor. Vibration dampening mounts shall be installed between supporting structures and panels when specified.</p> <p>(h.) <b>Non-free Standing Equipment</b></p> <p>(1.) Non-free standing local enclosures and cabinets shall be mounted in accessible locations on columns, walls, or stands in locations as indicated on the Employer's Plant Arrangement Drawings. Bracket and stands shall be fabricated as required to install the local enclosures and cabinets in a workman like manner.</p> <p>(2.) Rough edges and welds on all fabricated supports shall be ground smooth. The supports shall be finished with two coats of primer and two coats of paint as specified in this part.</p> <p>(i.) <b>Equipment Location</b></p> <p>(1.) All individual items of equipment not located in cabinets or on panels and racks are located approximately according to the floor elevation and the nearest building column designated by the Employer.</p> <p>(2.) Solenoid valves not located in enclosures or mounted on valves shall be mounted in easily accessible protected locations near the components with which they are associated.</p> <p>(3.) All brackets, stands, supports and other miscellaneous hardware required for mounting devices shall be furnished and installed.</p> <p>(4.) Thermometers shall be installed in the process lines and ducts as required and adjusted for ease in reading.</p> |  |

|   |  |   |                                |
|---|--|---|--------------------------------|
| <b>LOT-IB PROJECTS</b><br><b>FLUE GAS DESULPHURISATION (FGD)</b><br><b>SYSTEM PACKAGE</b> | <b>TECHNICAL SPECIFICATION</b><br><b>SECTION – VI, PART-D</b><br><b>BID DOC. NO. CS-0011-109(1B)-9</b> | <b>ERCTION CONDITIONS</b><br><b>OF</b><br><b>CONTRACT</b> | <b>PAGE</b><br><b>41 OF 53</b> |
|---|--|---|--------------------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
|            | <p>(5.) Permanent temperature wells on the main steam, hot reheat and cold reheat piping shall not be installed until steam blowing has been completed. Temporary temperature wells shall be installed in the main and reheat steam piping during steam blow and discarded after completion.</p> <p>(6.) Any required adapting hardware such as pipe bushings, nipples, drilled caps and the like shall be provided for complete installation of control devices into process connections.</p> <p>For location of C&amp;I related equipment/devices, the requirement specified elsewhere in the technical specification may be referred.</p> <p>(j.) <b>Installation of Field Mounted Instruments and Devices</b></p> <p>The Contractor shall submit installation drawings for all field mounted equipment furnished under this specification for Employer's approval. These drawings shall meet the requirements of this specification, installation drawings, applicable codes and standards and recommendations of manufacturers of instruments/devices. All installation work under this specification shall be strictly as per installation drawings approved by the Employer during detailed engineering stage.</p> <p>In addition to above relevant Portion as specified elsewhere in technical specification may be referred.</p> <p>(k.) <b>Piping Connections</b></p> <p>(1.) All equipment having piping connections shall be levelled, aligned and wedged in place but shall not be grouted or bolted prior to the initial fitting and alignment of connecting piping. All equipment shall, however, be grouted or bolted to its foundation prior to final bolting or welding of the connection piping.</p> <p>(2.) All flanged joints shall be checked and retightened after approximately 10 days of operation at normal operating temperature.</p> <p>(l.) <b>Equipment Checkout</b></p> <p>(1.) All equipment shall be cleaned after installation. Equipment subject to pressure differentials shall be checked for leakage.</p> <p>(2.) After erection, all equipment having moving parts, having electrical apparatus, or subject to pressure differentials shall be trial-operated.</p> <p>(m.) <b>Defects</b></p> <p>(1.) All defects in erection shall be corrected to the satisfaction of the Employer and the Project Manager. The dismantling and reassembly of Contractor furnished equipment to remove defective parts, replace</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>42 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO.      | ERCTION CONDITIONS OF CONTRACT   | NTPC |
|-----------------|--|------|
|                 | <p>parts, or make adjustments shall be included as a part of the work under these specifications.</p> <p>(2.) The removal of control and instrument equipment in order to allow bench calibration, if required, and the re-installation of the said equipment after calibration shall also be included as a part of the work under these specifications.</p> <p>(n.) <b>Equipment Protection</b></p> <p>(1.) All equipment to be erected under these specifications shall be protected from damage of any kind from the time of contract award until commissioning of each unit.</p> <p>(2.) The equipment shall be protected during storage as described herein.</p> <p>(3.) Equipment shall be protected from weld spatter during construction.</p> <p>(4.) Suitable guards shall be provided for protection of personnel on all exposed rotating or moving machine parts. All such guards with necessary spares and accessories shall be designed for easy removal and maintenance.</p> <p>(5.) Equipment having glass components such as gauges, or equipment having other easily breakable components, shall be protected during the construction period with plywood enclosures or other suitable means. Broken, stolen, or lost components shall be replaced by the Contractor.</p> <p>(6.) Machine finished surfaces, polished surfaces, or other bare metal surfaces which are not to be painted, such as machinery shafts and couplings shall be provided temporary protection during storage and constructional periods by a coating of a suitable non-drying, oily type, rust preventive compound.</p> |      |
| <b>53.00.00</b> | <b>WELDING - SPECIAL REQUIREMENTS</b>  |      |
|                 | If the manufacturer has special requirements relating to the welding procedures for welds at the terminals of the equipments to be performed under separate specifications, the requirements shall be submitted to the Project Manager in advance of commencement of erection work.  |      |
| <b>54.00.00</b> | <b>DEVIATIONS DISPOSITIONING:</b>  |      |
|                 | Any deviation to the contract and employer approved documents shall be properly recorded in the format prescribed by NTPC. All the deviations shall be brought to the knowledge of employer's representative for suitable dispositioning.  |      |
| <b>55.00.00</b> | <b>NON-DESTRUCTIVE TESTING (NDT):</b>  |      |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>43 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   |  |
|------------|--|---|
| 56.00.00   | <p>The contractor shall record results of NDTs carried out at site in the format acceptable to employer. All the radiographs &amp; its report duly signed &amp; correlated to the job shall be handed over to the employer. Sensitivity of all the test equipment shall be compatible to the job &amp; acceptance norms agreed.</p> <p><b>TESTING EQUIPMENT &amp; FACILITIES:</b></p> <p>Contractor shall provide the testing equipment and facilities necessary to carry out tests &amp; inspections.</p> |   |

| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>44 OF 53 |
|--|---|--------------------------------------|------------------|
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  |  |
|------------|---|---|
|            | <p style="text-align: right;"><b>ANNEXURE-I</b></p> <p style="text-align: center;"><b><u>STANDARD CHECKLIST</u></b></p> <p>This is an indicative list of items. The actual list shall depend on the Equipment / System being supplied by the contractor.</p> <p style="text-align: center;"><b><u>MECHANICAL</u></b></p> <p><b><u>VALVES</u></b></p> <ol style="list-style-type: none"> <li>1. Manually Operated Valve</li> <li>2. Electrically Operated Valve</li> <li>3. Pneumatically Actuated Valve</li> <li>4. Hydraulically Actuated Valve</li> <li>5. Safety Valve</li> <li>6. Electromatic Relief Valve</li> <li>7. Steam Trap</li> <li>8. Non Return Valve (including Hydraulic/ Pneumatic QCNRVS)</li> <li>9. Control Valve</li> <li>10. Relief Valve</li> <li>11. Differential Pressure Regulating Valve</li> <li>12. Pinch valve</li> </ol> <p><b><u>TANKS &amp; PRESSURE VESSELS</u></b></p> <ol style="list-style-type: none"> <li>1. Limestone silos</li> <li>2. Gypsum storage silos</li> <li>3. Limestone slurry tanks</li> <li>4. Filtrate tank</li> <li>5. Waste water tank</li> </ol> |   |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>45 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | एनटीपीसी<br>NTPC |
|------------|--|------------------|
|            | <ol style="list-style-type: none"> <li>6. Secondary hydrocyclone feed tank</li> <li>7. Lime dosing tank</li> <li>8. Process water tank</li> <li>9. Absorber</li> <li>10. Auxiliary absorbent tank</li> <li>11. Mill circuit tank</li> <li>12. Any other tank not covered above</li> <li>13. Vacuum tanks</li> <li>14. Air Receiver(if any)</li> </ol> <p><b><u>PUMPS</u></b></p> <ol style="list-style-type: none"> <li>1. Slurry recirculation pumps</li> <li>2. Gypsum bleed pumps</li> <li>3. Limestone slurry pumps</li> <li>4. Process water pumps</li> <li>5. All other slurry pumps</li> <li>6. Vacuum pumps</li> <li>7. Sump pumps</li> </ol> <p><b><u>PIPE WORK SYSTEM</u></b></p> <ol style="list-style-type: none"> <li>1. Steam services</li> <li>2. Water services</li> <li>3. Slurry services</li> <li>4. Air services</li> <li>5. Constant load support</li> <li>6. Spring supports</li> <li>7. Hangers and other Supports</li> </ol> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>46 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT |  |
|------------|--------------------------------|---|
|------------|--------------------------------|---|

|  |  |  |
|--|--|--|
|  | <p><b><u>STRAINER AND FILTER</u></b></p> <ol style="list-style-type: none"> <li>1. Strainer / Filter Basket Type</li> <li>2. Strainer Rotary (Low Pressure)</li> <li>3. Filter &amp; Strainers Centrifugal Separators</li> <li>4. Filter &amp; Strainer Y-Type</li> <li>5. Filter &amp; Strainer (Plate Type)</li> <li>6. Purifier</li> <li>7. Filter – Compressed Air Line</li> </ol> <p><b><u>FANS &amp; COMPRESSORS</u></b></p> <ol style="list-style-type: none"> <li>1. Booster Fans (if provided) – Axial Flow pressure Lubricated</li> <li>2. Oxidation Blowers/Compressors-General</li> </ol> <p><b><u>DAMPERS &amp; GATES</u></b></p> <ol style="list-style-type: none"> <li>1. Manually Operated Damper</li> <li>2. Pneumatically Operated Damper</li> <li>3. Electrically Operated Damper</li> <li>4. Manually Operated Gates</li> <li>5. Pneumatically Operated Gate</li> <li>6. Electrically Operated Gate</li> </ol> <p><b><u>DUCT WORK</u></b></p> <ol style="list-style-type: none"> <li>1. Flue Gas Ducting</li> <li>2. Expansion Joints</li> <li>3. Observation &amp; Access Door</li> </ol> <p><b><u>CRANES AND ELEVATORS</u></b></p> <ol style="list-style-type: none"> <li>1. Crane</li> <li>2. Hoists</li> </ol> |  |
|--|--|--|

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>47 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | एनटीपीसी<br>NTPC |
|------------|--|------------------|
|            | <p>3. Passenger cum goods elevator</p> <p><b><u>POWER TRANSMISSION</u></b></p> <ol style="list-style-type: none"> <li>1. Power Transmission Gear Box</li> <li>2. Bearings</li> <li>3. Couplings</li> </ol> <p><b><u>FGD &amp; AUX.SYSTEM</u></b></p> <ol style="list-style-type: none"> <li>1. Agitators</li> <li>2. Air Motor</li> <li>3. Process trustle</li> <li>4. Limestone feeder</li> <li>5. Vacuum belt filter</li> <li>6. Limestone ball mill</li> <li>7. Limestone Hydrocyclones</li> <li>8. Primary Hydrocyclones</li> <li>9. Secondary Hydrocyclones</li> <li>10. Absorber internals</li> <li>11. Absorber Auxiliaries</li> </ol> <p><b><u>ELELCTRICAL</u></b></p> <ol style="list-style-type: none"> <li>1. D.C. Motor</li> <li>2. HV Squirrel Cage Induction Motor</li> <li>3. 415 V Squirrel Cage Induction Motor</li> <li>4. Motor Operated Actuators</li> <li>5. Soot Blower (GGH)</li> <li>6. Aux. Control and Relay Panel Desk</li> <li>7. SWITCHGEARS/MCC</li> </ol> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>48 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | एनटीपीसी<br>NTPC |
|------------|--|------------------|
|            | <p>(I.) STANDARD CHELISTS FOR ALL TYPES OF RELAYS USED IN SWITCHGEARS PROTECTION SYSTEM</p> <p>(II.) PT CARRIAGE AND CUBICLES</p> <p>(III.) CABLE/BUS DUCT/BUS BARS</p> <p>(IV.) CONTRACTOR MODULE</p> <p>(V.) SWITCH FUSE MODULE</p> <p>(VI.) MASTER PANEL OF LUBE OIL PANEL</p> <p>(VII.) FEEDER PANEL OF LUBE OIL PANEL</p> <p>(VIII.) SPACE HEATER AND CABLE MODULE</p> <p>(IX.) HT CIRCUIT BREAKER</p> <p>(X.) 415 V CIRCUIT BREAKER</p> <p>POWER CABLE</p> <p>AUXILIARY CABLE</p> <p>D.C. CABLE</p> <p>EXPLOSION PROOF ELECTRICAL EQUIPMENT</p> <p>JUNCTION BOX</p> <p>CONTROL TRANSFORMER MODULE</p> <p>BRUSH GEAR ASSEMBLY</p> <p>AUX. CONTROL AND RELAY PANEL DESK</p> <p>INDICATING INSTRUMENT</p> <p>RECORDING INSTRUMENT</p> <p>INTEGRATING INSTRUMENT</p> <p><b><u>CONTROL &amp; INSTRUMENTATION</u></b></p> <ol style="list-style-type: none"> <li>1. Conductivity Measuring Equipment Including Test Procedures</li> <li>2. pH Analyser Including Test procedure</li> </ol> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>49 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | एनटीपीसी<br>NTPC |
|------------|---|------------------|
|            | <p>3. Silica Analyser</p> <p>4. Level Switch (Float Actuated)</p> <p>5. Level Switch (Electrode Type)</p> <p>6. Level Switch (Displacer Actuated)</p> <p>7. Transmitter (Float Operated Pneumatic Output including Testing procedures</p> <p>8. Level indicator (Float/Pulley Type)</p> <p>9. Local Temperature Indicator Including Test Procedure</p> <p>10. Resistance Thermometer Element Including Test procedure</p> <p>11. Thermocouple Element and Connecting Cable</p> <p>12. Thermocouple and Resistance Thermometer Convertor/Transmitter Including Test Procedures</p> <p>13. Temperature Switch Including Test Procedure</p> <p>14. Cold Junction Boxes</p> <p>15. O<sub>2</sub> Analyser</p> <p>16. SO<sub>2</sub> analyzer</p> <p>17. O<sub>2</sub> in Hydrogen including Test procedures</p> <p>18. Pressure and Vacuum Gauge</p> <p>19. Pressure and Vacuum Switch Including Test procedures</p> <p>20. Differential Pressure Transmitter including Test Procedures</p> <p>21. Differential pressure switch including Test procedures</p> <p>22. Flow indicator (Variable Area)</p> <p>23. Orifice plate</p> <p>24. Flow Switch</p> <p>25. Nozzle</p> <p>26. Flow Integrator (pneumatic input) including test procedure</p> |                  |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>50 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT  | નાનીયિકી<br>NTPC |
|------------|---|------------------|
|            | <p>27. Flow indicator (Float Operated) Including Test Procedure</p> <p>28. Venturi (Fluid)</p> <p>29. Flow Switch (Magnetic Type)</p> <p>30. Limit Switches</p> <p>31. Turbine Supervisory Measuring System</p> <p>32. Position Measurement &amp; Indication Including Test procedures</p> <p>33. Vibration Measurement</p> <p>34. Digital Indicator</p> <p>35. Moving Coil Indicator Including Test Procedures</p> <p>36. Recorder Including Test procedure</p> <p>37. Flame Scanner</p> <p>38. Electrical Auto Manual Control Station</p> <p>39. Push Button Module</p> <p>40. Test Procedure for Electronic Modules of DDCMIS</p> <p>41. Alarm Announcer Equipment Including Test Procedure</p> <p>42. Test procedure for Adjustment of Modulating Controller-PID Term</p> <p>43. Test Procedure Indicating Controller-Electrical Input &amp; Pneumatic Output</p> <p>44. Density monitors</p> |                  |

Note: The items which are not part of this specification may be considered as not applicable.

| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>51 OF 53 |
|--|---|--------------------------------------|------------------|
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   | ANNEXURE-II |
|------------|--|-------------|
|            | <p><b>BRIEF WRITE UP ON THE CONTENTS OF TESTING SCHEDULE / COMMISSIONING SCHEDULE</b></p> <p>Testing Schedules should be designed to ensure that the plant area, equipment or apparatus are tested and commissioned and will operate as per the employer's specifications and good engineering practices.</p> <p>Testing Schedule/Commissioning Schedule is required to be of a standard format in order to maintain consistency of presentation, content and reporting.</p> <p>Testing Schedule/Commissioning Schedule should contain the following sections to make the document a self contained one:</p> <ol style="list-style-type: none"> <li>1. Plant Details/Design data</li> <li>2. Testing Objective/Proposals</li> <li>3. State of the Plant <ol style="list-style-type: none"> <li>a) Erection Status with respect to Mech. Elect and C&amp;I</li> <li>b) Availability of the services required</li> <li>c) Safety requirements as per Manufacturer's</li> </ol> </li> <li>4. Test method including completion/acceptance criteria</li> <li>5. Results</li> <li>6. Appendix <ol style="list-style-type: none"> <li>a) Testing Programme</li> <li>b) Mech/Elect/C&amp;I -Plant item completing list</li> <li>c) List of Drawing/documents required for carrying out the testing.</li> </ol> </li> </ol> |             |

|  |   |                                      |                  |
|--|---|--------------------------------------|------------------|
| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>52 OF 53 |
|--|---|--------------------------------------|------------------|

| CLAUSE NO. | ERCTION CONDITIONS OF CONTRACT   |  |
|------------|--|---|
|            | <p style="text-align: right;"><b>ANNEXURE - III</b></p> <p style="text-align: center;"><b>SAFETY PLAN</b></p> <p>01. Safety Policy of the Contractor to be enclosed:</p> <p>02. When was the Safety Policy last reviewed:</p> <p>03. Details of implementation procedure / methods to implement Safety Policy / Safety Rules:</p> <p>04. Name, Qualification, experience of Safety Officer</p> <p>05. Review of Accidents Analysis Method, Methods to ensure Safety and Health:</p> <p>06. Unit executive responsible to ensure Safety at various levels in work area:</p> <p>07. List of employees trained in safety employed before execution of the job. Give the details of training:</p> <p>08. Safety Training Targets, Schedules, methods Adopting to providing safety training to all employees:</p> <p>09. Details of checklist for different jobs / work and responsible person to ensure compliance (copy of checklist to be enclosed):</p> <p>10. Regular Safety Inspection Methods and Periodicity and list of members to be enclosed:</p> <p>11. Risk Assessment, Safety Audit by Professional Agencies, Periodicity:</p> <p>12. Implementation of Recommendations of Audit / Inspections. Procedures for implementation and follow up:</p> <p>13. Provision for treatment of injured persons at work site:</p> <p>14. Review of overall safety by top Management and Periodicity:</p> <p>15. System for Implementation of Statutory legislations:</p> <p>16. Issue of PPEs to employees, Periodicity / stock on hand etc:</p> |   |

Signature  
Head of the Organisation  
with date & stamp

| LOT-IB PROJECTS<br>FLUE GAS DESULPHURISATION (FGD)<br>SYSTEM PACKAGE | TECHNICAL SPECIFICATION<br>SECTION – VI, PART-D<br>BID DOC. NO. CS-0011-109(1B)-9 | ERCTION CONDITIONS<br>OF<br>CONTRACT | PAGE<br>53 OF 53 |
|--|---|--------------------------------------|------------------|
|--|---|--------------------------------------|------------------|