

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## **NOTICE INVITING TENDER**

**SUB: AMC FOR 2X2000 KVA HT 11 KV DG SET.– REG.**

**Ref: Enquiry no: 9251700018 / DATED: 19/05/2017; DUE DT: 14/06/2017**

Tender of the following work should be submitted in a sealed cover consisting of three inner sealed covers such as 1) EMD cover, 2) Technical bid cover & 3) Price bid cover, all superscribing the name of work, enquiry number etc.

- 1) EMD cover shall contain requisite **EMD of ₹ 7,155/-** remitted in cash (as permissible under Income Tax Act)/Electronic Fund Transfer credited in BHEL account before tender opening or Banker's cheque/Pay order/Demand Draft in favour of M/S BHEL Trichy. Tender without EMD will be summarily rejected and the Technical bid & price bid shall not be considered.
- 2) Technical bid cover shall contain duly filled in Technical bid document signed by the tenderer in all the pages with documentary evidences for pre-qualification such as experience, value of work executed in the similar nature of work etc. Any bid without proper documentary evidence for pre-qualification shall not be considered for further evaluation.
- 3) One set of unpriced bid of Contract Work Schedule duly signed by the tenderer for accepting the work content (BOM) should be submitted along with the Technical bid for technical evaluation.
- 4) The price bid cover shall contain price bid document duly filled in and signed by the tenderer in all the pages. The tenderer has to quote most competitive rates for all the items given in the Bill of Quantities in price bid.

The complete Technical bid and price bid along with requisite **EMD of ₹ 7,155/-** shall reach the office of the undersigned on or before **14/06/2017 at 14.00 Hrs.**

MSE suppliers can avail EMD Waiver benefits only if they submit along with the offer, attested copies of either EM II Certificate having deemed validity (five years from the date of issue of acknowledgement in EM II) or valid NSIC certificate or EM II Certificate along with attested copy of a CA Certificate (Format Enclosed). Tenders without EMD/MSME proof as detailed above will be summarily rejected.

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

The Technical bid will be opened on the same day at 14.30 hrs. In case of opening day falls on holiday or happened to be declared as a holiday the receipt and opening of the tender shall automatically fall on the same timing of the next working day. Date and time of opening of the Price Bid shall be intimated only to the bidders those who have qualified after evaluation of the Technical bid. You / Your authorized representative may participate in the tender opening.

Clarification if any can be obtained from the undersigned.

Kindly acknowledge the receipt of the entire set of tender document.

Thanking you,

Yours faithfully,

For Bharat Heavy Electricals Limited,  
Engineer / Contracts  
Maintenance & Services

Encl:

- 1) NIT – Notice Inviting tender (Consists of Preamble, Technical Bid & price bid)

Tender should be addressed to: **THE ENGINEER,**

**MAINTENANCE & SERVICES / CONTRACTS,**

**2&4 BUILDING, BHARAT HEAVY ELECTRICALS LIMITED, HIGH**

**PRESSURE BOILER PLANT,**

**TIRUCHIRAPPALLI - 620014,**

**TAMILNADU**

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## **NOTICE INVITING TENDER**

01.	Name of work	<b>AMC FOR 2X2000 KVA HT 11 KV DG SET.</b>
02.	Earnest Money Deposit	<b>₹ 7,155/-</b>
03.	Duration of the contract	12 Months (from date of commencement of the work)
04.	Last Date for Receipt of Tender	14.00 Hrs on 14/06/2017
05.	Date of Technical Bid Opening	14.30 Hrs on 14/06/2017
05.	Date of Price Bid Opening	Will be intimated to those who are Qualified separately.
07.	Guarantee Period	Not applicable

The Tender documents can be down loaded from BHEL website ([www.bhel.com](http://www.bhel.com)) / govt. website ([www.tenders.gov.in](http://www.tenders.gov.in)) at free of cost.

Tender document contains 18 Pages (Technical Bid - 17 Pages, Schedule for price bid – 01 page).

ISSUING OFFICER

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## TECHNICAL BID

**NAME OF THE WORK: AMC FOR 2X2000 KVA HT 11 KV DG SET.**

**Ref: Enquiry no: 9251700018/ Dated: 19/05/2017; Due dt: 14/06/2017**

### PRE-QUALIFICATION CRITERIA

The following eligibility criteria shall be complied to fulfill the Technical bid:-

Sl. No	Description	Vendor to confirm
1	The bidder shall be OEM or OEM authorized service provider for the caterpillar engines. Necessary document in support of the same shall be enclosed by the OEM authorized dealer with the offer.	
2	The bidder shall have experience in maintenance of 11kV HT DG Sets and of capacity 1000 kVA or higher for a period not less than one year in the past five years as on the date of opening the tender. Work order copies in support of the same shall be enclosed with the offer.	
3	Performance/ work completion certificate from minimum one customer for the satisfactory work carried out shall be enclosed with the offer.	
4	BHEL may verify the information provided by vendor. In case the information provided by vendor is found to be false / incorrect, the offer shall be rejected. Bidder to confirm.	
5	PAN Number (Copy to be Enclosed)	
6	Service tax Registration Number (If applicable) – Certificate copy to be enclosed	
7	Acceptance for Scope of Work as per the Enquiry	
8	Acceptance for All Terms & Conditions as per the Enquiry	
9	The bidder along with its associate/collaborators/sub-contractors/sub-vendors/consultans/service providers shall strictly adhere to BHEL fraud prevention policy displayed on BHEL website <a href="http://www.bhel.com">http://www.bhel.com</a> and shall immediately bring to the notice of BHEL management about any fraud or suspected fraud as soon as it comes to their notice	

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## SCOPE OF WORK: AMC FOR 2X2000 KVA HT 11 KV DG SET.

ITEM NO.	SCOPE OF WORK	QTY & UOM
10	<p><b>Maintenance of DG-1 Diesel Engine.</b></p> <p>Details of Engine: Make: Caterpillar Engine SI No: 7RN02097 Engine Model No: 3516B Rating: DG-1 2000kVA.</p> <p>Scope of works:</p> <ol style="list-style-type: none"><li>1.To carry out the scheduled maintenance,</li><li>2.To carryout condition monitoring of Engine,</li><li>3.To attend and rectify minor breakdown/ repair,</li><li>4.To carryout S.O.S &amp; coolant Analysis.</li></ol> <p>Check list to be verified:</p> <ol style="list-style-type: none"><li>1.Walk around inspection for identifying the leaks and loose connections if any</li><li>2.Checking engine Air cleaner for any dust entry and proper tightness for clamps &amp; mountings,</li><li>3.Checking the condition of batteries,</li><li>4.Check the fuel tank- drain water and sediment,</li><li>5.Check oil level and add if necessary. Calculate the lube oil consumption/ hour,</li><li>6.Check the condition of lube oil &amp; inspect for presence of diesel/ coolant mixing.</li><li>7.Check the log book, calculate average load factor and advise accordingly,</li><li>8.Check the coolant level and add if necessary,</li><li>9.Visually check the condition of belts &amp; proper tightness,</li><li>10.Check the driven equipment for any abnormalities,</li><li>11.Open the tappet cover and inspect the cylinder head components,</li><li>12.Start the engine &amp; observe for any abnormal sounds, leakages, load response, smoke level &amp; breayer fumes.</li><li>13.Apply loads in steps and observe the load response &amp; other parameters of engine,</li></ol>	6 NO

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<p>14. Any other observation &amp; informations. In addition to the work mentioned above, following checks shall be done when the engines attains the required number hours of operations as per the OEM recommendations:</p> <p>The following check list works to be carried out after 1500hrs operation/ once during the contract period:</p> <ol style="list-style-type: none"><li>1.Engine: Engine oil and oil filters to be replaced.</li><li>2.Fuel system: Primary fuel filters &amp; secondary fuel filters to be replaced.</li><li>3.Cooling system: Check the condition and performance of the coolant oil and add extender to increase coolant life if required.</li><li>4.Belts: check the condition and performance of the belt and relpace the belt if required.</li><li>5.Hose &amp; clamps: Inspect the condition and tightness of the Hose &amp; clamps.</li><li>6.Radiators: inspect the conditon and performance of the radiator and clean the radiator free from dirts, lubricants etc.</li><li>7.Bearing : Apply lubricant ( oil/grease etc) to the bearing as specified.</li><li>8.Engine : Clean the component free from dirts, lubricants etc.</li><li>9.Crankcsse breather : Clean the copmonent free from dirts, lubricants etc.</li><li>10.Engine protective devices: Check the condition and performance of the components.</li></ol>	
---	--

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<p style="text-align: center;"><b>20</b></p>	<p><b>Maintenance of DG-2 Diesel Engine.</b></p> <p>Details of Engine: Make: Caterpillar Engine SI No: 7RN02095 Engine Model No: 3516B Rating: DG-2 2000kVA.</p> <p>Scope of works:</p> <ol style="list-style-type: none"><li>1.To carry out the scheduled maintenance,</li><li>2.To carryout condition monitoring of Engine,</li><li>3.To attend and rectify minor breakdown/ repair,</li><li>4.To carryout S.O.S &amp; coolant Analysis.</li></ol> <p>Check list to be verified:</p> <ol style="list-style-type: none"><li>1.Walk around inspection for identifying the leaks and loose connections if any</li><li>2.Checking engine Air cleaner for any dust entry and proper tightness for clamps &amp; mountings,</li><li>3.Checking the condition of batteries,</li><li>4.Check the fuel tank- drain water and sediment,</li><li>5.Check oil level and add if necessary. Calculate the lube oil consumption/ hour,</li><li>6.Check the condition of lube oil &amp; inspect for presence of diesel/ coolant mixing.</li><li>7.Check the log book, calculate average load factor and advise accordingly,</li><li>8.Check the coolant level and add if necessary,</li><li>9.Visually check the condition of belts &amp; proper tightness,</li><li>10.Check the driven equipment for any abnormalities,</li><li>11.Open the tappet cover and inspect the cylinder head components,</li><li>12.Start the engine &amp; observe for any abnormal sounds, leakages, load response, smoke level &amp; breayer fumes.</li><li>13.Apply loads in steps and observe the load response &amp; other parameters of engine,</li><li>14.Any other observation &amp; informations.</li></ol>	<p style="text-align: center;"><b>6 NO</b></p>
--	--	--

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<p>In addition to the work mentioned above, following checks shall be done when the engines attains the required number hours of operations as per the OEM recommendations:</p> <p>The following check list works to be carried out after 1500hrs operation/ once during the contract period:</p> <ol style="list-style-type: none"><li>1.Engine: Engine oil and oil filters to be replaced.</li><li>2.Fuel system: Primary fuel filters &amp; secondary fuel filters to be replaced.</li><li>3.Cooling system: Check the condition and performance of the coolant oil and add extender to increase coolant life if required.</li><li>4.Belts: check the condition and performance of the belt and relpace the belt if required.</li><li>5.Hose &amp; clamps: Inspect the condition and tightness of the Hose &amp; clamps.</li><li>6.Radiators: inspect the conditon and performance of the radiator and clean the radiator free from dirts, lubricants etc.</li><li>7.Bearing : Apply lubricant ( oil/grease etc) to the bearing as specified.</li><li>8.Engine : Clean the component free from dirts, lubricants etc.</li><li>9.Crankcsse breather : Clean the copnoment free from dirts, lubricants etc.</li><li>10.Engine protective devices: Check the condition and performance of the components.</li></ol>	
---	--

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<b>30</b>	<p><b>Maintenance of DG-1 Alternator</b></p> <p>Details of Alternator: Make: TDPS Alternator SI No: T-01807 Engine Model No: TD-100 Rating: DG-1 2000kVA.</p> <p>Scope of works: 1.To carry out the scheduled maintenance in the alternator, 2.To carryout condition monitoring of DG Set, 3.To attend and rectify minor breakdown/ repair in the alternator.</p> <p>Apart form the above works following checks shall be performed:</p> <ol style="list-style-type: none"><li>1.Walk around inspection,</li><li>2.Cleaning the alternator with the vaccum cleaner,</li><li>3.Checking the bearing sound and temperature,</li><li>4.Checking the voltage for propoer stability at noload and load &amp; power factor,</li><li>5.Checking the tightness of live terminals,</li><li>6.Removing the alternator cover and inspect for any loose connections/ damage/ burns etc. Correction if required.</li><li>7.Checking fuses for its healthiness,</li><li>8.Checking the live terminals for its proper clearance and spacing,</li><li>9.Checking the bearings and grease the bearings with proper grade and quantity,</li><li>10.Checking the winding insulation resistance value,</li><li>11.Checking the space heaters for proper operation,</li><li>12.Checking for any abnormal vibration and correct it if required.</li></ol>	<b>6 NO</b>
-----------	---	-----------------

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<b>40</b>	<p><b>Maintenance of DG-2 Alternator</b></p> <p>Details of Alternator: Make: TDPS Alternator SI No: T-01784 Engine Model No: TD-100 Rating: DG-2 2000kVA.</p> <p>Scope of works: 1.To carry out the scheduled maintenance in the alternator, 2.To carryout condition monitoring of DG Set, 3.To attend and rectify minor breakdown/ repair in the alternator.</p> <p>Apart form the above works following checks shall be performed:</p> <ol style="list-style-type: none"><li>1.Walk around inspection,</li><li>2.Cleaning the alternator with the vaccum cleaner,</li><li>3.Checking the bearing sound and temperature,</li><li>4.Checking the voltage for propoer stability at noload and load &amp; power factor,</li><li>5.Checking the tightness of live terminals,</li><li>6.Removing the alternator cover and inspect for any loose connections/ damage/ burns etc. Correction if required.</li><li>7.Checking fuses for its healthiness,</li><li>8.Checking the live terminals for its proper clearance and spacing,</li><li>9.Checking the bearings and grease the bearings with proper grade and quantity,</li><li>10.Checking the winding insulation resistance value,</li><li>11.Checking the space heaters for proper operation,</li><li>12.Checking for any abnormal vibration and correct it if required.</li></ol>	<b>6 NO</b>
-----------	---	-----------------

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<p>50</p>	<p><b>Maintenance of DG-1 Control Panel</b> Control Panels of 2x2000kVA DG Set-1 to be checked. 1.11kV Switchgear Panel, 2.Neutral Grounding Resistance Panel, 3.Relay Metering Panel, 4.Battery Charging Panel,</p> <p>Following Scope of works for the contractor: 1.To carry out the scheduled maintenance of the panels, 2.To carryout condition monitoring of DG Sets, 3.To attend and rectify minor breakdown/ repair in the panels.</p> <p>Checklist to be done: 1.Inspection of the control panel for its healthiness/ Correctness, 2.Cleaning the control panels with vaccum cleaner, 3.Checking the operation of electrical meters, 4.Checking the operation of relay units, 5.Checking the operation of AMF controller units, 6.Checking the operation of circuit breakers, 7.Checking the tightness of live terminals, 8.Checking the functionality of protection relays. 9.Conducting insulation test for the cables as per the testing procedure.</p>	<p>6 NO</p>
-----------	---	-----------------

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<b>60</b>	<p><b>Maintenance of DG-2 Control Panel</b> Control Panels of 2x2000kVA DG Set-2 to be checked.</p> <ol style="list-style-type: none"><li>1. Switchgear Panel,</li><li>2. Neutral Grounding Resistance Panel,</li><li>3. Relay Metering Panel,</li><li>4. Battery Charging Panel,</li></ol> <p>Following Scope of works for the contractor:</p> <ol style="list-style-type: none"><li>1. To carry out the scheduled maintenance of the panels,</li><li>2. To carry out condition monitoring of DG Sets,</li><li>3. To attend and rectify minor breakdown/ repair in the panels.</li></ol> <p>Checklist to be done:</p> <ol style="list-style-type: none"><li>1. Inspection of the control panel for its healthiness/ correctness,</li><li>2. Cleaning the control panels with vacuum cleaner,</li><li>3. Checking the operation of electrical meters,</li><li>4. Checking the operation of relay units,</li><li>5. Checking the operation of AMF controller units,</li><li>6. Checking the operation of circuit breakers,</li><li>7. Checking the tightness of live terminals,</li><li>8. Checking the functionality of protection relays.</li><li>9. Conducting insulation test for the cables as per the testing procedure.</li></ol> <p>Spares required for the maintenance work:</p> <p>Necessary spares required for the preventive maintenance will be given by BHEL at free of cost to the contractor. Other critical spare (if any) required by the contractor for breakdown maintenance, separate list has to be submitted by the contractor along with the budgetary quote.</p>	<b>6 NO</b>
-----------	---	-----------------

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

<p><b>GENERAL CONDITIONS:</b></p> <p>1.The contractor should engage qualified &amp; experienced service engineers for maintenance work. The total staff proposed for this contract should be mentioned separately for in the offer.</p> <p>2.All essential special tools shall be in the scope of bidder for performing the maintenance activities.</p> <p>3.Proper Safety procedure should be followed by using safety shoes, safety hand gloves etc. as per the instructions while executing the maintenance works in 2000 KVA DG.</p> <p>4.The contractor may specifically note that the scope of work as detailed above are only indicative of the probable nature of work and the entire scope of work is not limited to the information furnished above.</p> <p>5.The following items will be issued by BHEL free of cost at BHEL stores/site.</p> <p>(a).To provide consumables, Oil, Preventive Maintenance Spares, Break down spares and scheduled overhauling spares for Engines, Alternators, and Control Panels &amp; Radiator as required.</p> <p>(b).Supply of Fuel.</p> <p>(c).DM water for the engine cooling system.</p> <p>6.The following facilities will be arranged by BHEL:</p> <p>6.1).All necessary basic &amp; hand tools, crane, lifting tackles, waste cleaning clothes, diesel &amp; petrol for cleaning purposes and any other consumables that may be required.</p> <p>6.2). Cleaning &amp; Reconditioning of sub-assemblies like Radiator, Oil cooler, After cooler, Heat Exchanger, Battery, switchgear panels, control panels, etc.</p> <p>6.3). Maintenance as per the recommendations of OEM recommendations and periodical maintenance as per schedule.</p> <p>7.PAYMENT TERMS: Payment will be made once in Two months after completion of the preventive maintenance on submission of invoice in triplicate duly certified by Engineer in-charge.</p> <p>8.The DG Set is installed near the 110/11kV substation of HPBP/BHEL Trichy.</p>	
--	--

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## **GENERAL TERMS AND CONDITIONS FOR M&S CONTRACTS**

- 1) The workmen of contractor should be covered under PF/ESI, etc as per labour laws.
- 2) Safety precautions have to be ensured by the Contractor Depending on the work nature. Necessary work permit system and personal protective equipments (PPE) such as electrical resistance rubber gloves, helmet, spectacle goggles, safety shoes, safety belt etc. as applicable to Mechanical works should be adhered while carrying out the work.
- 3) PPEs for appropriate trade job has to be ensured by the contractor at the job site at all times.
- 4) The contractors may visit the area to assess the quantum of work before quoting.
- 5) The contractor should mention the point to point confirmation.
- 6) Contractor should commit for Terms and Conditions of the enquiry otherwise the offer shall be liable for rejection.
- 7) **TWO PART BID SYSTEM:** Contractor should send their offer for two part bid system as below
- 8) Contractor may visit to get acquaintance with quantum of day to day work by visiting BHEL Trichy premises before quoting.
- 9) The contractor should quote the exact time required to complete the work in their offer.

### **TENDERING CONDITIONS:**

- a) The Bidders shall submit the offer in TWO PART BID SYSTEM (Part -I & II) along with EMD as indicated below which shall be sealed in ONE OUTER ENVELOPE.
- b) Envelope I- This sealed envelope should contain all the copies of technical bid together with un-priced commercial bid. This envelope should be clearly marked "Part I - Technical and commercial bid", indicating Enquiry No., Due Date and Address & Reference of the Bidder. Envelope I should contain sealed EMD cover indicating the enquiry detail.
- c) Envelope II - This sealed envelope should contain price details. This envelope should be clearly marked as - "Part -II Price bid", indicating Enquiry No., Due Date and Address & Reference of the Bidder.
- d) Envelope III - This sealed envelope should contain requisite **EMD**. This envelope should be clearly marked as - "EMD COVER", indicating Enquiry No., Due Date and Address & Reference of the Bidder.
- e) All the three envelopes shall be put in one cover, duly sealed, super scribing as offer for Enquiry No., and due date of opening, Name of the work and the address and reference of the Bidder.
- f) The offer should reach this office on or before the due date by 14.00 Hrs. (IST). Late offers will not be considered.

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

g) Tender should not be addressed to any Individual's name but only by designation to:

THE SENIOR MANAGER  
MAINTENANCE & SERVICES / CONTRACTS,  
2&4 BUILDING,  
BHARAT HEAVY ELECTRICALS LIMITED,  
HIGH PRESSURE BOILER PLANT,  
TIRUCHIRAPALLI - 620 014.  
TAMIL NADU, INDIA.

h) Tenders should be free from CORRECTION AND ERASURES, Corrections if any, must be attested. All amounts shall be indicated both in words as well as in figures. Where there is difference between amount quoted in words and figures, amount quoted in words shall prevail.

i) Offers should be in ENGLISH and accompanied by detailed Point to point confirmation of the scope of work.

## **OPENING OF TENDERS:**

- The Part I - Technical & un-priced commercial bid and EMD Cover alone would be opened on the Tender opening date(as mentioned in the enquiry) by 14.30Hrs(IST)
- The Part II - Price bid of technically suitable Bidders alone would be opened. The Technically suitable Bidders would be informed about the Price bid opening date.
- Clarifications if any required by BHEL for Technical evaluation would be sought from Bidders before opening of Part II - price bid.

## **SERVICE TAX:**

- A copy of Service tax remittance challan for previous quarter should be submitted along with offer if the contractor is claiming service tax.
- If Contractor is exempted from service tax then a declaration that they are within the threshold limit should be submitted along with the offer.

## **LD CLAUSE:**

If the contractor fails to complete the work as per terms & conditions of the order within the delivery schedule, 0.5% of the order value will be deducted for each week of delay or part thereof subject to a maximum of 10% of the total contract value.

**IMPORTANT NOTE:** BHEL reserves the right to short close this AMC with one month advance notice due to administrative reasons. BHEL's decision in this regard is final. Under such circumstances payment will be made for actual number of cleanings carried out up to the period.

\*\*\*\*\*

Sign & Seal of Contractor

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

☎: (0431) 2575010 [e-mail: umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)



ISO 9001

ENQ No: 9251700018

Dt.19.05.2017

## **COMMERCIAL TERMS AND CONDITONS FOR M&S CONTRACTS**

- 1) Payment will be made once in Two months after completion of the preventive maintenance on submission of invoice in triplicate duly certified by Engineer in-charge.
- 2) Attendance register should be maintained.
- 3) EMD is to be submitted and is to be remitted in cash (as permissible under Income Tax Act)/Electronic Fund Transfer credited in BHEL account before tender opening or Banker's cheque/Pay order/Demand Draft in favour of M/S BHEL Trichy along with offer. **Offers without EMD shall be liable for rejection.**
- 4) Security Deposit shall be furnished by the successful vendor to the total contract value before starting the work. The total amount of Security Deposit will be 5% of the contract value. EMD of the successful tenderer shall be converted and adjusted towards the required amount of Security Deposit. SD is forfeited in case of any failure in execution of the contract or due to any shortcomings observed in the documentation furnished earlier for getting qualified or in case the Contractor is banned.
- 5) An additional payment as per circular ref. BHE/HR/W/EW/08.04.2014 is to be paid to the contract workmen as below, over and above the minimum wages prescribed by the government of Tamil Nadu:

Unskilled	-	Rs.3200/-
Semiskilled	-	Rs.3700/-
Skilled	-	Rs.4100/-
- 6) Bonus @ 8.33 % to workmen to be paid.
- 7) **Rate should be quoted as per price bid.**
- 8) Taxes if any will be mentioned separately in the offer.
- 9) The rate that is offered should be comprehensive and no separate charges will be made towards expenses like travel, boarding and lodging.
- 10) The contractor should quote the validity of the offer.
- 11) If two or more vendors offer the same rate, negotiation will be conducted separately.
- 12) The contractor should remit the salary/wages for their workmen only through Bank. Monthly clearance will be given in respect of all contractors, if only the salary/ wages to the workmen has been remitted through the bank account of the contract workmen. The relevant Bank statement/proof for Bank payment should be produced along with PF and ESI challan's to Welfare Section every month.

\*\*\*\*\*

Sign & Seal of Contractor

## Certificate by Chartered Accountant on Letter Head

This is to certify that M/s. \_\_\_\_\_ (hereinafter referred to as 'company') having its registered office at \_\_\_\_\_ is registered under MSMED Act 2006, (Entrepreneur Memorandum No (Part II)) \_\_\_\_\_ dt. \_\_\_\_\_, Category: (Micro/Small). (Copy enclosed).

Further verified from the Books of Accounts that the investment of the company as per the latest audited financial year \_\_\_\_\_ as per MSMED Act 2006 is as follows:

**1. For Manufacturing Enterprises:** Investment in plant and machinery (i.e. original cost excluding land and building and the items specified by the Ministry of Small Scale Industries vide its notification No. S.O.1722(E) dated October 5, 2006):

₹ \_\_\_\_\_ Lacs

**2. For Service Enterprises:** Investment in equipment (original cost excluding land and building and furniture, fittings and other items not directly related to the service rendered or as may be notified under the MSMED Act 2006):

₹ \_\_\_\_\_ Lacs

**(Strike off whichever is not applicable)**

The above investment of ₹ \_\_\_\_\_ Lacs is within permissible limit of ₹ \_\_\_\_\_ Lacs for \_\_\_\_\_ Micro / Small (Strike off which is not applicable) Category under MSMED Act 2006.

Or

The company has been graduated from its original category (Micro/Small) (Strike off which is not applicable) and the date of graduation of such enterprise from its original category is ..... (dd/mm/yyyy) which is within the period of 3 years from the date of graduation of such enterprise from its original category as notified vide S.O. No. 3322(E) dated 01.11.2013 published in the gazette notification dated 04.11.2013 by Ministry of MSME.

Date:

(Signature)

Name:

Membership number:

Seal of Chartered Accountant

# BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

High Pressure Boiler Plant, Tiruchirappalli 620 014, India

**MAINTENANCE & SERVICES DEPARTMENT**

(0431) 2575010 e-mail: [umadsankar@bheltry.co.in](mailto:umadsankar@bheltry.co.in)

ENQ No: 9251700018

Dt.19.05.2017

## **SCHEDULE FOR PRICE BID**

**SUB: AMC FOR 2X2000 KVA HT 11 KV DG SET.**

**Ref: Enquiry no: 9251700018 / Dated: 19/05/2017; Due dt: 14/06/2017**

ITEM No.	DESCRIPTIONS	UOM	QTY	RATE IN ₹	VALUE IN ₹
10	Maintenance of DG-1 Diesel Engine.	NO	6		
20	Maintenance of DG-2 Diesel Engine.	NO	6		
30	Maintenance of DG-1 Alternator	NO	6		
40	Maintenance of DG-2 Alternator	NO	6		
50	Maintenance of DG-1 Control Panel	NO	6		
60	Maintenance of DG-2 Control Panel	NO	6		

- Taxes if any should be quoted extra
- 1). Payment will be made once in Two months after completion of the preventive maintenance on submission of invoice in triplicate duly certified by Engineer in-charge.
  - 2). Tax deduction will be made from the every bill at the prevailing rate as per the Government rule and regulation from timeto time.
  - 3). Detailed scope of work and other terms and conditions are specified in the Technical Bid of the Tender.
  - 4). Cumulative L-1 will be considered for Ordering.

Sign & Seal of Contractor