



General Note:

Page:1/4

PHONE : 91-44-28158821

GRAMS : BHARATELEC

FAX NO:

E-mail :

Web :

OFFICE COPY**Collective No.**

9641700136

Enquiry Date

27.11.2017

**Due Date For
Quotation**

18.12.2017

Please quote Enquiry No, Date and due date in all correspondences.
This is only a request for quotation and not an order

Item	Description	Unit	Quantity	Delivery Quantity	Schedule Date
10	SP2000201075 5.5KW, 132S, 4POLE, B5, IE2 SQ.CAGE MOTOR 3 PHASE TEFC SQUIRREL CAGE INDUCTION MOTORCAPACITY : 5.5 KWREFERENCE STANDARD : IS 12615/IEC:60034-1VOLTAGE : 415V + /-10% 3 PHASEFREQUENCY : 50 Hz + /-5%FRAME : 132SNO.OF POLES : 4INSULATION : CLASS FMOUNTING : IMB5-FLANGE MOUNTINGDUTY : S1DEGREE OF PROTECTION: IP55EFFICIENCY CLASS : IE2 COOLING : IC411TESTING:- TYPE TESTED AS PER IS:325 AND IS:15999.ALL STANDARDS ARE APPLICABLE WITH LATEST REVISIONS.	NO	30.000	30.00	16.02.18
20	SP2000201081 1.1KW, 90S, 4POLE, B5, IE2 SQ.CAGE MOTOR 3 PHASE TEFC SQUIRREL CAGE INDUCTION MOTORCAPACITY : 1.1 KWREFERENCE STANDARD : IS:12615/IEC:60034-1 VOLTAGE : 415V + /-10% 3 PHASEFREQUENCY : 50 HZ + /- 5%FRAME : 90SNO.OF POLES : 4 INSULATION CLASS : FMOUNTING : IMB5-FLANGE MOUNTINGDUTY : S1DEGREE OF PROTECTION: IP55EFFICIENCY CLASS : IE2CO OLING : IC411TESTING : TYPE TESTED AS PER IS : 325 AND IS: 15999.ALL STANDARDS ARE APP LICABLE WITH LATEST REVISIONS.	NO	10.000	10.00	16.02.18
30	SP2000201115 5.5KW, 132M, 6POLE, B5, IE2 SQ.CAGE MOTOR 3 PHASE TEFC SQUIRREL CAGE INDUCTION MOTOR CAPACITY : 5.5 KWREFERENCE STANDARD : IS:12615/IEC:60034-1 VOLTAGE	NO	20.000	20.00	16.02.18

The offers should reach us 30 minutes before the time of opening of tenders.
The offers will be opened at 14.30 hrs on the due date of tender in the presence of
tenderers who have submitted their offer and who may like to be present for the tender
opening.Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)

**9641700136 / 27.11.2017****23505**

: 415V + /-10% 3 PHASE FREQUENCY : 50 HZ + /- 5% FRAME : 132MNO.OF POLES : 6 INSULATION CLAS S : FMOUNTING : IMB5-FLANGE MOUNTINGDUTY : S1DEGREE OF PROTECTION: IP55 EFFICIENCY CLASS : IE2C OOLING : IC411 TESTING : TYPE TESTED AS PER IS : 325 AND IS:15999.ALL STANDARDS ARE APP LICABLE WITH LATEST REVISIONS.	NO	10.000	10.00	16.02.18
40 SP2000201127 7.5KW, 132M, 4POLE, B5, IE2 SQ.CAGE MOTOR 3 PHASE TEFC SQUIRREL CAGE INDUCTION MOTORCAPACITY : 7.5 KWREFERENCE STANDARD : IS:12615/IEC:60034-1 VOLTAGE : 415V + /-10% 3 PHASE FREQUENCY : 50 HZ + /- 5% FRAME : 132MNO.OF POLES : 4 INSULATION CLASS : FMOUNTING : IMB5-FLANGE MOUNTINGDUTY : S1DEGREE OF PROTECTION: IP55 EFFICIENCY CLASS : IE2CO OLING : IC411 TESTING : TYPE TESTED AS PER IS : : 325 AND IS:15999.ALL STANDARDS ARE APPL ICABLE WITH LATEST REVISIONS. Note to Supplier: 1.Datasheets and GA drawings of the offered motors must be provided. Offers without these documents will not be be considered. 2.Authorization certificate from the Principal Supplier should be submitted in case of Dealers/ Agents. 3.Test certificates and Maintenance manuals must be provided along with the supply of motors. TENDER NOTES: 1. This Tender is floated on TWO-BID basis. 2. Following details are enclosed. a.,Annexure-A - Important Note to Tenderers & Annexure-D Note to MSE Vendors enclosed. Send your MSE Certificate accordingly. Tenderers are requested to submit their Offers in TWO-BID basis, viz., I.,Part I,.,.,Technical and Un-Priced Commercial Bid II.,Part II,.,.,Price Bid b.,Annexure-B - Technical Conditions c.,Annexure-C - Commercial Conditions 3. Tenderers are required to fill in above				

The offers should reach us 30 minutes before the time of opening of tenders.
The offers will be opened at 14.30 hrs on the due date of tender in the presence of
tenderers who have submitted their offer and who may like to be present for the tender
opening.Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)

**9641700136 / 27.11.2017****23505**

Annexure-B and C and enclose them along with their UN-PRICED BID.

4.a. Delivery date furnished in the Enquiry is only indicative.

4.b. For Delivery Schedule - Pl. refer Clause No. C.4 of Annexure- C.

5. Price Bid of Vendors, who accept the Clause No. B.1 to B.5 of Annexure-B & C.1 to C.4 of Annexure- C. shall only be considered for further processing. Fill the Annexure-B & C and enclose it with Technical and Un-Priced commercial Bid.

For Payment term - Refer Annexure - C Point No. C- 2. Any deviation in the above payment term will attract loading as mentioned below.

For payment term deviation - "Base rate of SBI (as applicable on the date of bid opening. Techno-commercial bid opening in case of two part bids) + 6% shall be considered for loading for the period of relaxation sought by bidders.

Payment through Bank is not preferred. In case of Payment through Bank is opted by Supplier, BHEL prefers documents submission through bank with copy of LR and door delivery of Goods to Stores with Consignee copy attached. In this case Loading will be 3% on the offered value. Offers of indigenous Suppliers with payment terms as LC/Advance Payment are liable for rejection.

General Note:**Enclosures:****"LD clause has to be confirmed without fail."**

The bidder along with its associate / collaborators / sub-contractors / sub-vendors / consultants /service providers shall strictly adhere to BHEL fraud prevention policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.

PR Links

Material.	PR.No	PR.Item.	Quantity	Acc. Assign	Customer Number
SP2000201075	120278151	00010	30.000	/000000	
SP2000201081	120278151	00020	10.000	/000000	
SP2000201115	120278151	00030	20.000	/000000	

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)

**9641700136 / 27.11.2017****23505**

Material.	PR.No	PR.Item.	Quantity	Acc. Assign	Customer Number
SP2000201127	120278151	00040	10.000	/000000	

list of suppliers**RFQ-5200006608****Open Tender Dummy Code**

The offers should reach us 30 minutes before the time of opening of tenders.
The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)