



General Note:

Page:1/2

PHONE : 91-44-28158821

GRAMS : BHARATELEC

FAX NO:

E-mail :

Web :

OFFICE COPY**Collective No.**

9641800068

Enquiry Date

26.04.2018

**Due Date For
Quotation**

17.05.2018

Please quote Enquiry No, Date and due date in all correspondences.
This is only a request for quotation and not an order

Item	Description	Unit	Quantity	Delivery Quantity	Schedule Date
10	SP2002004137 Flame proof panel-1 LPG Yard Flame proof panel-1 LPG Yard. 1) Incomer1: 400A SFU (EB Main power supply). 2) Outgoing1: 200A SFU (1000Kg Vaporiser). 3) Outgoing2: 200A SFU (500Kg Vaporiser). 4) Outgoing3: 200A SFU (spare). 5) Outgoing4: 200A SFU (spare). 6) Outgoing5: 32A SFU (Unloading compressor1). 7) Outgoing6: 32A SFU (Unloading compressor2). 8) Outgoing6: 32A SFU (Unloading compressor3). Each outgoing should have analog ammeter fixed with viewing glass. Incoming should have energy meter fixed. Energy meter shall be of model PAC3200 from M/s Siemens with viewing glass for viewing from outside. All feeders should have individual RYB Indicators. Panel shall be titled with metal tag "LPG YARD MCC PANEL 1". The panel should be flame proof for installation in LPG Yard area. Necessary certificates should be produced along with materials. Minimum detailed bill of materials are attached for compliance. Any additional data should be produced during the technical bid of tender.	NO	1.000	1.00	13.08.18
20	SP2002004138 Flame proof panel-2 LPG Yard Flame proof panel-2 LPG Yard. 1) Incomer1: 400A SFU with suitable rated fuse (EB Main power supply). 2) Outgoing1: DOL starter with Auto/Manual switch for 55KW 94A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 3) Outgoing2: DOL starter with Auto/Manual switch for 9.3KW 17.3A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 4) Outgoing3: DOL starter with Auto/Manual switch for 5)	NO	1.000	1.00	13.08.18

The offers should reach us 30 minutes before the time of opening of tenders.
The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)

**9641800068 / 26.04.2018****23505**

Outgoing4: DOL starter with Auto/Manual switch for 55KW 94A motor(pump application). Auto starting on receiving NC signal from field. Manual start/stop by button operation on panel. 6) Outgoing5: 63A SFU for lighting. 7) Outgoing6: 63A SFU spare. 8) Outgoing7: 32A SFU for local compressor. Each outgoing should have analog ammeter fixed with viewing glass. Incoming should have energy meter fixed. Energy meter shall be of model PAC3200 from M/s Siemens with viewing glass for viewing from outside. All feeders should have individual RYB Indicators. Panel shall be titled with metal tag "LPG YARD MCC PANEL 2". The panel should be flame proof for installation in LPG Yard area. Necessary certificates should be produced along with materials. The panel should be flame proof for installation in LPG Yard area. Necessary certificates should be produced along with materials. Minimum detailed bill of materials are attached for compliance. Any additional data should be produced during the technical bid of tender.

General Note:**Enclosures:****"LD clause has to be confirmed without fail."**

The bidder along with its associate / collaborators / sub-contractors / sub-vendors / consultants / service providers shall strictly adhere to BHEL fraud prevention policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.

PR Links

Material.	PR.No	PR.Item.	Quantity	Acc. Assign	Customer Number
SP2002004137	121508146	00010	1.000	/000000	
SP2002004138	121508146	00020	1.000	/000000	

list of suppliers**RFQ-5200007011****Open Tender Dummy Code**

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**

MANAGER / PURCHASE
(SSTP)