

Ennore tentative heat dissipation data

SI	Area	Heat Dissipation (tentative)	Location
a	Central Control Room	35 KW	17m
b	Control Equipment Room	150 KW	17m
c	Computer Room / DAS Room	56 KW	17m
d	Shift incharge room:	2.6 KW	17 m
e	C&I engineer room:	2.2 KW	17 m
f	UPS Room	70 KW	8.5 m
g	Charger Room		8.5 m

It may be noted that these are tentative data and may change during detail
Note: engg