



**AMENDMENT ON TECHNICAL SPECIFICATION
FOR EFFLUENT TREATMENT PLANT**

1x370 MW YELAHANKA CCPP

SPECIFICATION NO.: PE-TS-409-164-A001

AMENDMENT NO # 2

REV. NO. 00

DATE: 15/10/2016

Page 1 of 1

The following modifications with respect to Technical Specification for **EFFLUENT TREATMENT PLANT**, BHEL's Technical specification number PE-TS-409-164-A001 Rev 00 shall apply.

MODIFIED CLAUSES/PAGE NUMBERS.

SL NO	SECTION	SUB SECTION	CLAUSE NO	PAGE NO	EXISTING			MODIFIED TO		
1.	SECTION	SUB SECTION	2.46.5 (iv)	Page 6 of 188	Sr. No.	PIPING	TOTAL PIPING LENGTH IN METERS (BIDDER'S SCOPE)	Sr. No.	PIPING	TOTAL PIPING LENGTH IN METERS (BIDDER'S SCOPE)
					iv.	Piping distance from GT/ST Area Floor Wash Collection Pit to Line from Burnt Oil Collection Pit to ETP Area	100 Meters.	iv.	Piping distance from GT/ST Area Floor Wash Collection Pit to Line from Burnt Oil Collection Pit to ETP Area	350 Meters.
