

**SUB : AMENDMENT – 01 – REVISED PRICE BID & CLARIFICATIONS- REG**  
**Tender Specification No. BHE/PW/PUR/ FINSE-CVL/683**

**REPLY TO BIDDER’S QUERIES:**

**ANNEX-C-1**

Sl. No.	Bidders Query	BHEL’s Reply	REMARKS
1	<p><b>Bricks:-</b> There is non availability of Bricks in Ethiopia but as per practice in Ethiopia Govt. they use cement bricks block: Please clarify whether bricks are to be used or cement bricks can be used.</p>	<p>Please refer cl. No. 24.6.3 &amp; 24.6.4 of specifications attached with NIT for brick work &amp; concrete block work respectively.</p> <p>In view of the query, existing BOQ item no. 7.2 (b), 7.2(c), 7.3 &amp; 7.4 in Part-A <b>Main civil works</b> has been changed as <b>Concrete solid block of class AA</b> as per BATCODA standards.</p> <p>Similarly for Enabling works <b>Part-B, section A</b>, Item No. (9), <b>Section C</b> Item No. (7) has been changed as <b>Concrete hollow block of class AA</b> as per BATCODA standards.</p>	<b>Incorporated in revised Price-bid/BOQ</b>
2	<p><b>ACC Sheet:-</b>(Part B - Section A, Item no 11) As per our enquiry in Ethiopia the ACC Sheet is Banned so please let it know ACC Sheet is to be fixed or not.</p>	<p>In view of the query, existing BOQ Item No.11 Part B, Section A has been changed as <b>22G, GI Corrugated sheet</b>. Qty. shall remain same.</p> <p>Similarly <b>Item No. 12, Part-B, section A for false ceiling</b> has changed as <b>Teak wood particle board half perforated sheet 12 mm thick</b> in place of 4mm plain AC sheet</p>	<b>Incorporated in revised Price-bid/BOQ</b>

3	Item no. 16.3:- (Part A – Main Civil)Carbon Steel pipe is to be used please clarify the schedule of CS pipe & all the specification you required.(thickness)	100mm dia. - min. thickness 4.5mm & 150mm dia. min. thickness 4.8mm  200mm dia. – thickness >4.8mm & 300mm dia. min. thickness 5.6mm	<b>Incorporated in revised Price-bid/BOQ item no. 16.3 Part A , main civil works</b>
4	<u>Section B:-</u> Please clarify the specification of the cable size and length.	(1) Agency has to decide the size of the cables - external as well as internal for lighting of sheds of size 65x15M for their L.S. price (2) Approx. distance of Main Source of supply from store complex may be assumed as 500M.	<b>Agency to quote their rate accordingly.</b>
5	If any service tax is applicable it shall be borne by us or it shall be paid by you- Please clarify.	Taxes & Duties are clearly specified in Tender Specification Section-5, Cl No.5.9	-----
6	In clause no. 11.12 page 64, related to secured advance against materials brought at site, it is to submit that instead of a max 75% of the value (Invoice value) as given in the paid up purchase voucher , the secured advance be applicable on the material cost FOR site inclusive of all taxes, levies etc. or alternatively 75% of the cost of BOQ item rate. Please Clarify	No change in tender specification	-----