



QUALIFYING REQUIREMENTS

Revision 01, Dated:01.03.18

Enquiry Ref: NIT_36872 (3871553E)

Item: Rubber Lining for Absorber and Tanks for Bongaigaon NTPC Project (3x250MW).

The Bidder is required to meet the qualification requirement for rubber lining as per criteria stipulated below:

Rubber lining for the Wet Limestone based Flue Gas Desulphurization (FGD) System offered by the bidder shall be only from such bidders(s) who has previously executed this rubber lining application for Wet Limestone based FGD application such that the rubber lining should have been in successful operation in at least one plant for a period not less than one year reckoned as on the date of technical bid opening.

OR

Similar application where the rubber lining has to withstand erosion and corrosion environment with the area of application 2500 m² minimum per single item such that the rubber lining should have been in successful operation in at least one plant for a period not less than one year reckoned as on the date of technical bid opening.

The Bidder should provide reference list and performance certificates from End User along with bid.