

RFN00074 and RFW20106.

ANNEXURE - C TO TENDER BAP/FGD/2012/OT-3

**BONGAIGAON- 3X250 MW
FLUE GAS DESULFURIZATION SYSTEM**

**TECHNICAL SPECIFICATION FOR
MANUALLY OPERATED BALL
VALVES FOR PROCESS WATER
APPLICATION**

CUSTOMER : NATIONAL THERMAL POWER CORPORATION LIMITED



NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

BAP / FGD / 2012 / OT - 3



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

23

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

Prepared	Checked	Approved
<p>ASHWIN R</p> <p><i>R. Ashwin</i></p> <p>ENGINEER TRAINEE</p>	<p>MANOJ KUMAR THAKUR</p> <p><i>Manoj Kumar Thakur</i></p> <p>29/08/12</p> <p>ENGINEER-FGD</p>	<p>SASHI KUMAR</p> <p><i>Sashi Kumar</i></p> <p>Sr. ENGINEER-FGD</p>
R01 dated 29 08 12		



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

CONTENTS

1.0	PROJECT INFORMATION
2.0	INDENT OF SPECIFICATION
3.0	STANDARDS AND CODES
4.0	SPECIFICATION FOR DESIGN / CONSTRUCTION / MATERIAL PARTICULARS
5.0	MATERIAL OF CONSTRUCTION (BALL VALVES)
6.0	PROOF OF DESIGN TEST (TYPE TEST) FOR BALL VALVES
7.0	PAINTING OF VALVES
8.0	INSPECTION
9.0	GUARANTEE
10.0	DOCUMENTS AND DETAILS ALONG WITH BID
11.0	DOCUMENTS / SERVICE AFTER ORDER
12.0	DOCUMENTATION
13.0	ANNEXURE -1-LIST OF VALVES FOR PROCESS WATER APPLICATION WITH PROCESS PARAMETERS
14.0	ANNEXURE -2 –MANDATORY SPARE OF PROCESS WATER APPLICATION
15.0	ANNEXURE -3 –DATA SHEET FOR VALVES (TO BE FILLED BY THE VENDOR)
16.0	ANNEXURE - 4 - LIST OF DEVIATION
17.0	ANNEXURE -5 - PAINTING PROCEDURE

Signature
29/08/22



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

1.0	PROJECT INFORMATION	
	▪ Owner	NTPC
	▪ Buyer	BHEL, Ranipet
	▪ Process / application	Wet Lime Stone FGD system
1.1	SITE CONDITIONS	
	▪ Ambient temperature (Guarantee)	27 Deg C
	▪ Ambient temperature (Design)	50 Deg C
	▪ Height above sea level	47 m
	▪ Relative Humidity	60 %
1.2	LOCATION AND APPROACH	
	▪ Project location	
	▪ State	Assam
	▪ District	Kokrajhar
	▪ Place	Kumkuri near Salakati, Bongaigaon
	▪ Height above sea level	47 m

Signature
24/05/22



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

2.0 INTENT OF SPECIFICATION

- This specification together with the attendant Technical Data Sheet and other specifications/attachments to inquiry / order defines the minimum requirements for ball valves along with their accessories /auxiliaries for use in the process of Flue gas Desulphurization (FGD) system handling process water.
- Bidder shall make all possible efforts to comply strictly with the requirements of this specification and other specifications/attachments to inquiry/order.
- In case, deviations are considered essential by the Bidder (after exhausting all possible efforts), these shall be separately listed in the Bidder's proposal under separate section, titled as "List of Deviations/Exceptions to the Enquiry Document (Annexure-4)". Deviation shall be listed separately for each document with cross reference to Page No./Section/Clause No./Para etc. of the respective document supported with proper reasons for the deviation for purchaser's consideration. Any deviation, not listed under the above section, even if reflected in any other portion of the proposal, shall not be considered applicable. No deviation or exception shall be permitted without the written approval of the purchaser.
- The design, material, construction, manufacture, inspection, testing and performance of valves shall comply with all currently applicable statutes, regulations and safety codes in the locality where the valves will be installed. The valves shall conform to the latest editions of applicable codes and standards as mentioned elsewhere. Nothing in this specification shall be construed to relieve the Bidder of his responsibility. Compliance to this specification shall not relieve the Bidder of the responsibility of furnishing equipment and accessories/auxiliaries of proper design, materials and workmanship to meet the specified start up and operating conditions.
- In case the Bidder considers requirement of additional instrumentation, controls, safety devices and any other accessories/auxiliaries essential for safe and satisfactory operation of the equipment, he shall recommend the same along with reasons in a separate section along with his proposal and include the same in his scope of supply. The Bidder shall offer only proven design in successful operation.

3.0 STANDARDS AND CODES

The valves shall conform to the latest editions of applicable codes and standards as mentioned elsewhere. Valves in general shall conform to the requirements of the following standards:

- ANSI B 16.34 Standard for valves.

[Handwritten signature]
290812



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

- BS 5351 Specification for steel ball valves for the petroleum, petrochemical and allied industries
- ANSI-B-16.10 Valves face to face and other relevant dimension.
- API-598 Valves inspection test.

4.0 SPECIFICATION FOR DESIGN/CONSTRUCTION OF BALL VALVES

- 4.1. All valves shall be suitable for the service conditions i.e. flow, temperature and pressure at which they are required to operate.
- 4.2. The valves as well as all accessories shall be designed for easy disassembly and maintenance.
- 4.3. Valves to be installed outside shall be required to have the stem properly protected against atmospheric corrosion
- 4.4. The valves supplied shall be suitable for process water application
- 4.5. The valves shall be designed for the design pressure/temperature of the system on which it is installed and in accordance with AWWA-C-504, EN-593 or any other approved equivalent standard latest edition.
- 4.6. The seals, both on the body (sleeve) and on the ball shall be of the material specified. Necessary shaft seal shall be provided and adequately designed to ensure no leakage across the seal. This seal shall be designed so that they will allow replacement without removal of the valve shaft. The sealing ring on the disk shall be continuous type and easily replaceable.
- 4.7. For all types of valves, the design with shaft eccentric to the ball is preferred. The shaft shall be solid type and shall pivot on bushings. Bushings/sleeve type bearings shall be contained in the hub of valve body. The bearing shall be self-lubricated type with low coefficient of friction and should not have any harmful effect on water and on valve components.
- 4.8. The design of the shaft/stem shall be such that it will safely sustain maximum differential pressure across the closed valve. The shaft and any key (taper pin etc.) for transmitting the torque between shaft and ball shall be capable of withstanding the maximum torque required to operate the valve. However, the shaft diameter shall not be less than the minimum shaft diameter specified in relevant code. Necessary Torque Calculation and the torque class selected on the basis of the same shall be furnished to the Employer for information.
- 4.9. The ball shall rotate from the full open to the tight shut position. The ball shall be contoured to ensure the least possible resistance to flow and shall be suitable for throttling operation. While the ball is in the throttled position, valve shall not create any noise or vibration. The operating mechanism shall be mounted directly on or supported from the valve body.
- 4.10. All valves shall be complete with: position indicator (located in a visible place), arrow indicating the flow direction; adjustable mechanical stop limiting devices to prevent over travel of ball in open/close position; all valves shall be "tight shut off"

[Handwritten signature]
24/04/11 ✓



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

- 4.11. Hand operated valves shall have the following
- 4.11.1. Local hand controls
 - 4.11.2. The hand controls shall close the valve with clockwise rotation.
 - 4.11.3. The hand controls shall be dimensioned to guarantee an easy manoeuvre under most severe conditions.
 - 4.11.4. The hand controls shall be provided with locking systems suitable to avoid the ball assuming a non-desirable position during the operation.
- 4.12. Hand wheel shall be made of malleable iron with arms and rims of adequate strength. The hand wheel of diameters 300mm or less shall be provided with handles for ease of operation. The pulling force required on the hand wheel rim shall not exceed 25 Kgf when operating the valve under full flow and operating pressure.
- 4.13. Valves-350Nb and above shall have pressure equalizing bypass valves, wherever system parameters warrant the same.
- 4.14. All valves shall be provided with embossed name plate giving complete details such as tag number, type, size etc.

5.0 MATERIAL OF CONSTRUCTION (BALL VALVES)

Materials and other design details shall be as indicated below:

VALVE TYPE	2-WAY , BALL , FULL BORE , 3 PIECE DESIGN, FLOATING MOUNTING
VALVE SIZE & Quantity	AS PER ENCLOSED TABLE
BODY MATERIAL	CARBON STEEL A216 GR.WCB
BONNET TYPE & MATERIAL	Vendor to Specify
END CONNECTION	FLGD,ANSI B 16.34
RATING	Vendor to specify
BALL MATERIAL	SS 316
GLAND PACKING	GRAPHITE ASBE/ TEFLON
SEAT MATERIAL	PTFE / TEFLON
LEAKAGE CLASS	CLASS IV
MAX SOUND LEVEL	<80 dBA
STEM MATERIAL	SS 304

6.0 PROOF OF DESIGN TEST (TYPE TEST) FOR BALL VALVES

- 6.1. Proof of Design (P.O.D.) test certificates shall be furnished by the bidder for all applicable size-ranges and classes of Ball valves supplied by him, in the absence of which actual P.O.D. test shall be conducted by the bidder in the presence of Employer's representative.
- 6.2. All valves that are designed and manufactured as per AWWA-C-504 shall be governed by the relevant clauses of P.O.D test in AWWA-C-504. For Ball valves designed and manufactured to EN-593 or equivalent, the P.O.D. test methods and procedures shall generally follow the guidelines of AWWA-



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

C-504 in all respect except that Body & seat hydro test and ball-strength test shall be conducted at the pressures specified in EN-593 or the applicable code. Actuators shall also meet requirements of P.O.D. test of AWWA-C-504

7.0 PAINTING OF VALVES:

As per enclosed Annexure-5. Bidder to note that If during transport, unloading/unpacking or erection at site any part of the painted surface gets damaged, the same shall be made good by the contractor by repainting with compatible painting primer and enamel to the satisfaction of the project manager.

8.0 INSPECTION

Inspection shall be done at vendors works by BHEL as per the approved Quality Plan (QP) submitted by the vendor.

9.0 GUARANTEE:

Vendor to provide guarantee for a period of 12 months from the date of commissioning or 24 months from the date of supply whichever is earlier.

10.0 DOCUMENTS / DETAILS ALONG WITH BID

The following information / documents shall be submitted along with the offer

- a. Duly filled up data sheet for each valve type as per **Annexure-I** in the enclosed format.
- b. Detailed assembly drawing with overall dimensions.
- c. Valve cross sectional drawings with Bill of Material including the material specifications.
- d. Valve Regulation Characteristic Curve.
- e. Cv calculation.
- f. List of applicable standards for shop test.
- g. Reference list for the offered model.
- h. Typical Quality plan for supply of the above equipments.
- i. Valves Catalogues.
- j. List of commissioning spares.
- k. Recommended spares list for 3 year O&M along with item wise price.
- l. Any deviation shall be specifically mentioned in the enclosed deviation format **Annexure-II**.

In case of any deviation, the Bidder shall indicate the deviation, clause by clause in the deviation format attached in **Annexure-II**. If there is no deviation "NIL" statement shall be furnished. In the absence of **Annexure-II**, it will be construed that the bid confirms strictly to the specification. Acceptance or rejection of the offer with or without deviations (either fully or partially) is sole discretion of the

[Handwritten signature]
24.05.12



MANUALLY OPERATED BALL VALVES HANDLING PROCESS WATER

NTPC: BONG: FGD: WVALVES-BALL VALVE SPEC-028: REV-01

purchaser without seeking further clarification from the bidder.

NOTE: Bidders to note that failing to submit the above documents, the bid shall be considered as incomplete and liable for rejection.

11.0 DOCUMENTS / SERVICE AFTER ORDER

11.1. The following documents are to be submitted for BHEL's approval.

- Duly filled up data sheet in the enclosed format.
- Detailed assembly drawing with overall dimensions.
- Valve cross sectional drawings with Bill of Material including the material specifications.
- C_v Calculation
- Final Quality plan for approval

11.2. The following are to be submitted to BHEL's review and acceptance.

- Material test certificate
- Hydraulic & Leak test certificates
- Performance guarantee certificate
- Erection manual
- O&M manuals

12.0 DOCUMENTATION

- a. The documentation during bid and post order stage shall meet the following requirements.
- b. All documents and drawings shall be submitted in English.
- c. Hard copies of all documents and drawings during bid stage to be submitted in duplicate.
- d. Hard copies of all documents for approval to be submitted in triplicate.
- e. Hard copies of all final documents, drawings, manual etc., shall be submitted in bound folder in duplicate.
- f. Soft copies of all final documents in MS office in the form of CD-1 set.
- g. Soft copies of all final drawings in AutoCAD, latest version in the form of CD-1 set.

Sir
190812

DETAILS LIST OF VALVES WITH OPERATING PARAMETERS

Annexure - 1	
INDENT NO. RFW00074	
MATERIAL CODE : RFW 000710000	
Valve type	Ball Valve
Service	Isolation
Valve size	1 inch
Process Liquid	Process Water
Mode of Operation	Manually operated Ball Valves

Sl.No.	Valve / Instrument Tag No	Operating Conditions		Design Conditions		Material of Description			End Connection. FLD = Flanged Connection	Quantity
		Temp (°C)	Pressure (Kg/cm ²)	Temp. (°C)	Pressure (kgf/cm ²)	Body Material	Ball	Stem		
1.	10HTQ04AA005	50	98	100	100	A216 WCB	SS304	SS304	FLD	1
2.	10HTQ04AA006	50	98	100	100	A216 WCB	SS304	SS304	FLD	1
3.	20HTQ04AA005	50	98	100	100	A216 WCB	SS304	SS304	FLD	1
4.	20HTQ04AA006	50	98	100	100	A216 WCB	SS304	SS304	FLD	1
5.	30HTQ04AA005	50	98	100	100	A216 WCB	SS304	SS304	FLD	1
6.	30HTQ04AA006	50	98	100	100	A216 WCB	SS304	SS304	FLD	1

Sujit Biswas

DETAILS LIST OF MANDATORY VALVES WITH OPERATING PARAMETERS

ANNEXURE - 2 - MANDATORY SPARES	
INDENT NO. RFW20106	
MATERIAL CODE : RFW20106000	
Valve type	Ball Valve
Service	Isolation
Valve size	1 inch
Process Liquid	Process Water
Mode of Operation	Manually operated Ball Valves

Sl.No.	Valve / Instrument Tag No	Operating Conditions		Design Conditions		Material of Description			End Connection.	QTY of Valve
		Temp (°C)	Pressure (Kg/cm ²)	Temp. (°C)	Pressure (kgf/cm ²)	Body Material	Ball	Stem		
1	M1-BV-PW-MN-1	50	98	100	100	A216 WCB	SS304	SS304	FLD	1

Signature
29/08/12

ANNEXURE-3 DATA SHEET FOR VALVES

I. TECHNICAL PARAMETERS

- A. VALVE SIZE :
- a. Make :
- b. Model/ Type :
- c. Fluid details - Medium handled :
- +Temperature range ° C :
- d. Rated flow m³/Hr :
- e. Design Cv of the valve :
- f. Valve rating :
- g. Valve operation- (Lever/ Gear box) :
- h. Pressure Drop for rated flow bar(g) :
- i. Design pressure bar(g) :
- j. Hydraulic test pressure
- Body bar(g) :
- Seat bar(g) :
- k. Max. Shut off pressure bar(g) :

II. CONSTRUCTION DETAILS

- a. Material of construction - Body :
- (whatever applicable) - Ball :
- Stem :
- Disc :
- Seat :
- Bushing :
- Handle :
- Fasteners :
- b. End Connection / Rating / Standard :
- c. Recommended minimum pipe ID mm :
- d. Details of Gearbox if applicable :

III. GENERAL

- a. Weight per valve :
- b. Applicable standards :
- c. Valve GA Drawing / Cross Sectional Drg. :
- d. Enquiry / PO reference :

Sya
24/02/22

14

FORM FOR TECHNICAL DEVIATIONS (If any) ANNEXURE-4

ANNEXURE-4

Sl. No	Sec / clause no.	Specification	Statement of deviations/ variations	Reason for deviation	Cost of withdrawal

Date:

Signature & seal of the Bidder

[Handwritten Signature]
190812

PAINTING PROCEDURE**ANNEXURE - 5 PAINTING PROCEDURE**

Primer Coat		Intermediate Coat		Finish coat			Total DFT µm (min)
Paint	No of Coats /DFT	Paint	No of Coats	Paint	No. of Coats	Shade	
HB Chlorinated Rubber based Zinc Phosphate Primer DFT= 50 µm per coat (Solid by Volume min 60%)	2	--	--	Chlorinated Rubber Based Finish paint DFT= 30 µm per coat (Solid by Volume min 60%)	2	Gray shade to R9002	160

Signature
25/08/22