

ANNEXURE – I TO SPECIFICATION No. BA 89228

PROJECT: BHUSAWAL WET BALL MILL MATL. CODE: BA9789228007,Drg No: 36224500072-S00-R00

SL. NO	APPLICATION/ EQUIPMENT	DRG. NO/ ITEMNO	HOIST			HEAD ROOM MM	POWER SUPPLY		QTY	REMARKS
			CAPA. IN TONS	LIFT M	TRAVEL LENGTH M		DSL LEN. M	FIXED LEN. M		
1.0	TROLLEY WITH HOIST -01~		7.5	10.8	50 m outside hoist	Supplier to furnish			01	*, #
1.1	TROLLEY WITH HOIST --02~		7.5	10.8	40 m inside hoist	Supplier to furnish			01	*, #
1.2	DSL-01						50	15	01	Cable trolley type
1.3	DSL-02						40	15	01	Cable trolley type
2.0	HOIST MAINTENANCE PLATFORM								02	

The lift shown in the table is the minimum value. Depending upon head room of the hoist it may be altered upwards.

*ALL EQUIPMENTS ARE ELECTRICAL OPERATED.

**Vendor's scope starts from user's power supply point.

Two numbers of Hoist Maintenance Platforms shall be supplied one for each hoist.

Cable trolleys shall be made of metallic with self-lubricant bush type bearings for Smooth running.

Mono rail beams size and profile details are ISMB 500mm .

Prepared & Checked:		P V SRIHARI BABU, Manager./ PULV.ENG.
Approved	:	(AMANSERAPHIM SURIN), DGM/ PULV.ENG &TECH
		Rev. 00/Dt.25.02.2019