<u>ANNEXURE – I TO SPECIFICATION No. BA 89228</u>

PROJECT: BRBCL WET BALL MILL MATL. CODE: BA9789228066, Drg NO: 36224500075-S00-R00

			HOIST				POWER SUPPLY			
SL. NO	APPLICATION/ EQUIPMENT	DRG. NO/ ITEMNO	CAPA. IN TONS	LIFT M	TRAVEL LENGTH M	HEAD ROOM MM	DSL LEN. M	FIXED LEN. M	QTY	REMARKS
1.0	TROLLEY WITH HOIST -01~		10	11.8	60 m outside hoist	Supplier to furnish			01	*, #
1.1	TROLLEY WITH HOIST02~		10	11.8	50 m inside hoist	Supplier to furnish			01	*, #
1.2	DSL-01						60	15	01	Cable trolley type
1.3	DSL-02						50	15	01	Cable trolley type
2.0	HOIST MAINTENANCE PLATFORM								02	

The lift shown in the table is the minimum value. Depending upon head room of the hoist it may be altered upwards.

Two numbers of Hoist Maintenance Platforms shall be supplied one for each hoist.

^{*}ALL EQUIPMENTS ARE ELECTRICAL OPERATED.

^{**}Vendor's scope starts from user's power supply point.

Cable trolleys shall be made of metallic with self-lubricant bush type bearings for Smooth running.

Mono rail beams size and profile details are $\,$ ISMB 40 mm $\,$.

Prepared & Checked:		P V SRIHARI BABU, Manager./ PULV.ENGG.	
Approved	:	(AMANSERAPHIM SURIN), DGM/ PULV.ENGG &TECH	Rev. 00/Dt.25.02.2019