

**ANNEXURE – I TO SPECIFICATION No. BA 89228**

**PROJECT: NPGCL WET BALL MILL MATL. CODE: BA9789228074,Drg No36224500076-S00-R00**

SL. NO	APPLICATION/ EQUIPMENT	DRG. NO/ ITEMNO	HOIST			HEAD ROOM MM	POWER SUPPLY		QTY	REMARKS
			CAPA. IN TONS	LIFT M	TRAVEL LENGTH M		DSL LEN. M	FIXED LEN. M		
1.0	TROLLEY WITH HOIST -01~		15	13.8	110	Supplier to furnish			01	*, #
1.2	DSL-01						110	30	01	Cable trolley type
2.0	HOIST MAINTENANCE PLATFORM								01	

The lift shown in the table is the minimum value. Depending upon head room of the hoist it may be altered upwards.

\*ALL EQUIPMENTS ARE ELECTRICAL OPERATED.

\*\*Vendor's scope starts from user's power supply point.

**One numbers of Hoist Maintenance Platforms shall be supplied one for each hoist.**

**Cable trolleys shall be made of metallic with self-lubricant bush type bearings for Smooth running.  
Mono rail beams size and profile details are ISMB 450mm .**

<b>Prepared &amp; Checked:</b>	<b>P V SRIHARI BABU, Manager./ PULV.ENG.</b>
<b>Approved :</b>	<b>(AMANSERAPHIM SURIN ), DGM/ PULV.ENG &amp;TECH</b>
<b>Rev. 00/Dt.25.02.2019</b>	