

ADDENDUM-2

DATE: 23-02-2018

Mandatory spares of ESP Ash Handling System for 1 x 700 MW Bellary Unit 3 project

Tender Ref : 77/17/6215/ANA

1. Pre-bid Queries & clarifications have been uploaded on the website.
2. Any further addendum such issued carry part of the bidding documents and this will be available at the website from where the original documents have been received / downloaded by the bidder. Hence bidders are requested to visit the website <https://bheleps.buyjunction.in> on regular basis.

For Further Queries if any, Contact:

For Commercial :

Sh. Anand Aman
Dy. Manager / MM-1
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4134,
e-mail : ana@bhel.in

For Technical :

Sh. Rakesh Kumar
Sr. Engineer / PE / Mech
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4077,
e-mail : rsh@bhel.in

ENQUIRY NO. : 77/17/6215/ANA		
Mandatory spares of ESP Ash Handling System for 1 x 700 MW Bellary Unit 3 project		
Sl. No.	Bidders Query	BHEL Clarifications
1	B.1) Item Sl.No.A.1 : Diffuser Feeder Gate => Please inform whether your requirement is either supply of only the Gate Disc of the Diffuser Feeder 12" x 10" OR to supply the complete valve along with actuator but without limit switch & solenoid valve ? Please confirm. Please also indicate if you have considered top valve or bottom valve ? Please confirm.	Kindly provide 4 Nos. Top and 4 Nos. Bottom Valve with actuator.
2	B.2) Item Sl.No.C.1 : Fly Ash Diffuser Intake Valve => We have considered 12" x 6" Diffuser Feeder Valve to be supplied with actuator but without limit switch & solenoid valve. Please confirm.	Noted
3	B.3) Item Sl.No.C.2 : Fly Ash Intake Valve => We are considering 8" Fly Ash Intake Valve as per your drawing. Please confirm.	Noted. The valve shall be supplied with actuator.
4	C.0) Please confirm whether all NIT drawings & QAP to be submitted along with Tech Spec OR only Tech Spec after signing & stamping is to be uploaded ?	All NIT drawings & QAP to be submitted along with Tech Spec.