

PRE-BID CLARIFICATIONS-2 FOR LHP GHP: NTPC DADRI FGD

Enquiry No. : 77/18/6001/ANA dtd. 07.04.2018
Item : LHP and GHP for FGD Package
Project : NCTPP Dadri Stage - II (2 X 490 MW)

Sl.No.	Description	Bidder Query	BHEL ISG reply/comments/confirmation
A) Technical Queries			
1	Prebid clarifications for NCTPP Dadri (Technical) - refer sl. No. 13	Please refer sl. No. 13, wherein please note that free issue item spares shall not be in the scope of bidder	Spares for BHEL unit related items shall be respective BHEL unit scope
2		The commissioning of free issue item shall not be in the scope of bidder, as supplier shall have to be involved in commissioning specially for the item Battery, battery Charger, UPS & DCS.	Commissioning of free issue item shall be in bidders scope as per Electrical scope matrix R1 dated 08.05.18 attached.
3	B) Scope related to – Sr.no 33 - Vibration monitoring system	-	Electrical scope matrix has been revised and VMS is no longer a free supply item from BHEL.