

ADDENDUM-5

DATE: 10-11-2016

Passenger Elevator for common AHP Building for 1X500 MW BOKARO TPS A

Tender Ref : 77/16/6181/ANA Dtd. 07.09.2016

1. Bidder's Queries & BHEL clarifications are as follows :

Sl. No.	Bidder's Query	BHEL's Reply
1.	With refer to the subject tender and technical specification there is a requirement of 8 Pass 544Kg Elevator but the available shaft size is too big for 8 Pass Elevator the available shaft as per tender drawing is 3000mm (W) X 2500mm(D) and to install a 8 pass Elevator shaft has to be reduced by using channel separator which has to be done by M/s BHEL or alternatively we will increase the capacity of the Elevator as per available shaft the price will be higher than that of 8 pass Elevator.	BHEL requires 8 passenger elevator only, if space provided is exceeding standard size (that is sufficient) for 8 passenger elevator, bidder has to take care of extra arrangements need to done and same shall be done by bidder only. Bidder has to submit the offer taking care of other BHEL requirements as per technical enquiry documents.

2. Any further addendum such issued carry part of the bidding documents and this will be available at the website from where the original documents have been received / downloaded by the bidder. Hence bidders are requested to visit the website <https://bheleps.buyjunction.in> on regular basis.

For Further Queries if any, Contact:

For Commercial :

Sh. Anand Aman

Sr. Engineer, Purchase/Works-1
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4134,
e-mail : ana@bhelisg.com

For Technical :

Sh. Amit Gupta

Manager/ PE/ Mech
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4282,
e-mail : amit@bhelisg.com