

ADDENDUM-8

DATE: 23-05-2019

CHP/LHP/GHP Package for 1X660 MW Panki Thermal Power Station

Tender Ref : 77/19/6003/ANA

1. Pre-bid Queries & BHEL clarifications have been uploaded in the website <https://bhel.abcpurchase.com>
2. Any further addendum such issued carry part of the bidding documents and this will be available at the website from where the original documents have been received / downloaded by the bidder. Hence bidders are requested to visit the website <https://bhel.abcpurchase.com> on regular basis.

For Further Queries if any, Contact:

For Commercial :

Sh. Anand Aman
Dy. Manager / MM
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4134,
e-mail : ana@bhel.in

For Technical :

Sh. Lovekush Verma
Engineer / Engg (Mech.)
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080-2218 4063,
e-mail : lkv@bhel.in

ENQUIRY NO. : 77/19/6003/ANA dtd. 17.04.2019
CHP/LHP/GHP PACKAGE FOR 1X660 MW PANKI THERMAL POWER STATION

Sl.No.	Bid document	Page	Clause	Description as per NIT	Bidder's query /comment	BHEL Rpely datd: 18.05.2019	Bidder's query /comment on 20.05.2019
4. (As per Addendum-6, Dtd-18.05.219)	Volume III : Mechanical Works	94 of 116	M-26, 2.3	DFDSS # 1 shall cover discharge & receipt points of underground equipment / conveyors in Tippler complex # WTC-1. [Pump House # PMH-1] ii) DFDSS #2 shall cover discharge & receipts of equipment / conveyors in ERHC-1 [Pump House # PMH-2] iii) DFDSS #3 shall cover discharge & receipts of equipment / conveyors in bldg# CRH-1/ JT-6/JT-7/ JT-8/JT-9/JT-10 & discharge points of Tripper Conveyors. [Pump House # PMH-3] iv) DFDSS #4 shall cover discharge & receipts of equipment / conveyors in JT- 1/2/2A/3/3A/4/5 [Pump House # PMH-4]	As per the tender requirement, Four (4) no, of DFDS system has to be considered. Plant Layout says two no. of pumps for entire CHP/LHP/GHP. Specification is not clear, whether we need to follow four no. of DFDS system as per technical document or two no. of DFFDS system for CHP area. Please clarify	As per layout only two pump house is envisaged to cater all pump for dust suppression for CHP/LHP/GHP.	Noted & confirmed for two pump house for dust suppression & other water system for CHP/LHP/GHP system.