

Enquiry No.: 77/19/6099/SK

Tender Description : Design manufacturing, testing and supply of Instrumentation Cables for CHP VMAS System for 2X660 MW Suratgarh SCTPS, Stage-V, Unit-7&8

| SI No | Vendor's Query                                                                                                                                                                                                                                                                                                                                                                                                                                          | BHEL Clarifications                                                                                                                                                                                                                                                                                           |
|-------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1.    | <p>We have received <b>three</b> specification along with this tender</p> <p>1 – Tech Spec No : RRVUNL / ELEC /197 Date of issue 11-09-2019 (Sheet 1 to 8)</p> <p>2 - Annexure – 1 Typical Technical Particulars of Instrumentation Cables (Page 5 to 8)</p> <p>3 - Doc. No. PE-DC-392-507-E002 REV. No. 07 Date – 16.08.2014 (Sheet 44 to 47)</p> <p>All specification are contradictory to each other , Kindly clarify which specification follow</p> | <p>For Technical specifications, please follow the 'Annexure – 1 Typical Technical Particulars of Instrumentation Cables', however conductor size will be 0.75 Sq.mm and Drain wire size will be 0.5 Sq.mm. Further, Drum lengths will be 24X1000 &amp; 2X500 Mtrs and tolerance will be as per contract.</p> |

For further clarifications please refer the following:

|                                                                                                                                                                            |                                                                                                                                                                                           |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>For Commercial Queries:<br/> Sushil Kumar- Dy. Manager/ MM<br/> E-Mail: <a href="mailto:kumarsushil@bhel.in">kumarsushil@bhel.in</a><br/> Ph. No. +91-080-2218 4567</p> | <p>For Technical Queries:<br/> Venkateshwar Rao Vangla- Dy. Manager / Engineering (Elec)<br/> E-Mail: <a href="mailto:vraov@bhel.in">vraov@bhel.in</a><br/> Ph. No. +91-080-2218 4077</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|