

Enquiry No.: 77/19/6100/SK

Tender Description : Design manufacturing, testing and supply of LT Power and Control Cables for Conveyor Package for 2X660 MW Suratgarh SCTPS, Stage-V, Unit-7&8

SI No	Vendor's Query	BHEL Clarifications
1	Specification for Anti-Fungal test & required rating (0, 1, 2, 3 & 4) for this test.	The Outer sheath shall be resistant to fungus and rating shall be '0'.
2	For Anti-Fungal test, we are providing test certificate from third party not older than one year.	Bidder to follow Specifications.
3	Type test conducted on each type of cable instead of each size as mentioned in ANNEXURE-2 due to small quantity of cable.	Bidder to follow Specifications.
4	Flammability test as per IS:10810 (P-62) Cat-A & IEEE-383 not conducted due to small quantity of cable.	Bidder to follow Specifications.
5	UV Test Certificate shall be provided as per ASTM G-154/BS EN ISO-4892-2 not older than one year for CPRI/ERDA/NABL Lab due to small quantity of cable.	Bidder to follow Specifications.

For further clarifications please refer the following:

For Commercial Queries: Sushil Kumar- Dy. Manager/ MM E-Mail: kumarsushil@bhel.in Ph. No. +91-080-2218 4567	For Technical Queries: Venkateshwar Rao Vangla- Dy. Manager / Engineering (Elec) E-Mail: vraov@bhel.in Ph. No. +91-080-2218 4077
---	---