

ADDENDUM TO BHEL SPEC ST 46056 REV-03

Item: DUPLEX FILTER (L.O) AS PER VAR 06 OF SPEC ST 46056

Project: DOLVI JSW (1x250 MW)

GeM Enquiry: GEM/2025/B/6529982 dt 04.08.2025

REFER TO ANNEX-1 AT PAGE NO. 05 OF 07: DIFFERENTIAL PRESSURE TRANSMITTER IS REQUIRED INSTEAD OF DP SWITCH.

SPECIFICATION OF DIFFERENTIAL PRESSURE TRANSMITTER:

1. RANGE: 0-2 BAR
2. ACCURACY: 0.5%
3. STABILITY: + & -0.25% FOR 10 YEARS
4. Any other accessories - Mounting bracket, adapter/fittings, connecting tubing & valve etc. (compatible with process connection of Filter) required for transmitter mounting, to be supplied along with transmitter
5. KKS TAG FOR BOTH DPT (EACH BASKET) SHALL BE MAV42CP013 & MAV42CP015

Deepak Goyal.
Sr. Mgr/CE
07/08/2025
(Approved By)

(Vendor Sign)