

**TSGENCO MANUGURU NATURAL DRAFT COOLING TOWER ENQUIRY**  
**TECHNICAL ADDENDUM -2**

**TECHNICAL SPECIFICATION NO.: PE-TS-411-165-N001 (REV.0)**

- 1) Clause # 5.4 – Section D1 (Datasheet A): External Walkway platform: With reference to the external walkway platform as stated in the technical specification, bidder may alternatively provide an equivalent walkway arrangement viz. at the top of the shell by thickening the shell wall upto 1200 mm width.
- 2) Clause # 2.01.01 (i) – Section C1, Specific technical requirement : Scope of Mechanical works: Bidder may alternatively offer Hot water manifold piping at TP with Edge prepared suitable for butt welding (instead at Flanged piping).
- 3) Clause # 1 & 8.8 of Section D1 (Datasheet A) & Cl. no. 6.04 of Section C: Type of fills : Bidder can alternatively offer PP Splash grid as against the Splash V Bar fills for the Manuguru Cooling Tower.