

PROJECT - GSECL,2 X 250 MW SIKKATPP UNIT # 3 & 4

ITEM - SUPPLY OF ASH SLURRY PUMPS

ENQUIRY NO:- 77/11/6283/RSB

1. The slurry concentration by weight ((i.e. Weight of Ash / (weight of Ash + Weight of Water)) shall be:
 - i) upto 25 % in case of only bottom ash slurry, and
 - ii) upto 35% in case of fly ash slurry
 - iii) upto 28% in case of combined bottom ash and fly ash slurry
2. Slurry Density to be handled by slurry pumps: approximately 1.2 T/ M³ .
3. Clinker / ash particle size to be handled by the slurry pump: upto 25 mm.