

ADDENDUM-7

DATE: 25-05-2011

Pre tender tie up for Selection of Associate Vendor for CHP conveyor package for Nabinagar STPP (3X660 MW) – Aurangabad (Bihar).

Tender Ref: IS-1-11-E-2000/CONV

1. Clarifications for pre-bid queries enclosed.
The earlier set of replies to the pre-bid queries as mentioned in Addendum – 6, point No.1 & 2 is superseded by Addendum – 7.
2. **Any further addendum such issued carry part of the bidding documents and this will be available at the web site from where the original documents have been received / downloaded by the bidder. Hence bidders are requested to visit the web site on regular basis.**

For Further Queries if any, Contact:

Sh. M.V.Gautam

DGM / BG-1A (MM)

BHEL-ISG,

Prof.C.N.R.RAO CIRCLE, MALLESWARAM,

BANGALORE-560 012

Off: 080 2218 4087; E.MAIL: mvg@bhelisg.com

**NABINAGAR SUPER THERMAL POWER PROJECT STAGE II (3 x 660 MW) PRE BID
QUERIES AND REPLIES FOR CHP CONVEYOR PACKAGE**

SL.NO	CONVEYOR PACKAFGE VENDOR'S QUERIES	BHEL'S REPLY
1	Kindly confirm if the erection and commissioning of machines package (excluding SCR) is there in the scope.	Yes, Erection and commissioning of machines is in conveyor package vendor's scope as per scope matrix
2	Calculation shall be based on CEMA and also IS11592 .Please confirm which one to be considered.	Please refer clause no.1.02.08, page 2 of 16, SUB-SECTION 3A,PART-B of NTPC tender specifications
3.	Kindly reconfirm the scope of work for Seal plate	Seal plate is included in CHP civil and structural scope.
4.	Kindly reconfirm the scope of work for hoppers	Hoppers other than track hopper, wagon tippler hopper, emergency reclaim hopper, if applicable shall be in conveyor package scope
5.	Kindly confirm if the Effluent treatment plant is there in the scope	Any effluent treatment, if applicable ,as per NTPC tender specifications shall be included.
6.	Kindly reconfirm the scope of work for motors.	LT and HT Motors for conveyor drives only is in BHEL scope.
7.	Kindly reconfirm if the belt vulcanizing is there in the vendor's scope	Supply for Belt vulcanizing machine is in BHEL scope as per Scope matrix, Refer Note 2...
8.	Kindly confirm the material for counter weights. Cast Iron or RCC	Vendor can quote for either RCC or Cast iron as material of construction for counter weights.
9.	Kindly confirm if scope involves only pressure ventilation system or all type of ventilation system namely pressure, tunnel and bunker ventilation system	All ventilation systems as per NTPC tender specifications to be considered.
10	Kindly confirm the detailed scope for electrical scope of work	Following electricals are in conveyor package vendor's scope 1. Complete electricals for ILMS, Belt scale, Hoists and cranes, Elevators, DE, Ventilation, Air conditioning, Vibrating Feeder, including motors, panels and cables etc. 2. Motors, JB's for Flap gates , RPG etc are in vendor scope BHEL will provide only Power Supply. 3. From Field instruments to Field Junction Box(including JB) for all switches.