

ADDENDUM OF HE570161. MATERIAL OF CONSTRUCTION : (FOR SEA WATER APPLICATION)

In Clause No 4.0 B-2 , add "All pipings, valves & Instruments coming in contact with sea water shall be SS 316L".

## 2. VENDOR TO SUPPLY HEAVY-DUTY, SELF-UNDERCUTTING ANCHOR BOLTS (FOUNDATION BOLTS) ALONG WITH VACUUM PUMP PACKAGE. NO POCKETS SHALL BE PROVIDED IN CONCRETE FOUNDATION FOR ANCHOR BOLTS.