

	INDUSTRIAL SYSTEMS GROUP (Purchase/Works-1) RFQ No. 77/16/6276/RCD	SPECIAL CONDITIONS OF CONTRACT (SCC) Revision No. 00	2X800 MW Telangana Super Thermal Power Project-Karimnagar Conveyor Main Package
---	--	--	---

Clause no. 20 and 24 of Special Conditions of Contract shall be read as follows:

Clause no.20	Taxes & Duties	Bidder to note that the Custom Duty benefits is available under Chapter 98.01 of the Customs Tariff Act for import of goods, which are required for incorporation in the facilities under the Contract. The BHEL / NTPC shall issue the required Certificate, as per relevant policies of the Govt. of India, to facilitate the bidders to avail any such benefit under the Contract. For issuance of such Certificate by the BHEL / NTPC, the bidders shall be required to indicate the import content included in their price bid. The bidders shall themselves be solely responsible for availing the above benefits, which they have considered in their bid. In case of failure of the bidders to receive the benefits partly or fully from the Govt. of India and/or in case of any delay in receipt of such benefits and/or withdrawal of such benefits by the Govt. of India, the BHEL / NTPC shall neither be liable nor responsible in any manner whatsoever. For foreign suppliers, the customs duty shall be paid on merit. All bidders to note that being a PI project, Excise Duty is applicable. Vendor shall quote ED separately in price bid at applicable rate and ED will be reimbursed to vendor by BHEL. For main supply and commissioning / mandatory spares, consideration of Quoted ED in evaluation shall be intimated during techno-commercial evaluation of the bids. Vendor shall quote CST / VAT (whichever applicable) separately in the price bid and CST / VAT shall be reimbursed to vendor by BHEL. For main supply and commissioning / mandatory spares, consideration of Quoted CST / VAT in evaluation shall be intimated during techno-commercial evaluation of the bids. Concessional Sales Tax against issuance and exchange of form 'C' & 'E1/E2' / VAT, as applicable, are to be quoted by the bidder in their offer. VAT for Intra-state dispatch shall be paid subject to conditions specified in Annexure I. VAT returns to be submitted by vendor as and when required by BHEL. Anti-dumping duty, if any, shall be in the account of bidder and shall be included in their price. No separate payment shall be made by BHEL for the same. Entry tax : If any, shall be payable by ultimate customer (NTPC) directly to tax authority. Hence the same should not be considered in the offer.
---------------------	----------------------------------	--

	INDUSTRIAL SYSTEMS GROUP (Purchase/Works-1) RFQ No. 77/16/6276/RCD	SPECIAL CONDITIONS OF CONTRACT (SCC) Revision No. 00	2X800 MW Telangana Super Thermal Power Project-Karimnagar Conveyor Main Package
---	--	--	---

Clause no.24	Evaluation criteria	a) Tenders will be evaluated on the basis of delivered cost, i.e. total cost to the Purchaser, taking into consideration loadings, if any, and all available financial advantages, including those available from Owner, taxation authorities etc. However, consideration of quoted ED / CVD and CST/VAT/SAD shall be intimated during techno commercial evaluation of bids. b) Though foreign bidders are required to quote CFR prices, Price evaluation and comparison will be made on the basis of Free Delivery at the Project site. c) For evaluation, exchange rate (TT selling rate of State Bank of India) as on scheduled date of tender opening (Part-I bid in case of two part bid) shall be considered. d) In case of foreign bidders, the quoted CFR price shall be loaded by following factors to arrive at total FOR Site price, in case not quoted by the bidder: d.1) Insurance – @ 0.082% of FOB value d.2) Port handling/clearing charges : @ 1% of CIF value (CFR + loading as per d.1) d.3) Custom Duties (including CVD @ 12.5% & SAD @5 %) at Indian port : 29.44 % of (CIF value + Port handling/clearing charges). d.4) Inland freight – @ 2% of CIF value (CFR + loading as per d.1)
-------------------------	-----------------------------------	---

Conveyor package - Queries & replies - 2x800MW, Telangana (Karimnagar) project.			
S.No.	Reference Clause	Bidder's Queries	BHEL Replies, Dtd: 31/01/17
1	Enquiry No.: 77 / 16 / 6276 / RCD	Please inform the pressure at which the water & air headers are provided by NTPC/BHEL for dust suppression / service water/ cold water/ drinking water systems and their exact location (i.e. at what elevation / floor provided).	Bidder to refer NTPC technical specifications section-VI/Part-A/sub-section-III, for terminal points for all water applications. However, pressure will be provided during detail engineering. Also, bidder to note that, air headers will not be provided by BHEL/NTPC and it shall be in bidders scope.
2		Trippers should be provided with Cable reeling drums or with Festoon arrangement as the travel is not much.	Trippers should be provided with Festoon arrangement.
3		We would need the plan drawing & elevation drawing with details at the bunker shed to enable us to work out the exact ventilation BOQ.	Elevation drg. shall be as per conveyor profile already provided to bidders. However, plan drg. will be furnished during detail engineering.
4		The location of pump house with details is not clear in the plot plan available nor its routing. Confirm distance.	Bidder to refer the main equipment plan layout provided along tender documents. i.e., Annex-4/technical specifications.
5		As per your calculation itself, motor ratings are 350Kw for conv. 40A/B, 375Kw for conv. 41A/B and 300Kw for 42A/B & 43A/B and accordingly the limiting Bkw power consumption as per your Annexure A would be more than 300Kw excluding tripper Kws with duty factor of 0.5. Please clarify and advise.	It is auxiliary power consumption at rated capacity with 0.5 duty factor. Checked & found ok. Bidder to follow specifications.
6		We have noted that construction of toilets & pump houses not in scope.	Noted.
7		We assume that the HT cables/ power cables / control cables upto MCC/ Control stations are excluded from our scope except for the cables from the termination point/ junction point at Bunker floor / Transfer tower provided by BHEL. Please confirm.	As per NIT terms.
8		We assume the lighting is excluded from our scope.	Noted.
9		-	Latest GA of Bunker feeding conveyors (i.e, applicable for all respective units.) is enclosed for bidders reference.