

TD-201 Rev No. 00	Form No.	 HYDERABAD	PRODUCT STANDARD PROJECT ENGINEERING & SYSTEMS DIVISION HYDERABAD		Amendment -1 to PY51285 Rev No. 00 Page 1 of 2	
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.		<u>AMENDMENT -1 TO TECHNICAL SPECIFICATION FOR INERT GAS EXTINGUISHING SYSTEM</u> <u>(SPEC NO PY 51285 Rev 00)</u>				
		Ref Cl.No	Present Description	Revised Description		
		7.13	Mandatory Spares	Mandatory spares are not applicable for this project		
		--	--	The dimensions of the cylinder room is 10m x 7m which is already finalized and cannot be changed now. Bidder to select the system (as per NFPA-2001 guidelines) to which while meeting the intended requirement as per the specification and shall be properly housed in the inert gas cylinder room. Adequate space for Operation & Maintenance of cylinder shall also be considered while selecting the inert gas system. Location of cylinder room marked in the Annexure-19. However, bidder is requested to consider a pipe distance of min.100 mtrs up to the entry of the inert gas protected zone.		
		--	--	Rubber mats shall be provided at the bottom of each cylinder.		
				Seamless pipes of SCH 160 for manifold and SCH 80 for branch network design shall be considered by bidder.		
Ref. Doc	Revisions : Refer to record of revisions :		Prepared : RTJ	Checked : DVPK	Approved : PCS	Date : 28.09.17

[illegible]

