

**PRE QUALIFICATION CRITERIA FOR THE BIDDERS FOR OPEN TENDER ENQUIRY FOR SUPPLY & ETC OF 400 KV
XLPE CABLE WITH NECESSARY AUXILIARY EQUIPMENT FOR 750 MW PRAGATI CCPP AT BAMNALI**

Sl.N o.	P. Q. Criteria	Requirements	Documents Required
01	Technical Capabilities with respect to personnel, equipment and manufacturing & testing facilities in supplier's works.	The vendors are required to establish about their technical capability in manufacturing of such Cable and/or joints and terminations.	The Bidder shall furnish the Test Reports of the Pre qualification Tests as well as Type Test reports of similar cable system (cable system consists of cable, straight through joint boxes and end termination) as per IEC 62067 from accredited laboratory (accredited by the national accreditation body of country where laboratory is located). The alternative long term test/ demonstration of satisfactory service experience as per note to clause 13.2 of IEC 62067 shall not be considered for this purpose. <i>In case type test reports are more than 5 years old or the reports of type tests are found to be technically unacceptable, the type test shall be conducted by the vendor without cost and delivery implication to BHEL.</i>
02	Experience	Bidder shall have designed, manufactured; type tested & supplied 400 kV cables and accessories of similar type and rating which should be in successful continuous operation for at least 2 years in last 10 years.	The performance certificate to satisfy the above qualification criteria shall be submitted along with the bid.
03	Foreign Vendors	The order shall be placed on original manufacturer however they can execute the order through their Indian associates. In this case the order shall be placed on OEM & supply as well as guarantee of material shall be given by the OEM	The bidders should furnish under taking in compliance of this clause and declare the names of their Indian associates.