

Date -10.11.2017

**AMENDMENT OF TECHNICAL SPECIFICATION OF 400kV ISOLATORS FOR
ARIYALUR PROJECT**

DOCUMENT No. TB-394-316-110, Rev. No.-00

Section -1, Cl. No. 1.5 (Type testing) should be read as mentioned below

“Bidder shall submit valid type test reports (As per relevant IEC/IS standard) for the tests carried out **within last ten years from the date of opening of the tender** (i.e. 30.09.2016). The reports should have been conducted on identical or similar equipment/components to those offered. In case type test reports are more than 10 years old (from the date of opening of the tender **i.e. 30.09.2016**) or the reports of type tests are found to be technically unacceptable , the type test shall be conducted by the vendor without cost and delivery implication to BHEL. The type test if conducted shall be witnessed by BHEL/Customer”.

Sarav Kumar
10/11/17