

**TSGENCO BHADRADRI NATURAL DRAFT COOLING TOWER ENQUIRY**

**TECHNICAL AMENDMENT -5**

**TECHNICAL SPECIFICATION NO.: PE-TS-411-165-N001 (REV.0)**

**Section C3 (CIVIL)**

1. The clause no. 9.02.03, 9.02.05 and 9.01.06 mentioned wherever stands amended as clause no. 3.02.03, 3.02.05 and 3.01.06 respectively.
2. Refer clause no. 3.02.08:  
Additional Point to be considered: For structural design of water distribution system pressure level to be considered shall not be less than 1.5 times the design pressure.