

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

पावर सेक्टर – पच्छिम क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 – किंग्सवे
नागपुर – 440 001



Bharat Heavy Electricals Limited

Power Sector – Western Region
Shreemohini Complex, 345 – Kingsway
Nagpur – 440 001

फॅक्स / FAX: 0712 – 3048605 वेब साईट / WEB SITE: www.bhelpswr.co.in

Ref: BHE/PW/PUR/PIPVG-BULD/758/AMD-01 (Page-1/2) Dated: 30/08/2010

To,

ALL BIDDERS

Dear Sir,

SUB : AMENDMENT – 01- REG

NAME OF WORK: CONSTRUCTION OF CIVIL, ARCHITECTURAL AND STRUCTURAL WORKS FOR CONTROL & FACILITY BUILDING, DM CWST, CSWPH, OH TANK, ELECTROCHLORINATION PLANT, ETP, STP, ROAD AND DRAINS, CULVERTS, WORKSHOP, STORES, CW PIPING AND PIPE & CABLE RACK WORKS ETC (ALL WITHDRAWN FROM SCOPE OF OTHER AGENCY) AT 2X350MW CCPP, GPPCL, PIPAVAV, GUJARAT. **TENDER SPECIFICATION No: BHE / PW / PUR / PIPVG-BULD / 758**

Bidder may refer “ **Volume-II – Price Bid -758**” issued against this tender. In BOQ of this price bid, the existing item no 205 & 1812 has been amended as below as 205 (R) & 1812 (R).

ST. NO	Description of Items	Unit	Qty.	Rate in Fig. in Rs	Rate in word	Amount
205 (R)	Concrete of grade M-30 conforming to IS:456 with coarse sand and graded hard stone aggregate 20mm nominal size in foundations/substructure, grade slab, paving, drains, under floors etc at any level below finished floor level, any shape, position or thickness etc complete including use of plasticizer/ super plasticizer conforming to IS:9103 (latest) to achieve required slump in concrete all complete using of 43/53 grade Sulphate Resisting Cement conforming to relevant IS Code.	CUM	8000			
1812 (R)	Design, supply, fabrication, installation of truly leveled and aligned 600mm high cavity flooring comprising of 35mm thick Nova teak or approved equivalent make super particle board of size 610mm x 610mm floor panels having 2mm thick anti-static PVC sheet on top, 2mm thick hard PVC strip lipping on edges and 26G aluminum sheet fixed with araldite on underside including cutting of panels where required for cables etc with supporting system comprising of 25mm diameter galvanized MS threaded rod and pressure die cast zinc aluminum alloy adjustable head attachment at top and welded to 100mmx100mmx8mm base plate, pedestal fixed to floor by means of expansion fasteners to existing floor at a distance of 610mm center to center both ways etc all complete as per specification and as directed by Engineer.	SQM	500			

SUB : AMENDMENT – 01- REG

The above amendment shall be a part of this tender specification. As such bidders are requested to quote the rate for amended item no 205 (R) & 1812 (R). The existing item no 205 & 1812 of price bid-Vol-II shall be null & void.

Bidders may please download these documents from web and enclose print out without quoting prices of same with technical bid duly counter signed by your authorized signatory and stamped with official seal as a token of your unqualified acceptance of this amendment.

Bidder shall quote rate for amended item no 205 (R) & 1812 (R) and submit the same with Volume-II – Price Bid -758 . The total price all items shall be considered including these amended item 205 (R) & 1812 (R).

Clarifaction-01 – Refer Part-C Reinforced Concrete Structure & Foundation- Cl no -8.9 page 971/ 1036 – It is clarified that The reinforcement supplied by BHEL free of cost is HCR- M (High Corrosion Resistant Marine) grade which is replacement of Fusion bonded epoxy coated steel. Bidder has nothing to do this and they have to quote the rate for cutting, bending & fixing including delivery of material from BHEL store.

All other terms & condition of the tender specification shall remain unchanged unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully

DY. GENERAL. MANAGER (PURCHASE)