



365 - 148

**PRODUCT ENGINEERING / V&SB
PURCHASE SPECIFICATION FOR
CABLE GLANDS**

**SPEC:SB:0012
PAGE 01 OF 01**

**REV:04
13.09.14**

1.0 Component : Double compression cable glands

2.0 :

Type	Material codes	Material	Size
(i)	963535180000	Brass body nickel plated	Suitable for 3C X 2.5 mm ² armoured Cable of OD 14.5 mm with nipple entry Size of M20 x 1.5. Ferrule suitable for armoured wire diameter 0.8mm.
(ii)	963535180100		Suitable for 3C X 6 mm ² armoured Cable of OD 20 mm with nipple entry Size of M20 x 1.5. Ferrule suitable for armoured wire diameter 0.8mm.
(iii)	963535180200		Suitable for 3C X 2.5 mm ² unarmoured Cable 11 +0.65 /-0.40 mm with nipple entry Size of M20 x 1.5. Ferrule suitable for unarmoured wire diameter 0.8mm.

3.0 Area classification : Non flame proof

4.0 Document required for acceptance : Compliance certificate.

5.0 Packing : Suitably packed to avoid thread damages.

6.0 Critical check list :
1. Compliance certificate
2. Thread size
3. Cable entry size

REV: 04

For material Code 963531580200 cable OD included.

PREPARED
(J. SANKAR)

CHECKED
(S.K.GUPTA)

APPROVED
(HIRENDRA RAUT)