

Sr. No	Description	Supporting Document to be attached	Reference No. of supporting documents																
B)	Cl. No. 3.1 (ii) of Section-1 of TS																		
01	765kV Current Transformers from the manufacturer, who have established manufacturing and testing facilities in India for the offered equipment and not meeting the requirement stipulated in Cl.3.1 (i) of Section-1, can also be considered provided that 715kV or higher Voltage class Current Transformer(s) must have been manufactured in the above Indian works & type tested (as per IEC/IS standard) and supplied.	a) Bidder to provide confirmation of fulfilling Technical Requirements mentioned in Cl. No. 3.1 (ii) of Section-1 of TS. b) Purchase Orders The details are to be submitted in following format, <table><thead><tr><th>Sr. No</th><th>ITEMS SUPPLIED TO</th><th>ORDER REFERENCE No. & DATE</th><th>ITEMS</th><th>QUANTITY</th><th>ORDER FULLY EXECUTED. YES/NO</th><th>STATUS, IF ORDER UNDER EXECUTION</th><th>REMARK</th></tr></thead><tbody><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></tbody></table> c) Dispatch Instructions/ Material Receipt at site certificate/ Lorry Receipt details etc d) Type Test Certificates	Sr. No	ITEMS SUPPLIED TO	ORDER REFERENCE No. & DATE	ITEMS	QUANTITY	ORDER FULLY EXECUTED. YES/NO	STATUS, IF ORDER UNDER EXECUTION	REMARK									a) b) c) d)
Sr. No	ITEMS SUPPLIED TO	ORDER REFERENCE No. & DATE	ITEMS	QUANTITY	ORDER FULLY EXECUTED. YES/NO	STATUS, IF ORDER UNDER EXECUTION	REMARK												
02	The manufacturer shall furnish performance guarantee for an amount of 10% of the ex-works cost of the Current Transformers and this performance guarantee shall be in addition to the contract performance guarantee to be submitted by the manufacturer.	e) Manufacturer's confirmation regarding submission of the additional performance guarantee, if applicable.	e)																

Note: 1) Satisfactory operation means certificate issued by the customer/end user certifying the operation without any adverse remarks.

2) Bidder to meet both B) 01 & B) 02 above to qualify against Sr. No.3.1 (ii) of Section-1 of TS

[Signature]
12/12/12

[Signature]

TECHNICAL REQUIREMENT OF PQR

Name of Project:- 765/400KV Jeerat & Medinipur Substation

Name Of Item :- 765KV Current Transformer

Sr. No	Description	Supporting Document to be attached	Reference No. of supporting documents																
A)	Cl. No. 3.1 (i) of Section-1 of TS																		
01	The manufacturer(s) whose 765kV Current Transformer(s) are offered, must have manufactured, type tested (as per IEC/IS or equivalent standard) and supplied 715kV or higher voltage class Current Transformer(s).	a) Bidder to provide confirmation of fulfilling Technical Requirements mentioned in Cl. No. 3.1 (i) of Section-1 of TS. b) Purchase Orders The details are to be submitted in following format, <table><tr><th>Sr. No</th><th>ITEMS SUPPLIED TO</th><th>ORDER REFERENCE No. & DATE</th><th>ITEMS</th><th>QUANTITY</th><th>ORDER FULLY EXECUTED. YES/NO</th><th>STATUS, IF ORDER UNDER EXECUTION</th><th>REMARK</th></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></table>	Sr. No	ITEMS SUPPLIED TO	ORDER REFERENCE No. & DATE	ITEMS	QUANTITY	ORDER FULLY EXECUTED. YES/NO	STATUS, IF ORDER UNDER EXECUTION	REMARK									a) b)
Sr. No	ITEMS SUPPLIED TO	ORDER REFERENCE No. & DATE	ITEMS	QUANTITY	ORDER FULLY EXECUTED. YES/NO	STATUS, IF ORDER UNDER EXECUTION	REMARK												
02	The 765kV Current Transformers should be in satisfactory operation for at least two (2) years as on 23.11.2016.(original scheduled date of bid opening)	e) Letter/ Certificate/ MOM from customer/ end user for satisfactory operation	e)																

Note: 1) Satisfactory operation means certificate issued by the Employer/ Utility certifying the operation without any adverse remark

2) Bidder to meet both A) 01 & A) 02 above to qualify against Sr. No.3.1 (i) of Section-1 of TS