

**Pre-Qualification requirements for Sealing Ring
(BHEL Drg. No.-31230401037 & 31280409041)**

Sl. No.	Pre-qualification requirements	Vendor's Response
1	Vendor should have experience of manufacturing, testing & supplying of Sealing Ring made from duplex braided pure fine graphite fiber yarn. Vendor to confirm.	
2	Supplied Sealing Ring should be suitable for the following parameters. a) Applicable Medium - Steam b) Operating Pressure – 60 bar or above c) Operating Temperature- 650 deg. C or above d) Carbon Content \geq 80% Vendor to inform the actual parameters of supplied Sealing Rings.	
3	Minimum 01 No. P.O. must have been executed by the vendor in last ten (10) years from the date of issuance of enquiry. In support of above, vendor to furnish following information for previously supplied Sealing Rings meeting technical requirement as per Sl. No.-2 above. a) Customer name and it's address b) Purchase Order No. & Date c) Name, designation, e-mail ID & Phone No. of the responsible person in customer's organization	
4	Vendor to submit the following documents of supplied Sealing Ring for the successfully executed order mentioned at Sl. No.-3 above. a) Copy of Un-Priced Purchase Order (P.O.). b) Dimensional details along with material test certificate against the above mentioned P.O. The submitted test certificates should have co-relation with P.O. c) Material acceptance certificate/dispatch document against above P.O. d) Catalogue of supplied Sealing Ring (if available).	

Note:-

1. Against vendor's replies, BHEL reserves the right to ask for more information/documents.
2. Vendor's offer shall not be considered, if vendor fails to furnish the document/information and doesn't meet the acceptance criteria as mentioned above.
3. In case information furnished by the vendor found false/incorrect, BHEL reserves the right to reject their offer.

Prepared by	Approved by
<i>Susheel</i> 11/01/22	<i>VSK</i> 11/01/2022
Susheel kothiyal (Dy. Mgr./ STE-TG)	Vikas Malhotra (Sr. Mgr./ STE-TG)